

| OHA - Drinking Water Program - Turbidity |                |               |               |                 | County: Washington |                    |                                                  |
|------------------------------------------|----------------|---------------|---------------|-----------------|--------------------|--------------------|--------------------------------------------------|
| System Name: Hillsboro-Cherry Grove      |                |               |               | ID#: 41 00985-A |                    | Month/Year: Sep-25 |                                                  |
| Day                                      | 12 AM<br>[NTU] | 4 AM<br>[NTU] | 8 AM<br>[NTU] | NOON<br>[NTU]   | 4 PM<br>[NTU]      | 8 PM<br>[NTU]      | Highest Reading of the day <sup>1</sup><br>[NTU] |
| 1                                        |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 2                                        |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 3                                        |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 4                                        |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 5                                        |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 6                                        |                |               | 0.08          |                 |                    |                    | 0.08                                             |
| 7                                        |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 8                                        |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 9                                        |                |               | 0.08          |                 |                    |                    | 0.08                                             |
| 10                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 11                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 12                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 13                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 14                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 15                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 16                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 17                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 18                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 19                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 20                                       |                |               | 0.08          |                 |                    |                    | 0.08                                             |
| 21                                       |                |               | 0.06          |                 |                    |                    | 0.06                                             |
| 22                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 23                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 24                                       |                |               | 0.07          |                 |                    |                    | 0.07                                             |
| 25                                       |                |               | 0.06          |                 |                    |                    | 0.06                                             |
| 26                                       |                |               | 0.06          |                 |                    |                    | 0.06                                             |
| 27                                       |                |               | 0.06          |                 |                    |                    | 0.06                                             |
| 28                                       |                |               | 0.06          |                 |                    |                    | 0.06                                             |
| 29                                       |                |               | 0.06          |                 |                    |                    | 0.06                                             |
| 30                                       |                |               | 0.06          |                 |                    |                    | 0.06                                             |
|                                          |                |               |               |                 |                    |                    |                                                  |

|                                                       |                                              |                                           |                                              |
|-------------------------------------------------------|----------------------------------------------|-------------------------------------------|----------------------------------------------|
| <b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>    |                                              | <b>Monthly Summary (Answer Yes or No)</b> |                                              |
| 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> | <input checked="" type="checkbox"/> Yes / No | CT's met everyday? (see back)             | <input checked="" type="checkbox"/> Yes / No |
| All daily turbidity readings ≤ 5 NTU?                 | <input checked="" type="checkbox"/> Yes / No |                                           | <input checked="" type="checkbox"/> Yes / No |
| Notes:                                                |                                              | PRINTED NAME: Todd Evers                  |                                              |
|                                                       |                                              | SIGNATURE:                                |                                              |
|                                                       |                                              | PHONE #: ( 541 ) 497-3945                 |                                              |
|                                                       |                                              | Cert: T-6149                              | DATE:<br>10/1/2025                           |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

# OHA - Drinking Water Program - Surface Water Quality Data Form

**System Name:** Hillsboro-Cherry Grove      **ID#: 41 00985-A**      **Month / Year:** Sep-25      **Disinfection Giardia Log Inactiv:** 1

| Date | Time  | Minimum Cl <sub>2</sub><br>Residual at 1st<br>User ( C ) <sup>3</sup> | Contact<br>Time<br>(T) | Actual CT | Temp  | pH   | Required CT | CT Met? <sup>3</sup> | Peak Hourly<br>Demand Flow |
|------|-------|-----------------------------------------------------------------------|------------------------|-----------|-------|------|-------------|----------------------|----------------------------|
|      |       | [ppm or mg/L]                                                         | [minutes]              | C X T     | [° C] |      | formula     | Yes / No             | [GPM]                      |
| 1    | 11:15 | 1.70                                                                  | 503                    | 856       | 16.9  | 7.22 | 28.2        | Yes                  | 375                        |
| 2    | 9:30  | 1.61                                                                  | 472                    | 760       | 16.7  | 7.22 | 28.3        | Yes                  | 400                        |
| 3    | 11:00 | 1.61                                                                  | 581                    | 935       | 17.2  | 7.22 | 27.4        | Yes                  | 325                        |
| 4    | 9:00  | 1.54                                                                  | 539                    | 830       | 16.9  | 7.23 | 27.8        | Yes                  | 350                        |
| 5    | 11:15 | 1.69                                                                  | 581                    | 981       | 17.1  | 7.23 | 27.9        | Yes                  | 325                        |
| 6    | 9:15  | 1.60                                                                  | 686                    | 1098      | 17.2  | 7.21 | 27.2        | Yes                  | 275                        |
| 7    | 9:15  | 1.54                                                                  | 539                    | 830       | 17.1  | 7.23 | 27.4        | Yes                  | 350                        |
| 8    | 8:45  | 1.63                                                                  | 755                    | 1231      | 16.9  | 7.22 | 28.0        | Yes                  | 250                        |
| 9    | 9:00  | 1.66                                                                  | 377                    | 627       | 16.9  | 7.22 | 28.1        | Yes                  | 500                        |
| 10   | 8:00  | 1.67                                                                  | 360                    | 600       | 16.7  | 7.21 | 28.4        | Yes                  | 525                        |
| 11   | 9:30  | 1.79                                                                  | 397                    | 711       | 16.7  | 7.20 | 28.7        | Yes                  | 475                        |
| 12   | 8:30  | 1.68                                                                  | 377                    | 634       | 16.7  | 7.21 | 28.4        | Yes                  | 500                        |
| 13   | 8:30  | 1.60                                                                  | 343                    | 549       | 16.4  | 7.22 | 28.8        | Yes                  | 550                        |
| 14   | 11:00 | 1.61                                                                  | 343                    | 553       | 16.7  | 7.21 | 28.2        | Yes                  | 550                        |
| 15   | 8:45  | 1.57                                                                  | 343                    | 539       | 16.3  | 7.23 | 29.0        | Yes                  | 550                        |
| 16   | 9:30  | 1.59                                                                  | 343                    | 546       | 16.2  | 7.22 | 29.2        | Yes                  | 550                        |
| 17   | 9:00  | 1.75                                                                  | 343                    | 601       | 16.1  | 7.22 | 29.9        | Yes                  | 550                        |
| 18   | 10:30 | 1.70                                                                  | 315                    | 535       | 16.1  | 7.19 | 29.4        | Yes                  | 600                        |
| 19   | 9:15  | 1.92                                                                  | 343                    | 659       | 15.9  | 7.19 | 30.6        | Yes                  | 550                        |
| 20   | 7:00  | 1.75                                                                  | 260                    | 456       | 15.8  | 7.18 | 30.1        | Yes                  | 725                        |
| 21   | 10:00 | 1.95                                                                  | 343                    | 669       | 15.9  | 7.16 | 30.3        | Yes                  | 550                        |
| 22   | 10:00 | 1.88                                                                  | 360                    | 676       | 15.7  | 7.16 | 30.5        | Yes                  | 525                        |
| 23   | 8:00  | 1.72                                                                  | 343                    | 590       | 15.5  | 7.15 | 30.2        | Yes                  | 550                        |
| 24   | 7:30  | 1.65                                                                  | 328                    | 542       | 15.2  | 7.20 | 31.2        | Yes                  | 575                        |
| 25   | 9:15  | 1.66                                                                  | 343                    | 570       | 15.3  | 7.19 | 30.9        | Yes                  | 550                        |
| 26   | 8:30  | 1.65                                                                  | 360                    | 593       | 15.2  | 7.20 | 31.2        | Yes                  | 525                        |
| 27   | 9:15  | 1.65                                                                  | 360                    | 593       | 15.2  | 7.20 | 31.2        | Yes                  | 525                        |
| 28   | 7:00  | 1.69                                                                  | 360                    | 608       | 15.0  | 7.20 | 31.7        | Yes                  | 525                        |
| 29   | 8:00  | 1.64                                                                  | 397                    | 652       | 15.0  | 7.19 | 31.4        | Yes                  | 475                        |
| 30   | 8:30  | 1.63                                                                  | 419                    | 684       | 15.4  | 7.19 | 30.6        | Yes                  | 450                        |
|      |       |                                                                       |                        |           |       |      |             |                      |                            |

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised September 2013