

OHA - Drinking Water Program - Turbidity					County: Washington		
System Name: Hillsboro-Cherry Grove			ID#: 41 00985-A		Month/Year: Oct-25		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.06				0.06
2			0.06				0.06
3			0.06				0.06
4			0.06				0.06
5			0.06				0.06
6			0.06				0.06
7			0.06				0.06
8			0.07				0.07
9			0.07				0.07
10			0.07				0.07
11			0.07				0.07
12			0.06				0.06
13			0.06				0.06
14			0.06				0.06
15			0.06				0.06
16			0.06				0.06
17			0.05				0.05
18			0.05				0.05
19			0.06				0.06
20			0.05				0.05
21			0.05				0.05
22			0.05				0.05
23			0.05				0.05
24			0.05				0.05
25			0.06				0.06
26			0.06				0.06
27			0.05				0.05
28			0.05				0.05
29			0.06				0.06
30			0.06				0.06
31			0.06				0.06

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	☒ Yes / No	CT's met everyday? (see back)	☒ Yes / No
All daily turbidity readings $\leq$ 5 NTU?	☒ Yes / No		☒ Yes / No
Notes:		PRINTED NAME: Todd Evers SIGNATURE: PHONE #: (541) 497-3945	
		Cert: T-6149 DATE: 11/5/2025	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hillsboro-Cherry Grove

ID#: 41 00985-A

**Month /
Year:** Oct-25

**Disinfection
Giardia Log
Inactiv:**

1

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	10:30	1.74	397	691	14.8	7.19	32.2	Yes	475
2	9:30	1.67	444	742	14.6	7.19	32.4	Yes	425
3	8:30	1.61	377	608	14.3	7.20	33.0	Yes	500
4	9:15	1.59	377	600	14.1	7.20	33.3	Yes	500
5	10:00	1.61	397	640	13.9	7.19	33.7	Yes	475
6	8:45	1.68	397	668	13.7	7.20	34.6	Yes	475
7	8:30	1.61	581	935	13.7	7.18	34.0	Yes	325
8	9:00	1.62	686	1112	13.7	7.17	34.0	Yes	275
9	9:00	1.63	397	648	13.2	7.18	35.3	Yes	475
10	8:15	1.68	397	668	12.9	7.19	36.3	Yes	475
11	8:41	1.65	397	656	12.7	7.19	36.7	Yes	475
12	10:00	1.65	419	692	12.5	7.20	37.3	Yes	450
13	7:30	1.77	444	786	12.3	7.19	38.7	Yes	425
14	11:30	1.86	419	780	12.2	7.19	39.3	Yes	450
15	8:00	1.58	397	628	11.8	7.21	39.4	Yes	475
16	9:00	1.68	419	705	11.5	7.22	40.8	Yes	450
17	8:15	1.76	397	699	11.6	7.21	40.7	Yes	475
18	9:00	1.63	377	615	11.4	7.22	40.8	Yes	500
19	9:15	1.59	397	632	11.5	7.22	40.3	Yes	475
20	8:30	1.63	377	615	11.4	7.22	40.8	Yes	500
21	7:45	1.61	377	608	11.3	7.23	41.1	Yes	500
22	8:30	1.63	419	684	11.3	7.24	41.3	Yes	450
23	8:45	1.59	377	600	11.4	7.24	40.9	Yes	500
24	8:30	1.78	377	672	11.3	7.22	41.8	Yes	500
25	10:30	1.67	419	700	11.3	7.31	42.6	Yes	450
26	10:30	1.70	444	755	11.1	7.21	41.8	Yes	425
27	8:45	1.59	397	632	10.8	7.23	42.4	Yes	475
28	8:00	1.57	397	624	10.6	7.23	42.9	Yes	475
29	8:00	1.67	419	700	10.3	7.22	44.0	Yes	450
30	10:00	1.36	444	604	10.3	7.23	42.7	Yes	425
31	10:30	1.63	377	615	10.3	7.20	43.5	Yes	500

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised September 2013