

OHA - Drinking Water Program - Turbidity					County: Washington		
System Name: Hillsboro-Cherry Grove				ID#: 41 00985-A		Month/Year: Nov-25	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.06				0.06
2			0.06				0.06
3			0.06				0.06
4			0.06				0.06
5			0.06				0.06
6			0.07				0.07
7			0.07				0.07
8			0.07				0.07
9			0.07				0.07
10			0.06				0.06
11			0.07				0.07
12			0.07				0.07
13			0.07				0.07
14			0.07				0.07
15			0.07				0.07
16			0.07				0.07
17			0.07				0.07
18			0.07				0.07
19			0.07				0.07
20			0.07				0.07
21			0.07				0.07
22			0.07				0.07
23			0.07				0.07
24			0.06				0.06
25			0.06				0.06
26			0.06				0.06
27			0.06				0.06
28			0.06				0.06
29			0.06				0.06
30			0.06				0.06

Slow Sand/Membrane/DE Filtration/Unfiltered				Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings $\leq$ 1 NTU? ²				☒ Yes / No		CT's met everyday? (see back)	
All daily turbidity readings $\leq$ 5 NTU?				☒ Yes / No		All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?	
				☒ Yes / No		☒ Yes / No	

Notes:	PRINTED NAME: Todd Evers		Cert: T-6149
	SIGNATURE:		DATE:
	PHONE #: (541) 497-3945		12/2/25

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hillsboro-Cherry Grove **ID#: 41 00985-A** **Month / Year:** Nov-25 **Disinfection**
Giardia Log Inactiv: 1

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	9:30	1.64	377	619	10.3	7.20	43.6	Yes	500
2	10:15	1.76	419	738	9.9	7.20	45.4	Yes	450
3	9:00	1.79	419	751	9.9	7.19	45.4	Yes	450
4	9:00	1.60	419	671	9.9	7.19	44.4	Yes	450
5	9:00	1.60	377	604	9.8	6.90	40.4	Yes	500
6	9:00	1.64	419	688	10.5	7.15	42.3	Yes	450
7	9:00	1.56	419	654	10.4	7.25	43.7	Yes	450
8	8:45	1.66	419	696	10.2	7.24	44.6	Yes	450
9	8:15	1.59	397	632	10.2	7.25	44.4	Yes	475
10	8:15	1.59	419	667	10.2	7.07	41.7	Yes	450
11	12:00	1.56	419	654	10.2	7.08	41.7	Yes	450
12	8:15	1.59	444	706	10.1	7.08	42.1	Yes	425
13	7:45	1.66	397	660	10.2	7.04	41.6	Yes	475
14	7:15	1.71	419	717	10.2	7.07	42.3	Yes	450
15	11:30	1.73	444	768	10.5	7.08	41.7	Yes	425
16	10:30	1.76	419	738	10.3	7.09	42.5	Yes	450
17	8:45	1.73	377	653	10.3	7.10	42.5	Yes	500
18	8:30	1.76	360	633	10.0	7.09	43.4	Yes	525
19	9:45	1.74	503	876	10.0	7.09	43.3	Yes	375
20	9:00	1.91	503	961	9.9	7.08	44.2	Yes	375
21	11:00	1.78	503	896	9.6	7.09	44.6	Yes	375
22	10:00	1.71	503	861	9.4	7.23	47.1	Yes	375
23	9:00	1.72	539	928	9.2	7.23	47.8	Yes	350
24	8:00	1.83	539	987	8.9	7.10	47.2	Yes	350
25	9:00	1.80	503	906	8.8	7.10	47.3	Yes	375
26	9:30	1.77	503	891	8.7	7.11	47.6	Yes	375
27	9:45	1.79	503	901	8.7	7.10	47.6	Yes	375
28	9:45	1.80	472	849	8.8	7.10	47.3	Yes	400
29	9:45	1.83	539	987	8.6	7.11	48.3	Yes	350
30	10:30	1.74	503	876	8.7	7.11	47.5	Yes	375

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.