

OHA - Drinking Water Program - Turbidity

County: **Washington**

System Name: **Hillsboro-Cherry Grove**

ID#: **41 00985-A**

Month/Year: **Dec-25**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1			0.06				0.06
2			0.06				0.06
3			0.06				0.06
4			0.06				0.06
5			0.06				0.06
6			0.07				0.07
7			0.07				0.07
8			0.07				0.07
9			0.06				0.06
10			0.07				0.07
11			0.06				0.06
12			0.06				0.06
13			0.06				0.06
14			0.07				0.07
15			0.07				0.07
16			0.07				0.07
17			0.07				0.07
18			0.07				0.07
19			0.07				0.07
20			0.07				0.07
21			0.07				0.07
22			0.07				0.07
23			0.06				0.06
24			0.06				0.06
25			0.06				0.06
26			0.06				0.06
27			0.06				0.06
28			0.06				0.06
29			0.06				0.06
30			0.06				0.06
31			0.07				0.07

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	<input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No
<b>Notes:</b>	<b>PRINTED NAME:</b> Todd Evers		<b>Cert:</b> T-6149
	<b>SIGNATURE:</b> 		<b>DATE:</b>
	<b>PHONE #:</b> ( 541 ) 497-3945		1/6/26

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**System Name:** Hillsboro-Cherry Grove    **ID#: 41 00985-A**    **Month / Year:** Dec-25    **Disinfection Giardia Log Inactiv:** 1

Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT <b>C X T</b>	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1	9:30	1.79	581	1040	8.5	7.11	48.4	Yes	325
2	8:30	1.81	581	1051	8.4	7.11	48.8	Yes	325
3	9:30	1.77	581	1028	8.4	7.10	48.4	Yes	325
4	9:00	1.66	539	895	8.3	7.12	48.5	Yes	350
5	9:30	1.65	629	1038	8.4	7.11	47.9	Yes	300
6	9:00	1.73	539	933	8.4	6.81	43.5	Yes	350
7	13:00	1.74	629	1095	8.6	6.80	42.9	Yes	300
8	10:00	1.76	581	1022	8.7	6.80	42.7	Yes	325
9	11:30	1.73	581	1005	8.9	6.80	42.0	Yes	325
10	9:15	1.84	581	1069	9.3	6.79	41.2	Yes	325
11	9:30	1.89	581	1098	9.3	6.79	41.5	Yes	325
12	8:00	1.72	581	999	9.2	6.80	41.1	Yes	325
13	11:00	1.77	629	1114	9.2	6.79	41.2	Yes	300
14	10:30	1.76	581	1022	9.3	6.80	41.0	Yes	325
15	9:00	1.70	629	1070	9.4	6.80	40.5	Yes	300
16	9:00	1.73	581	1005	9.4	6.79	40.5	Yes	325
17	7:15	1.64	686	1126	9.2	6.78	40.5	Yes	275
18	8:45	1.69	629	1063	9.2	6.78	40.7	Yes	300
19	8:30	1.59	755	1200	9.5	6.76	39.2	Yes	250
20	12:45	1.76	755	1329	9.4	6.75	40.0	Yes	250
21	12:45	1.70	686	1167	9.3	6.75	40.0	Yes	275
22	8:30	1.71	755	1291	8.9	6.81	42.0	Yes	250
23	10:30	1.54	686	1057	8.9	6.77	40.7	Yes	275
24	7:15	1.43	755	1080	8.7	6.75	40.4	Yes	250
25	11:15	1.69	755	1276	8.6	6.74	41.7	Yes	250
26	9:00	1.76	686	1208	8.4	6.74	42.6	Yes	275
27	11:45	1.83	755	1382	8.3	6.73	43.1	Yes	250
28	9:30	1.89	755	1427	8.2	6.74	43.8	Yes	250
29	10:00	1.60	755	1208	8.0	6.75	43.1	Yes	250
30	9:30	1.56	686	1071	8.1	6.89	44.8	Yes	275
31	8:30	1.58	686	1084	7.9	6.79	43.9	Yes	275

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.