

OHA - Drinking Water Program - Turbidity

County: Washington

System Name: Hillsboro-Cherry Grove

ID#: 41 00985-A

Month/Year: Jan-26

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.07				0.07
2			0.06				0.06
3			0.06				0.06
4			0.06				0.06
5			0.05				0.05
6			0.06				0.06
7			0.05				0.05
8			0.05				0.05
9			0.06				0.06
10			0.06				0.06
11			0.06				0.06
12			0.06				0.06
13			0.06				0.06
14			0.06				0.06
15			0.06				0.06
16			0.06				0.06
17			0.06				0.06
18			0.06				0.06
19			0.05				0.05
20			0.05				0.05
21			0.05				0.05
22			0.05				0.05
23			0.05				0.05
24			0.05				0.05
25			0.05				0.05
26			0.05				0.05
27			0.05				0.05
28			0.05				0.05
29			0.05				0.05
30			0.05				0.05
31			0.05				0.05

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
Notes:		PRINTED NAME: Todd Evers SIGNATURE:  PHONE #: (541) 497-3945	
		Cert: T-6149 DATE: 2/3/2026	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hillsboro-Cherry Grove **ID#: 41 00985-A** **Month / Year:** Jan-26 **Disinfection Giardia Log Inactiv:** 1

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	10:00	1.89	686	1297	7.7	6.77	45.8	Yes	275
2	9:30	1.96	686	1345	7.6	6.77	46.4	Yes	275
3	10:30	1.80	686	1235	7.5	6.77	45.9	Yes	275
4	10:30	1.68	629	1057	7.5	6.79	45.6	Yes	300
5	8:00	1.66	686	1139	7.3	6.78	45.9	Yes	275
6	8:30	1.79	686	1229	7.5	6.77	45.9	Yes	275
7	9:30	1.80	686	1235	7.7	6.77	45.3	Yes	275
8	9:30	1.78	686	1222	7.5	6.79	46.1	Yes	275
9	8:00	1.86	629	1170	7.5	6.78	46.4	Yes	300
10	9:30	1.68	686	1153	7.3	6.79	46.2	Yes	275
11	10:00	1.84	686	1263	7.3	6.78	46.9	Yes	275
12	8:30	1.87	686	1283	7.4	6.77	46.6	Yes	275
13	9:30	1.76	686	1208	7.3	6.78	46.5	Yes	275
14	8:30	1.77	581	1028	7.3	6.79	46.7	Yes	325
15	8:15	1.84	686	1263	7.3	6.79	47.1	Yes	275
16	8:45	1.79	686	1229	7.4	6.80	46.7	Yes	275
17	9:30	1.85	629	1164	7.3	6.97	50.2	Yes	300
18	10:00	1.93	629	1214	7.2	6.79	47.9	Yes	300
19	9:30	1.70	1079	1834	7.3	6.79	46.3	Yes	175
20	8:15	1.56	1079	1683	7.2	6.81	46.2	Yes	175
21	8:30	1.80	1258	2265	7.1	6.80	47.6	Yes	150
22	6:30	1.98	1258	2491	6.2	6.90	53.5	Yes	150
23	12:00	1.69	1258	2127	7.0	6.81	47.5	Yes	150
24	8:15	1.55	944	1463	6.6	6.83	48.4	Yes	200
25	8:15	1.55	1258	1950	6.4	6.83	49.0	Yes	150
26	9:00	1.77	1510	2673	6.5	6.81	49.6	Yes	125
27	10:15	1.81	1079	1952	6.4	6.81	50.2	Yes	175
28	8:15	1.67	1079	1801	6.3	6.83	50.0	Yes	175
29	8:30	1.60	839	1342	6.3	6.84	49.8	Yes	225
30	9:00	1.80	629	1132	6.1	6.83	51.5	Yes	300
31	9:30	1.72	686	1181	6.2	6.84	50.9	Yes	275

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.