

OHA - Drinking Water Program - Turbidity

County: **Washington**

System Name: **Hillsboro-Cherry Grove**

ID#: **41 00985-A**

Month/Year: **Mar-26**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.05				0.05
2			0.06				0.06
3			0.05				0.05
4			0.05				0.05
5			0.06				0.06
6			0.06				0.06
7			0.06				0.06
8			0.06				0.06
9			0.06				0.06
10			0.06				0.06
11			0.06				0.06
12			0.06				0.06
13			0.06				0.06
14			0.06				0.06
15			0.06				0.06
16			0.06				0.06
17			0.06				0.06
18			0.06				0.06
19			0.06				0.06
20			0.06				0.06
21			0.06				0.06
22			0.06				0.06
23			0.06				0.06
24			0.06				0.06
25			0.06				0.06
26			0.06				0.06
27			0.06				0.06
28			0.06				0.06
29			0.06				0.06
30			0.06				0.06
31			0.06				0.06

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
Notes:		PRINTED NAME: Todd Evers SIGNATURE: <i>Todd Evers</i> PHONE #: (541) 497-3945	
		Cert: T-6149 DATE: 4/2/2026	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hillsboro-Cherry Grove **ID#: 41 00985-A** **Month / Year:** Mar-26 **Disinfection Giardia Log Inactiv:** 1

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	9:45	1.68	686	1153	7.1	6.92	49.0	Yes	275
2	8:30	1.74	686	1194	7.2	6.92	49.1	Yes	275
3	9:15	1.67	686	1146	7.4	6.92	48.0	Yes	275
4	10:45	1.75	755	1321	7.4	6.90	48.1	Yes	250
5	8:45	1.73	629	1088	7.5	6.92	48.0	Yes	300
6	8:30	1.94	629	1221	7.6	6.91	48.7	Yes	300
7	11:00	1.65	686	1132	7.9	6.89	45.9	Yes	275
8	13:30	1.78	755	1344	8.0	6.89	46.2	Yes	250
9	8:30	1.80	686	1235	7.8	6.90	47.1	Yes	275
10	8:15	1.76	755	1329	7.9	6.90	46.6	Yes	250
11	8:30	1.73	629	1088	8.0	6.91	46.3	Yes	300
12	11:30	1.69	686	1160	8.1	6.92	45.9	Yes	275
13	9:00	1.58	686	1084	8.1	6.94	45.7	Yes	275
14	9:30	1.66	686	1139	8.1	6.94	46.1	Yes	275
15	9:00	1.70	686	1167	8.2	6.95	46.2	Yes	275
16	8:45	1.81	686	1242	8.5	6.93	45.5	Yes	275
17	9:00	1.79	629	1126	8.5	6.94	45.6	Yes	300
18	9:00	1.59	629	1000	8.7	6.96	44.3	Yes	300
19	8:30	1.68	686	1153	8.9	6.95	44.0	Yes	275
20	8:45	1.83	686	1256	9.1	6.95	44.2	Yes	275
21	9:15	1.72	755	1299	9.2	6.95	43.3	Yes	250
22	9:15	1.79	755	1351	9.2	6.93	43.4	Yes	250
23	8:30	1.78	686	1222	9.3	6.93	43.0	Yes	275
24	8:30	1.83	755	1382	9.6	6.94	42.6	Yes	250
25	9:00	1.65	581	958	9.5	6.95	42.1	Yes	325
26	8:30	1.65	581	958	9.4	6.94	42.3	Yes	325
27	9:30	1.73	581	1005	9.5	6.94	42.4	Yes	325
28	9:15	1.64	629	1032	9.6	6.94	41.7	Yes	300
29	9:45	1.65	686	1132	9.7	6.94	41.4	Yes	275
30	8:45	1.71	629	1076	9.6	6.93	41.9	Yes	300
31	9:00	1.68	629	1057	9.7	6.94	41.6	Yes	300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.