

Water Services - Turbidity Monitoring Report Form

County: Lane

Cartridge or Bag Filtration

Month/Year: Apr '21

System Name: Lakeshore RV Park

ID# 4101001

WTP ID:

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	22	15	7	15	.48	
2					.49	
3					.49	
4					.50	
5					.50	
6					.51	
7					.51	
8					.50 .50	
9					.50	
10					.48	
11					.47	
12					.47	
13					.49	
14					.48	
15					.48	
16					.47	
17					.48	
18					.47	
19					.50	
20					.51	
21					.51	
22					.50	
23					.52	
24					.52	
25					.52	
26					.50	
27					.50	
28					.48	
29					.48	
30	22	15	7	15	.48	
31						

Cartridge Filtration Monthly Summary

Monthly Summary (Answer Yes or No)

% of daily turbidity readings ≤ 1 NTU? Yes / No
 daily turbidity readings ≤ 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point ≥ 0.2 mg/L? Yes / No

PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Zeck Lupton
 SIGNATURE: [Signature] DATE: 5/8/21
 PHONE #: (541) 997-2741 CERT #:

OHA - Drinking Water Services - Surface Water Quality Data Form

Month/Year: Apr '21

System Name: <u>Lakeshore Rv Park</u>		ID# <u>41 01001</u>		WTP				
Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	(Yes) No	[GPM]
<u>1/10</u>	<u>1.0</u>	<u>40</u>	<u>10</u>	<u>10</u>	<u>6.6</u>	<u>37</u>	<u>Y</u>	<u>60</u>
<u>2/</u>					<u>6.6</u>			
<u>3/</u>					<u>6.7</u>			
<u>4/</u>					<u>6.7</u>			
<u>5/</u>					<u>6.9</u>			
<u>6/</u>					<u>6.9</u>			
<u>7/</u>					<u>6.9</u>			
<u>8/</u>					<u>6.8</u>			
<u>9/</u>					<u>6.7</u>			
<u>10/</u>					<u>6.7</u>			
<u>11/</u>					<u>7.0</u>			
<u>12/</u>					<u>7.0</u>			
<u>13/</u>					<u>6.9</u>			
<u>14/</u>					<u>6.9</u>			
<u>15/</u>					<u>6.9</u>			
<u>16/</u>					<u>6.8</u>			
<u>17/</u>					<u>6.8</u>			
<u>18/</u>					<u>6.9</u>			
<u>19/</u>					<u>7.0</u>			
<u>20/</u>					<u>7.0</u>			
<u>21/</u>					<u>7.0</u>			
<u>22/</u>					<u>7.0</u>			
<u>23/</u>					<u>6.8</u>			
<u>24/</u>					<u>6.8</u>			
<u>25/</u>					<u>6.8</u>			
<u>26/</u>					<u>6.9</u>			
<u>7/</u>					<u>6.9</u>			
<u>8/</u>					<u>7.0</u>			
<u>9/</u>					<u>7.0</u>			
<u>10/10</u>	<u>1.0</u>	<u>40</u>	<u>10</u>	<u>10</u>	<u>6.8</u>	<u>37</u>	<u>Y</u>	<u>60</u>

If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours.

Revised August 2016

download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to:

dwp.dnce@state.or.us: Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97223-0350