

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Lane
Month/Year: MAR 25

Cartridge or Bag Filtration

System Name: <u>LAKE SHORE RV PARK</u>		ID# <u>41 01001</u>		WTP ID:		Highest Reading of the Day ¹ [NTU]
DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	
1	34	20	10	15	.27	SAME
2	34	20	10	15	.37	SAME
3	34	20	10	15	.37	SAME
4	34	20	10	15	.37	SAME
5	34	20	10	15	.31	SAME
6	34	20	10	15	.31	SAME
7	34	20	10	15	.31	SAME
8	34	20	10	15	.33	SAME
9	34	20	10	15	.33	SAME
10	34	20	10	15	.28	SAME
11	34	20	10	15	.28	SAME
12	34	20	10	15	.28	SAME
13	34	20	10	15	.30	SAME
14	34	20	10	15	.30	SAME
15	34	20	10	15	.30	SAME
16	34	20	10	15	.31	SAME
17	34	20	10	15	.31	SAME
18	34	20	10	15	.31	SAME
19	34	20	10	15	.29	SAME
20	34	20	10	15	.29	SAME
21	34	20	10	15	.29	SAME
22	34	20	10	15	.29	SAME
23	34	20	10	15	.29	SAME
24	34	20	10	15	.29	SAME
25	34	20	10	15	.31	SAME
26	34	20	10	15	.31	SAME
27	34	20	10	15	.31	SAME
28	34	20	10	15	.31	SAME
29	34	20	10	15	.33	SAME
30	34	20	10	15	.33	SAME
31	34	20	10	15	.33	SAME

Cartridge Filtration Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? ☒ Yes / ☐ No
All daily turbidity readings ≤ 5 NTU? ☒ Yes / ☐ No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)
☒ Yes / ☐ No

All Cl₂ residual at entry point ≥ 0.2 mg/l?
☒ Yes / ☐ No

Notes: PSI = pounds per square inch
PSID = pounds per square inch difference (before filter - after filter)
PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME:

Mike Blankenship

SIGNATURE:

[Signature]

DATE:

4.7.25

PHONE #:

541 997-2741

CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

Month/Year: Mar 25

System Name: <u>LAKESHORE RV PARK</u>		ID# 41 <u>01001</u>		WTP		Peak Hourly Demand Flow		
Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	
1 /	.7	65	45.5	10	6.8	37	Y	5
2 /	.7	65	45.5	10	6.8	37	Y	5
3 /	.7	65	45.5	10	6.8	37	Y	5
4 /	.7	65	45.5	10	6.8	37	Y	5
5 /	.7	65	45.5	10	6.8	37	Y	5
6 /	.7	65	45.5	10	6.8	37	Y	5
7 /	.7	65	45.5	10	6.8	37	Y	5
8 /	.7	65	45.5	10	6.8	37	Y	5
9 /	.7	65	45.5	10	6.8	37	Y	5
10 /	.7	65	45.5	10	6.8	37	Y	5
11 /	.7	65	45.5	10	6.8	37	Y	5
12 /	.7	65	45.5	10	6.8	37	Y	5
13 /	.7	65	45.5	10	6.8	37	Y	5
14 /	.7	65	45.5	10	6.8	37	Y	5
15 /	.7	65	45.5	10	6.8	37	Y	5
16 /	.7	65	45.5	10	6.8	37	Y	5
17 /	.7	65	45.5	10	6.8	37	Y	5
18 /	.7	65	45.5	10	6.8	37	Y	5
19 /	.7	65	45.5	10	6.8	37	Y	5
20 /	.7	65	45.5	10	6.8	37	Y	5
21 /	.7	65	45.5	10	6.8	37	Y	5
22 /	.7	65	45.5	10	6.8	37	Y	5
23 /	.7	65	45.5	10	6.8	37	Y	5
24 /	.7	65	45.5	10	6.8	37	Y	5
25 /	.7	65	45.5	10	6.8	37	Y	5
26 /	.7	65	45.5	10	6.8	37	Y	5
27 /	.7	65	45.5	10	6.8	37	Y	5
28 /	.7	65	45.5	10	6.8	37	Y	5
29 /	.7	65	45.5	10	6.8	37	Y	5
30 /	.7	65	45.5	10	6.8	37	Y	5
31 /	.7	65	45.5	10	6.8	37	Y	5

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours.

Revised November 2022

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to:

dwp.dmce@oha.oregon.gov; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350