

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Lane
Cartridge or Bag Filtration						Month/Year:	September 2025
System Name:	Lakeshore RV Park		4101001		WTP ID:	TP-	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]	
1	34.00	20.00	14.00	15.00	0.31	same	
2	34.00	20.00	14.00	15.00	0.31	same	
3	34.00	20.00	14.00	15.00	0.29	same	
4	34.00	20.00	14.00	15.00	0.29	same	
5	34.00	20.00	14.00	15.00	0.29	same	
6	34.00	20.00	14.00	15.00	0.30	same	
7	34.00	20.00	14.00	15.00	0.30	same	
8	34.00	20.00	14.00	15.00	0.30	same	
9	34.00	20.00	14.00	15.00	0.29	same	
10	34.00	20.00	14.00	15.00	0.29	same	
11	34.00	20.00	14.00	15.00	0.29	same	
12	34.00	20.00	14.00	15.00	0.32	same	
13	34.00	20.00	14.00	15.00	0.32	same	
14	34.00	20.00	14.00	15.00	0.32	same	
15	34.00	20.00	14.00	15.00	0.33	same	
16	34.00	20.00	14.00	15.00	0.33	same	
17	34.00	20.00	14.00	15.00	0.33	same	
18	34.00	20.00	14.00	15.00	0.29	same	
19	34.00	20.00	14.00	15.00	0.29	same	
20	34.00	20.00	14.00	15.00	0.29	same	
21	34.00	20.00	14.00	15.00	0.32	same	
22	34.00	20.00	14.00	15.00	0.32	same	
23	34.00	20.00	14.00	15.00	0.32	same	
24	34.00	20.00	14.00	15.00	0.27	same	
25	34.00	20.00	14.00	15.00	0.27	same	
26	34.00	20.00	14.00	15.00	0.27	same	
27	34.00	20.00	14.00	15.00	0.25	same	
28	34.00	20.00	14.00	15.00	0.25	same	
29	34.00	20.00	14.00	15.00	0.25	same	
30	34.00	20.00	14.00	15.00	0.27	same	
31							
Cartridge & Bag Filtration					SIGNATURE:		
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	Yes		
Notes: PSI = pounds per square inch					PRINTED NAME: Natalie Blankenship		
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE: Natalie Blankenship		
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					DATE: 10.7.2025		
					PHONE #: ()5419972741		
					CERT #:		

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form						WTP - :	
System Name:	Lakeshore RV Park	ID#:	41 01001	Month/Year:	September 2025	Disinfection Giardia Log Inactiv:	1

Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	65	52.0	15.0	6.80	24.7	YES	5
2	0.8	65	52.0	15.0	6.80	24.7	YES	5
3	0.8	65	52.0	15.0	6.80	24.7	YES	5
4	0.8	65	52.0	15.0	6.80	24.7	YES	5
5	0.8	65	52.0	15.0	6.80	24.7	YES	5
6	0.8	65	52.0	15.0	6.80	24.7	YES	5
7	0.8	65	52.0	15.0	6.80	24.7	YES	5
8	0.8	65	52.0	15.0	6.80	24.7	YES	5
9	0.8	65	52.0	15.0	6.80	24.7	YES	5
10	0.8	65	52.0	15.0	6.80	24.7	YES	5
11	0.8	65	52.0	15.0	6.80	24.7	YES	5
12	0.8	65	52.0	15.0	6.80	24.7	YES	5
13	0.8	65	52.0	15.0	6.80	24.7	YES	5
14	0.8	65	52.0	15.0	6.80	24.7	YES	5
15	0.8	65	52.0	15.0	6.80	24.7	YES	5
16	0.8	65	52.0	15.0	6.80	24.7	YES	5
17	0.8	65	52.0	15.0	6.80	24.7	YES	5
18	0.8	65	52.0	15.0	6.80	24.7	YES	5
19	0.8	65	52.0	15.0	6.80	24.7	YES	5
20	0.8	65	52.0	15.0	6.80	24.7	YES	5
21	0.8	65	52.0	15.0	6.80	24.7	YES	5
22	0.8	65	52.0	15.0	6.80	24.7	YES	5
23	0.8	65	52.0	15.0	6.80	24.7	YES	5
24	0.8	65	52.0	15.0	6.80	24.7	YES	5
25	0.8	65	52.0	15.0	6.80	24.7	YES	5
26	0.8	65	52.0	15.0	6.80	24.7	YES	5
27	0.8	65	52.0	15.0	6.80	24.7	YES	5
28	0.8	65	52.0	15.0	6.80	24.7	YES	5
29	0.8	65	52.0	15.0	6.80	24.7	YES	5
30	0.8	65	52.0	15.0	6.80	24.7	YES	5
31								

2 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.
Return by 10th of following month by email, fax, or mail to:
dws.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350