

OHA - Drinking Water Services - Surface Water Quality Data Form

County:

Lane

Cartridge or Bag Filtration

Month/Year:

October 2025

System Name:		Lakeshore RV Park		ID#:	4101001		WTP ID:	TP-	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]			
1	34.00	20.00	14.00	15.00	0.27	same			
2	34.00	20.00	14.00	15.00	0.27	same			
3	34.00	20.00	14.00	15.00	0.25	same			
4	34.00	20.00	14.00	15.00	0.25	same			
5	34.00	20.00	14.00	15.00	0.29	same			
6	34.00	20.00	14.00	15.00	0.29	same			
7	34.00	20.00	14.00	15.00	0.25	same			
8	34.00	20.00	14.00	15.00	0.25	same			
9	34.00	20.00	14.00	15.00	0.25	same			
10	34.00	20.00	14.00	15.00	0.25	same			
11	34.00	20.00	14.00	15.00	0.25	same			
12	34.00	20.00	14.00	15.00	0.25	same			
13	34.00	20.00	14.00	15.00	0.25	same			
14	34.00	20.00	14.00	15.00	0.26	same			
15	34.00	20.00	14.00	15.00	0.25	same			
16	34.00	20.00	14.00	15.00	0.25	same			
17	34.00	20.00	14.00	15.00	0.25	same			
18	34.00	20.00	14.00	15.00	0.26	same			
19	34.00	20.00	14.00	15.00	0.26	same			
20	34.00	20.00	14.00	15.00	0.26	same			
21	34.00	20.00	14.00	15.00	0.23	same			
22	34.00	20.00	14.00	15.00	0.23	same			
23	34.00	20.00	14.00	15.00	0.23	same			
24	34.00	20.00	14.00	15.00	0.27	same			
25	34.00	20.00	14.00	15.00	0.27	same			
26	34.00	20.00	14.00	15.00	0.27	same			
27	34.00	20.00	14.00	15.00	0.29	same			
28	34.00	20.00	14.00	15.00	0.29	same			
29	34.00	20.00	14.00	15.00	0.29	same			
30	34.00	20.00	14.00	15.00	0.30	same			
31	34.00	20.00	14.00	15.00	0.30	same			
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 1 NTU?			Yes		CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?			
All daily turbidity readings ≤ 5 NTU?			Yes		Yes	Yes			
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					PRINTED NAME: Natalie Blankenship				
					SIGNATURE:			DATE:11.7.25	
					PHONE #: (541) 541.991.7821			CERT #:	

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form				WTP- :	
System Name:	Lakeshore RV Park	ID#: 41 01001	Month/Year: October 2025	Disinfection <i>Giardia</i> Log Inactiv:	1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	65	52.0	15.0	6.80	24.7	YES	5
2	0.7	65	45.5	15.0	6.80	24.4	YES	5
3	0.8	65	52.0	15.0	6.80	24.7	YES	5
4	0.8	65	52.0	15.0	6.80	24.7	YES	5
5	0.7	65	45.5	15.0	6.80	24.4	YES	5
6	0.8	65	52.0	15.0	6.80	24.7	YES	5
7	0.7	65	45.5	15.0	6.80	24.4	YES	5
8	0.8	65	52.0	15.0	6.80	24.7	YES	5
9	0.8	65	52.0	15.0	6.80	24.7	YES	5
10	0.9	65	58.5	15.0	6.80	25.0	YES	5
11	0.8	65	52.0	15.0	6.80	24.7	YES	5
12	0.9	65	58.5	15.0	6.80	25.0	YES	5
13	0.9	65	58.5	15.0	6.80	25.0	YES	5
14	0.9	65	58.5	15.0	6.80	25.0	YES	5
15	0.8	65	52.0	15.0	6.80	24.7	YES	5
16	0.9	65	58.5	15.0	6.80	25.0	YES	5
17	0.8	65	52.0	15.0	6.80	24.7	YES	5
18	0.8	65	52.0	15.0	6.80	24.7	YES	5
19	0.7	65	45.5	15.0	6.80	24.4	YES	5
20	0.7	65	45.5	15.0	6.80	24.4	YES	5
21	0.8	65	52.0	15.0	6.80	24.7	YES	5
22	0.7	65	45.5	15.0	6.80	24.4	YES	5
23	0.8	65	52.0	15.0	6.80	24.7	YES	5
24	0.9	65	58.5	15.0	6.80	25.0	YES	5
25	0.9	65	58.5	15.0	6.80	25.0	YES	5
26	0.9	65	58.5	15.0	6.80	25.0	YES	5
27	0.8	65	52.0	15.0	6.80	24.7	YES	5
28	0.9	65	58.5	15.0	6.80	25.0	YES	5
29	0.9	65	58.5	15.0	6.80	25.0	YES	5
30	0.9	65	58.5	15.0	6.80	25.0	YES	5
31	0.9	65	58.5	15.0	6.80	25.0	YES	5