

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Lane
Cartridge or Bag Filtration						Month/Year:	Nov. 2025
System Name:	Lakeshore RV Park			ID#: 4101001	WTP ID: TP-		
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]	
1	23.00	21.00	2.00	15.00	0.30	same	
2	23.00	21.00	2.00	15.00	0.33	same	
3	23.00	21.00	2.00	15.00	0.33	same	
4	23.00	21.00	2.00	15.00	0.32	same	
5	23.00	21.00	2.00	15.00	0.32	same	
6	23.00	21.00	2.00	15.00	0.32	same	
7	23.00	21.00	2.00	15.00	0.32	same	
8	23.00	21.00	2.00	15.00	0.26	same	
9	23.00	21.00	2.00	15.00	0.26	same	
10	23.00	21.00	2.00	15.00	0.26	same	
11	23.00	21.00	2.00	15.00	0.33	same	
12	23.00	21.00	2.00	15.00	0.33	same	
13	23.00	21.00	2.00	15.00	0.33	same	
14	23.00	21.00	2.00	15.00	0.26	same	
15	23.00	21.00	2.00	15.00	0.26	same	
16	23.00	21.00	2.00	15.00	0.26	same	
17	23.00	21.00	2.00	15.00	0.23	same	
18	23.00	21.00	2.00	15.00	0.23	same	
19	23.00	21.00	2.00	15.00	0.23	same	
20	23.00	21.00	2.00	15.00	0.27	same	
21	23.00	21.00	2.00	15.00	0.27	same	
22	23.00	21.00	2.00	15.00	0.27	same	
23	23.00	21.00	2.00	15.00	0.25	same	
24	23.00	21.00	2.00	15.00	0.25	same	
25	23.00	21.00	2.00	15.00	0.25	same	
26	23.00	21.00	2.00	15.00	0.27	same	
27	23.00	21.00	2.00	15.00	0.27	same	
28	23.00	21.00	2.00	15.00	0.27	same	
29	23.00	21.00	2.00	15.00	0.24	same	
30	23.00	21.00	2.00	15.00	0.24	same	
31							
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?				Yes	Yes	Yes	
Notes: PSI = pounds per square inch					PRINTED NAME: Natalie Blankenship		
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE:		DATE: 12.5.2025
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					PHONE #: (541) 991.7821		CERT #:
1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.							
PAGE 1 of 2							

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP - :	
System Name:	Lakeshore RV Park	ID#: 41 01001		Month/Year: November 2025	Disinfection <i>Giardia</i> Log Inactiv:	1		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.9	65	58.5	14.4	6.80	26.0	YES	5
2	0.8	65	52.0	14.4	6.80	25.7	YES	5
3	0.8	65	52.0	14.4	6.80	25.7	YES	5
4	0.9	65	58.5	14.4	6.80	26.0	YES	5
5	0.7	65	45.5	14.4	6.80	25.4	YES	5
6	0.7	65	45.5	14.4	6.80	25.4	YES	5
7	0.8	65	52.0	14.4	6.80	25.7	YES	5
8	0.7	65	45.5	14.4	6.80	25.4	YES	5
9	0.7	65	45.5	14.4	6.80	25.4	YES	5
10	0.8	65	52.0	14.4	6.80	25.7	YES	5
11	0.7	65	45.5	14.4	6.80	25.4	YES	5
12	0.7	65	45.5	14.4	6.80	25.4	YES	5
13	0.7	65	45.5	14.4	6.80	25.4	YES	5
14	0.8	65	52.0	14.4	6.80	25.7	YES	5
15	0.8	65	52.0	14.4	6.80	25.7	YES	5
16	0.8	65	52.0	14.4	6.80	25.7	YES	5
17	0.7	65	45.5	14.4	6.80	25.4	YES	5
18	0.8	65	52.0	14.4	6.80	25.7	YES	5
19	0.7	65	45.5	14.4	6.80	25.4	YES	5
20	0.8	65	52.0	14.4	6.80	25.7	YES	5
21	0.8	65	52.0	14.4	6.80	25.7	YES	5
22	0.8	65	52.0	14.4	6.80	25.7	YES	5
23	0.7	65	45.5	14.4	6.80	25.4	YES	5
24	0.7	65	45.5	14.4	6.80	25.4	YES	5
25	0.8	65	52.0	14.4	6.80	25.7	YES	5
26	0.8	65	52.0	14.4	6.80	25.7	YES	5
27	0.8	65	52.0	14.4	6.80	25.7	YES	5
28	0.7	65	45.5	14.4	6.80	25.4	YES	5
29	0.8	65	52.0	14.4	6.80	25.7	YES	5
30	0.8	65	52.0	14.4	6.80	25.7	YES	5
31								

2 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022

PAGE 2 of 2