

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lane

Cartridge or Bag Filtration

Month/Year: December/2025

System Name: Lakeshore RV Park ID#: 41 01001 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	33.00	29.00	4.00	15.00	0.24	same
2	33.00	29.00	4.00	15.00	0.23	same
3	33.00	29.00	4.00	15.00	0.24	same
4	33.00	29.00	4.00	15.00	0.23	same
5	33.00	29.00	4.00	15.00	0.23	same
6	33.00	29.00	4.00	15.00	0.26	same
7	33.00	29.00	4.00	15.00	0.25	same
8	33.00	29.00	4.00	15.00	0.23	same
9	33.00	29.00	4.00	15.00	0.24	same
10	33.00	29.00	4.00	15.00	0.23	same
11	33.00	29.00	4.00	15.00	0.23	same
12	33.00	29.00	4.00	15.00	0.25	same
13	33.00	29.00	4.00	15.00	0.22	same
14	33.00	29.00	4.00	15.00	0.25	same
15	33.00	29.00	4.00	15.00	0.23	same
16	33.00	29.00	4.00	15.00	0.24	same
17	33.00	29.00	4.00	15.00	0.24	same
18	33.00	29.00	4.00	15.00	0.26	same
19	33.00	29.00	4.00	15.00	0.26	same
20	33.00	29.00	4.00	15.00	0.28	same
21	33.00	29.00	4.00	15.00	0.27	same
22	33.00	29.00	4.00	15.00	0.24	same
23	33.00	29.00	4.00	15.00	0.26	same
24	33.00	29.00	4.00	15.00	0.23	same
25	33.00	29.00	4.00	15.00	0.24	same
26	33.00	29.00	4.00	15.00	0.31	same
27	33.00	29.00	4.00	15.00	0.28	same
28	33.00	29.00	4.00	15.00	0.24	same
29	33.00	29.00	4.00	15.00	0.27	same
30	33.00	29.00	4.00	15.00	0.29	same
31	33.00	29.00	4.00	15.00	0.27	same

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)
95% of daily turbidity readings ≤ 1 NTU? Yes	CT's met everyday? (see back) Yes
All daily turbidity readings ≤ 5 NTU? Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Natalie Blankenship
 SIGNATURE: _____ DATE: 1.8.2026
 PHONE #: (541) 991.7821 CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	Lakeshore RV Park	ID#: 41 01001	Month/Year:	December 2025	Disinfection <i>Giardia</i> Log Inactiv:	1
---------------------	-------------------	----------------------	--------------------	---------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	65	52.0	14.4	6.80	25.7	YES	5
2	0.8	65	52.0	14.4	6.80	25.7	YES	5
3	0.8	65	52.0	14.4	6.80	25.7	YES	5
4	0.8	65	52.0	13.9	6.80	26.6	YES	5
5	0.8	65	52.0	13.9	6.80	26.6	YES	5
6	0.8	65	52.0	13.9	6.80	26.6	YES	5
7	0.8	65	52.0	13.9	6.80	26.6	YES	5
8	0.8	65	52.0	13.9	6.80	26.6	YES	5
9	0.8	65	52.0	13.9	6.80	26.6	YES	5
10	0.8	65	52.0	13.9	6.80	26.6	YES	5
11	0.8	65	52.0	13.9	6.80	26.6	YES	5
12	0.8	65	52.0	13.9	6.80	26.6	YES	5
13	0.8	65	52.0	13.3	6.80	27.7	YES	5
14	0.8	65	52.0	13.3	6.80	27.7	YES	5
15	0.8	65	52.0	13.3	6.80	27.7	YES	5
16	0.8	65	52.0	13.3	6.80	27.7	YES	5
17	0.8	65	52.0	13.3	6.80	27.7	YES	5
18	0.8	65	52.0	13.3	6.80	27.7	YES	5
19	0.8	65	52.0	13.3	6.80	27.7	YES	5
20	0.8	65	52.0	12.8	6.80	28.6	YES	5
21	0.8	65	52.0	12.8	6.80	28.6	YES	5
22	0.8	65	52.0	12.8	6.80	28.6	YES	5
23	0.8	65	52.0	12.8	6.80	28.6	YES	5
24	0.8	65	52.0	12.8	6.80	28.6	YES	5
25	0.8	65	52.0	12.8	6.80	28.6	YES	5
26	0.8	65	52.0	12.8	6.80	28.6	YES	5
27	0.8	65	52.0	12.8	6.80	28.6	YES	5
28	0.8	65	52.0	12.8	6.80	28.6	YES	5
29	0.8	65	52.0	12.8	6.80	28.6	YES	5
30	0.8	65	52.0	12.2	6.80	30.6	YES	5
31	0.8	65	52.0	12.2	6.80	30.6	YES	5

2 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dup.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350