

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lane

Cartridge or Bag Filtration

Month/Year: Jan 2026

System Name: Lakeshore RV Park ID#: 4101001 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	30.00	22.00	8.00	15.00	0.27	same
2	30.00	22.00	8.00	15.00	0.26	same
3	30.00	22.00	8.00	15.00	0.27	same
4	30.00	22.00	8.00	15.00	0.26	same
5	30.00	22.00	8.00	15.00	0.26	same
6	30.00	22.00	8.00	15.00	0.27	same
7	30.00	22.00	8.00	15.00	0.28	same
8	30.00	22.00	8.00	15.00	0.26	same
9	30.00	22.00	8.00	15.00	0.27	same
10	30.00	22.00	8.00	15.00	0.29	same
11	30.00	22.00	8.00	15.00	0.25	same
12	30.00	22.00	8.00	15.00	0.26	same
13	30.00	22.00	8.00	15.00	0.25	same
14	30.00	22.00	8.00	15.00	0.25	same
15	30.00	22.00	8.00	15.00	0.26	same
16	30.00	22.00	8.00	15.00	0.27	same
17	30.00	22.00	8.00	15.00	0.27	same
18	30.00	22.00	8.00	15.00	0.24	same
19	30.00	22.00	8.00	15.00	0.24	same
20	30.00	22.00	8.00	15.00	0.23	same
21	30.00	22.00	8.00	15.00	0.24	same
22	30.00	22.00	8.00	15.00	0.25	same
23	30.00	22.00	8.00	15.00	0.24	same
24	30.00	22.00	8.00	15.00	0.25	same
25	30.00	22.00	8.00	15.00	0.28	same
26	30.00	22.00	8.00	15.00	0.28	same
27	30.00	22.00	8.00	15.00	0.25	same
28	30.00	22.00	8.00	15.00	0.24	same
29	30.00	22.00	8.00	15.00	0.26	same
30	30.00	22.00	8.00	15.00	0.27	same
31	30.00	22.00	8.00	15.00	0.25	same

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	YES	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	Yes	All Cl2 residual at entry point ≥ 0.2 mg/l?
		Yes

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: Natalie Blankenship	
	SIGNATURE:	DATE: 2.9.2026
	PHONE #: (541) 991.7821	CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - :

System Name:	Lakeshore RV Park	ID#: 41 01001	Month/Year:	January 2026	Disinfection <i>Giardia</i> Log Inactiv:	1
---------------------	-------------------	----------------------	--------------------	--------------	---	---

Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	65	52.0	11.7	6.80	31.6	YES	5
2	0.8	65	52.0	11.7	6.80	31.6	YES	5
3	0.8	65	52.0	11.7	6.80	31.6	YES	5
4	0.8	65	52.0	11.7	6.80	31.6	YES	5
5	0.8	65	52.0	11.7	6.80	31.6	YES	5
6	0.8	65	52.0	11.7	6.80	31.6	YES	5
7	0.8	65	52.0	11.7	6.80	31.6	YES	5
8	0.8	65	52.0	11.7	6.80	31.6	YES	5
9	0.8	65	52.0	11.7	6.80	31.6	YES	5
10	0.8	65	52.0	11.7	6.80	31.6	YES	5
11	0.8	65	52.0	11.7	6.80	31.6	YES	5
12	0.8	65	52.0	11.7	6.80	31.6	YES	5
13	0.8	65	52.0	11.7	6.80	31.6	YES	5
14	0.8	65	52.0	11.7	6.80	31.6	YES	5
15	0.8	65	52.0	11.7	6.80	31.6	YES	5
16	0.8	65	52.0	11.7	6.80	31.6	YES	5
17	0.8	65	52.0	11.7	6.80	31.6	YES	5
18	0.8	65	52.0	11.7	6.80	31.6	YES	5
19	0.8	65	52.0	11.7	6.80	31.6	YES	5
20	0.8	65	52.0	11.7	6.80	31.6	YES	5
21	0.8	65	52.0	11.7	6.80	31.6	YES	5
22	0.8	65	52.0	11.7	6.80	31.6	YES	5
23	0.8	65	52.0	11.7	6.80	31.6	YES	5
24	0.8	65	52.0	11.7	6.80	31.6	YES	5
25	0.8	65	52.0	11.7	6.80	31.6	YES	5
26	0.8	65	52.0	11.7	6.80	31.6	YES	5
27	0.8	65	52.0	11.7	6.80	31.6	YES	5
28	0.8	65	52.0	11.7	6.80	31.6	YES	5
29	0.8	65	52.0	11.7	6.80	31.6	YES	5
30	0.8	65	52.0	11.7	6.80	31.6	YES	5
31	0.8	65	52.0	11.7	6.80	31.6	YES	5

2 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350