

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **May-21**

System Name:	PP&L Toketee Village		ID#: 41	01012		WTP : TP - Conventional	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	0.06	POL	POL	POL	0.06
2	POL	POL	POL	POL	0.06	POL	0.06
3	POL	POL	POL	0.07	POL	POL	0.07
4	POL	POL	POL	0.09	POL	POL	0.09
5	POL	POL	POL	0.06	POL	POL	0.06
6	POL	POL	POL	0.05	POL	POL	0.05
7	POL	POL	POL	0.09	0.03	POL	0.09
8	POL	POL	POL	POL	POL	POL	0.00
9	POL	POL	POL	POL	POL	POL	0.00
10	POL	POL	POL	0.05	POL	0.00	0.05
11	POL	POL	POL	0.05	POL	POL	0.05
12	POL	POL	0.06	POL	POL	POL	0.06
13	POL	POL	0.04	POL	0.04	POL	0.04
14	POL	POL	POL	0.03	POL	0.03	0.04
15	0.03	POL	POL	POL	POL	POL	0.00
16	POL	POL	0.05	POL	0.03	0.03	0.05
17	POL	POL	0.01	0.04	POL	0.04	0.04
18	0.03	POL	POL	0.03	POL	POL	0.03
19	POL	POL	0.04	0.03	POL	POL	0.04
20	POL	POL	POL	POL	0.04	POL	0.04
21	POL	POL	0.05	0.07	POL	POL	0.07
22	POL	POL	POL	0.03	POL	POL	0.03
23	POL	POL	0.03	POL	POL	POL	0.03
24	POL	POL	POL	0.03	POL	POL	0.03
25	POL	POL	POL	0.04	0.03	POL	0.04
26	POL	POL	POL	POL	POL	POL	0.00
27	POL	POL	0.05	POL	POL	POL	0.05
28	POL	POL	POL	0.04	0.03	POL	0.04
29	POL	POL	0.03	POL	POL	POL	0.04
30	0.03	POL	POL	POL	POL	0.04	0.04
31	POL	POL	0.04	POL	POL	0.04	0.04

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? YES	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? YES		
All turbidity readings < IFE ² triggers Yes / No		

Notes:	PRINTED NAME: Jonathan Woody
	SIGNATURE: Jonathan Woody DATE: 6-8-21
	PHONE #: (541) 643-6137 CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County :		Douglas		WTP - :	WTP-A
				Month/Year :	May / 2021	Disinfection <i>Giardia</i> Log	0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM	
1	0.56	120	67.2	14	7.66	17.68	YES	70	
2	0.47	120	56.4	12	7.33	17.91	YES	70	
3	0.56	120	67.2	15	7.47	15.42	YES	70	
4	0.55	120	66.0	13	7.27	16.34	YES	70	
5	0.42	120	50.4	14	7.56	16.77	YES	70	
6	0.52	120	62.4	15	7.58	15.99	YES	70	
7	0.47	120	56.4	13	7.44	17.25	YES	70	
8	0.50	120	60.0	12	7.54	19.32	YES	70	
9	0.49	120	58.8	13	7.64	18.61	YES	70	
10	0.56	120	67.2	13	7.36	16.92	YES	70	
11	0.52	120	62.4	12	7.03	16.26	YES	70	
12	0.54	120	64.8	13	7.29	16.45	YES	70	
13	0.66	120	79.2	13	7.33	16.92	YES	70	
14	0.68	120	81.6	15	7.49	15.75	YES	70	
15	0.64	120	76.8	14	7.42	16.33	YES	70	
16	0.50	120	60.0	17	7.64	14.27	YES	70	
17	0.43	120	51.6	17	7.57	13.80	YES	70	
18	0.42	120	50.4	18	7.60	13.03	YES	70	
19	0.43	120	51.6	18	7.53	12.71	YES	70	
20	0.42	120	50.4	16	7.55	14.62	YES	70	
21	0.42	120	50.4	14	7.40	15.81	YES	70	
22	0.37	120	44.4	14	7.36	15.49	YES	70	
23	0.44	120	52.8	14	7.25	14.99	YES	70	
24	0.47	120	56.4	13	7.36	16.74	YES	70	
25	0.36	120	43.2	12	7.31	17.58	YES	70	
26	0.41	120	49.2	14	7.34	15.44	YES	70	
27	0.38	120	45.6	15	7.63	16.03	YES	70	
28	0.52	120	62.4	17	7.53	13.73	YES	70	
29	0.59	120	70.8	16	7.66	15.53	YES	70	
30	0.58	120	69.6	16	7.70	15.74	YES	70	
31	0.70	120	84.0	15	7.29	14.66	YES	70	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.