

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Douglas  
Month/Year: Jun-21

System Name: PP&L Toketae Village ID#: 41 01012 WTP: TP - Conventional

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	POL	POL	0.04	0.01	POL	0.03	0.04
2	POL	POL	0.04	0.03	POL	0.07	0.07
3	0.03	POL	POL	0.04	POL	POL	0.09
4	POL	POL	POL	0.03	POL	POL	0.04
5	0.03	POL	POL	0.03	POL	POL	0.03
6	0.04	POL	POL	0.03	POL	POL	0.04
7	POL	POL	0.05	POL	POL	0.03	0.05
8	POL	POL	POL	0.04	POL	POL	0.04
9	POL	POL	0.03	POL	POL	POL	0.04
10	0.04	POL	POL	0.06	POL	0.00	0.06
11	POL	POL	POL	0.07	POL	POL	0.07
12	POL	POL	POL	0.06	0.04	POL	0.06
13	POL	POL	0.04	POL	POL	POL	0.04
14	POL	0.04	0.03	POL	POL	POL	0.04
15	POL	0.04	0.03	0.03	POL	POL	0.04
16	POL	POL	0.03	POL	POL	0.05	0.05
17	0.03	POL	0.03	0.03	POL	POL	0.03
18	0.04	POL	0.03	POL	POL	0.03	0.04
19	POL	0.03	0.03	0.03	POL	0.04	0.04
20	0.03	0.04	0.03	0.04	POL	0.04	0.04
21	0.03	0.04	0.03	0.08	0.04	0.03	0.08
22	POL	POL	POL	POL	0.04	0.04	0.04
23	POL	POL	0.05	0.04	POL	0.03	0.05
24	POL	0.04	0.03	0.03	0.03	POL	0.04
25	POL	0.04	POL	0.03	POL	0.03	0.04
26	POL	POL	0.04	0.03	POL	0.03	0.04
27	POL	0.04	0.04	POL	POL	0.04	0.05
28	POL	POL	0.03	0.04	POL	POL	0.04
29	0.04	POL	POL	0.04	0.03	POL	0.09
30	POL	0.04	0.03	POL	POL	0.04	0.04
31	0.03	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	0.00

<p><b>Conventional or Direct Filtration</b></p> <p>95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> YES</p> <p>All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> YES</p> <p>All turbidity readings &lt; IFE<sup>2</sup> triggers <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO</p>		<p><b>Monthly Summary (Answer Yes or No)</b></p> <p>CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p>	
<p>Notes:</p>		<p>PRINTED NAME: Jonathan Woody</p> <p>SIGNATURE: <i>Jonathan Woody</i></p> <p>PHONE #: (541) 643-6137</p>	
		<p>DATE: 7-9-21</p> <p>CERT #: 7232</p>	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

### OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County :	Douglas		WTP - :	WTP-A
				Month/Year :	January / 1900	Disinfection <i>Giardia</i> Log	0.5	
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM
1	0.61	120	73.2	15	7.38	15.00	YES	70
2	0.63	120	75.6	20	7.74	12.30	YES	70
3	0.60	120	72.0	20	7.70	12.07	YES	70
4	0.68	120	81.6	18	7.27	11.87	YES	70
5	0.88	120	105.6	20	7.46	11.40	YES	70
6	0.74	120	88.8	18	8.01	15.74	YES	70
7	0.74	120	88.8	16	7.37	14.19	YES	70
8	0.64	120	76.8	15	7.78	17.45	YES	70
9	0.66	120	79.2	16	7.44	14.43	YES	70
10	0.62	120	74.4	18	7.82	14.47	YES	70
11	0.57	120	68.4	14	7.41	16.14	YES	70
12	0.63	120	75.6	15	6.98	12.96	YES	70
13	0.69	120	82.8	18	7.78	14.37	YES	70
14	0.61	120	73.2	18	7.79	14.29	YES	70
15	0.63	120	75.6	15	7.30	14.59	YES	70
16	0.56	120	67.2	15	7.59	16.12	YES	70
17	0.70	120	84.0	15	7.53	16.02	YES	70
18	0.72	120	86.4	16	7.39	14.26	YES	70
19	0.71	120	85.2	16	7.52	14.95	YES	70
20	0.72	120	86.4	16	7.50	14.85	YES	70
21	0.74	120	88.8	16	7.60	15.45	YES	70
22	0.72	120	86.4	18	7.53	13.14	YES	70
23	0.68	120	81.6	20	7.81	12.70	YES	70
24	0.72	120	86.4	16	7.59	15.36	YES	70
25	0.72	120	86.4	18	7.31	12.11	YES	70
26	0.63	120	75.6	18	7.66	13.65	YES	70
27	0.64	120	76.8	18	7.42	12.50	YES	70
28	0.66	120	79.2	18	7.79	14.37	YES	70
29	0.66	120	79.2	21	7.78	11.71	YES	70
30	0.65	120	78.0	21	7.81	11.83	YES	70
31		120						70

If Cl<sub>2</sub> at any point < 0.2 mg/L or CT not met, OHA is notified by email and by hard copy.