

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Oct-21

System Name:	PP&L Toketee Village		ID#:	41	01012	WTP: TP - Conventional	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	0.06	POL	POL	POL	0.06
2	POL	POL	POL	0.05	POL	POL	0.05
3	POL	POL	POL	0.04	POL	POL	0.04
4	POL	POL	POL	0.04	POL	POL	0.04
5	POL	POL	0.04	POL	POL	POL	0.05
6	POL	POL	POL	0.04	POL	0.00	0.06
7	POL	POL	POL	POL	0.04	POL	0.04
8	POL	POL	0.04	0.05	POL	POL	0.08
9	POL	POL	POL	0.06	POL	POL	0.06
10	POL	POL	POL	0.06	0.04	0.00	0.06
11	POL	0.04	0.05	0.05	POL	POL	0.05
12	POL	POL	POL	0.05	POL	POL	0.05
13	POL	POL	POL	POL	POL	POL	0.00
14	POL	POL	POL	0.04	POL	POL	0.06
15	POL	POL	0.05	POL	POL	POL	0.05
16	POL	POL	0.05	POL	POL	POL	0.05
17	POL	POL	POL	0.05	POL	POL	0.05
18	POL	POL	POL	0.04	POL	POL	0.04
19	POL	POL	POL	0.05	POL	POL	0.05
20	POL	POL	POL	0.05	POL	POL	0.05
21	POL	POL	POL	0.06	POL	POL	0.06
22	POL	POL	POL	0.04	POL	POL	0.04
23	POL	POL	POL	0.05	POL	POL	0.05
24	POL	POL	POL	POL	0.07	POL	0.07
25	POL	POL	POL	POL	POL	0.06	0.06
26	POL	POL	0.04	POL	POL	POL	0.04
27	POL	POL	POL	0.04	0.04	POL	0.12
28	POL	POL	0.05	POL	POL	POL	0.05
29	POL	POL	POL	POL	0.04	POL	0.06
30	POL	POL	POL	0.05	POL	POL	0.05
31	POL	POL	POL	0.06	POL	POL	0.06

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All 4-hour turbidity readings \leq 1 NTU?	YES	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:	PRINTED NAME: Jonathan Woody		
	SIGNATURE: <i>John Woody</i>		DATE: 11-7-21
	PHONE #: (541) 643-6137		CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County : Month/Year :		Douglas October / 2021		WTP - : Disinfection <i>Giardia</i> Log	WTP-A
									0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM	
1	0.37	120	44.4	13	7.73	18.98	YES	70	
2	0.45	120	54.0	15	7.24	13.98	YES	70	
3	0.45	120	54.0	15	7.31	14.35	YES	70	
4	0.45	120	54.0	13	7.42	17.08	YES	70	
5	0.47	120	56.4	14	7.19	14.71	YES	70	
6	0.51	120	61.2	13	7.39	17.01	YES	70	
7	0.53	120	63.6	13	7.44	17.36	YES	70	
8	0.64	120	76.8	12	7.47	19.16	YES	70	
9	0.70	120	84.0	11	7.67	22.08	YES	70	
10	0.74	120	88.8	11	7.59	21.56	YES	70	
11	0.74	120	88.8	11	7.34	19.76	YES	70	
12	0.77	120	92.4	9	7.48	23.76	YES	70	
13	0.71	120	85.2	10	7.54	22.56	YES	70	
14	0.71	120	85.2	9	7.36	22.62	YES	70	
15	0.69	120	82.8	10	7.44	21.73	YES	70	
16	0.65	120	78.0	9	7.60	24.46	YES	70	
17	0.53	120	63.6	10	7.32	20.46	YES	70	
18	0.53	120	63.6	10	7.45	21.41	YES	70	
19	0.68	120	81.6	9	7.51	23.77	YES	70	
20	0.70	120	84.0	10	7.48	22.06	YES	70	
21	0.68	120	81.6	10	7.34	20.96	YES	70	
22	0.72	120	86.4	10	7.27	20.54	YES	70	
23	0.80	120	96.0	10	7.61	23.36	YES	70	
24	0.59	120	70.8	10	7.25	20.10	YES	70	
25	0.56	120	67.2	11	7.48	20.33	YES	70	
26	0.70	120	84.0	10	7.37	21.22	YES	70	
27	0.90	120	108.0	10	7.54	23.05	YES	70	
28	0.54	120	64.8	10	7.32	20.49	YES	70	
29	0.54	120	64.8	10	7.30	20.34	YES	70	
30	0.58	120	69.6	10	7.41	21.24	YES	70	
31	0.59	120	70.8	10	7.38	21.04	YES	70	