

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: **Douglas**

Conventional or Direct Filtration

Month/Year: **April-22**

System Name:	PP&L Toketee Village		ID#: 41	01012	WTP : TP - Conventional		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	0.05	POL	POL	0.05
2	POL	POL	POL	POL	POL	POL	POL
3	POL	POL	POL	0.05	POL	POL	0.05
4	POL	POL	POL	0.05	POL	POL	0.05
5	POL	POL	POL	0.07	POL	POL	0.07
6	POL	POL	POL	POL	POL	POL	POL
7	POL	POL	POL	0.12	POL	POL	0.12
8	POL	POL	POL	POL	POL	POL	POL
9	POL	POL	POL	POL	POL	POL	POL
10	POL	POL	0.18	POL	POL	POL	0.18
11	POL	POL	POL	POL	POL	POL	POL
12	POL	POL	POL	0.08	POL	POL	0.08
13	POL	POL	POL	POL	POL	POL	POL
14	POL	POL	POL	0.05	POL	POL	0.05
15	POL	POL	0.05	0.05	POL	POL	0.05
16	POL	POL	POL	0.04	POL	POL	0.04
17	POL	POL	POL	0.07	POL	POL	0.07
18	POL	POL	POL	POL	POL	POL	POL
19	POL	POL	0.04	POL	POL	POL	0.05
20	POL	POL	0.07	POL	POL	POL	0.07
21	POL	POL	POL	0.07	POL	POL	0.07
22	POL	POL	POL	POL	POL	POL	POL
23	POL	POL	0.05	0.06	POL	POL	0.06
24	POL	POL	POL	POL	POL	POL	POL
25	POL	POL	0.06	POL	POL	POL	0.06
26	POL	POL	POL	POL	POL	POL	POL
27	POL	POL	0.05	POL	POL	POL	0.05
28	POL	POL	POL	POL	POL	0.13	0.13
29	POL	POL	POL	POL	POL	POL	POL
30	POL	POL	POL	0.11	0.15	POL	0.15
31	POL	POL	POL	POL	POL	POL	POL

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? YES	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? YES		
All turbidity readings < IFE ² triggers Yes / No		
Notes:	PRINTED NAME: Jonathan Woody	DATE: 5/10/22
	SIGNATURE: <i>John Woody</i>	CERT #: 7232
	PHONE #: (541) 643-6137	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County :	Douglas		WTP - :	WTP-A
				Month/Year :	April / 2022		Disinfection <i>Giardia</i> Log	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM
1	pol	120	#####	pol	pol	#VALUE!	#VALUE!	70
2	0.40	120	48.0	10	7.50	21.48	YES	70
3	0.43	120	51.6	10	7.48	21.40	YES	70
4	0.51	120	61.2	9	7.61	24.15	YES	70
5	0.51	120	61.2	9	7.61	24.15	YES	70
6	0.49	120	58.8	8	7.43	24.16	YES	70
7	0.49	120	58.8	10	7.46	21.39	YES	70
8	0.42	120	50.4	10	7.60	22.29	YES	70
9	0.45	120	54.0	10	7.27	19.93	YES	70
10	0.41	120	49.2	10	7.19	19.30	YES	70
11	0.40	120	48.0	9	7.34	21.69	YES	70
12	0.55	120	66.0	9	7.47	23.09	YES	70
13	0.49	120	58.8	9	7.41	22.45	YES	70
14	0.48	120	57.6	8	7.57	25.37	YES	70
15	0.43	120	51.6	8	7.42	23.91	YES	70
16	0.53	120	63.6	8	7.51	24.97	YES	70
17	0.50	120	60.0	8	7.17	22.07	YES	70
18	0.53	120	63.6	8	7.36	23.68	YES	70
19	0.54	120	64.8	8	7.49	24.83	YES	70
20	0.50	120	60.0	10	6.98	18.13	YES	70
21	0.51	120	61.2	8	7.43	24.22	YES	70
22	0.49	120	58.8	8	7.47	24.51	YES	70
23	0.52	120	62.4	8	7.40	23.99	YES	70
24	0.46	120	55.2	8	7.45	24.25	YES	70
25	0.52	120	62.4	8	7.57	25.49	YES	70
26	0.48	120	57.6	8	7.39	23.80	YES	70
27	0.41	120	49.2	10	7.10	18.71	YES	70
28	0.43	120	51.6	11	7.45	19.83	YES	70
29	0.45	120	54.0	11	7.23	18.42	YES	70
30	0.31	120	37.2	10	7.26	19.55	YES	70
31		120						70

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.