

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Jun-22

System Name: PP&L Tokete Village ID#: 41 01012 WTP: TP - Conventional

| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day ¹ [NTU] |
|-----|-------------|------------|------------|------------|------------|------------|---|
| 1 | POL | 0.06 | POL | POL | POL | POL | 0.06 |
| 2 | POL | POL | POL | 0.07 | POL | POL | 0.07 |
| 3 | POL | POL | POL | POL | POL | POL | 0.00 |
| 4 | POL | POL | POL | 0.07 | POL | POL | 0.07 |
| 5 | POL | POL | 0.05 | POL | POL | POL | 0.05 |
| 6 | POL | POL | POL | POL | POL | POL | 0.00 |
| 7 | POL | POL | 0.09 | POL | POL | POL | 0.09 |
| 8 | POL | POL | POL | POL | 0.05 | POL | 0.05 |
| 9 | POL | POL | POL | POL | POL | POL | 0.00 |
| 10 | POL | POL | POL | POL | 0.11 | 0.00 | 0.11 |
| 11 | POL | POL | POL | POL | POL | POL | 0.00 |
| 12 | POL | POL | POL | 0.08 | 0.05 | POL | 0.08 |
| 13 | POL | POL | POL | POL | POL | POL | 0.00 |
| 14 | POL | POL | 0.05 | POL | POL | POL | 0.06 |
| 15 | POL | POL | POL | 0.05 | 0.08 | POL | 0.08 |
| 16 | POL | POL | POL | POL | POL | POL | 0.00 |
| 17 | POL | POL | 0.05 | POL | POL | POL | 0.05 |
| 18 | POL | POL | POL | 0.05 | POL | POL | 0.05 |
| 19 | POL | POL | POL | 0.05 | POL | POL | 0.05 |
| 20 | POL | POL | POL | POL | POL | POL | 0.00 |
| 21 | POL | POL | POL | 0.04 | POL | POL | 0.05 |
| 22 | POL | POL | POL | POL | 0.05 | 0.05 | 0.05 |
| 23 | POL | POL | POL | POL | POL | POL | 0.00 |
| 24 | POL | POL | POL | 0.06 | 0.04 | POL | 0.06 |
| 25 | POL | POL | POL | POL | POL | POL | 0.00 |
| 26 | POL | POL | POL | 0.05 | POL | 0.14 | 0.14 |
| 27 | 0.06 | POL | POL | POL | 0.03 | POL | 0.06 |
| 28 | POL | POL | POL | POL | POL | POL | 0.04 |
| 29 | 0.03 | POL | 0.03 | POL | POL | POL | 0.04 |
| 30 | POL | 0.03 | POL | POL | POL | POL | 0.04 |
| 31 | POL | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | 0.00 |

| | | | |
|--|----------------------------------|---|---|
| Conventional or Direct Filtration | | Monthly Summary (Answer Yes or No) | |
| 95% of 4-hour turbidity readings ≤ 0.3 NTU? | YES | CT's met everyday? (see back) | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All 4-hour turbidity readings ≤ 1 NTU? | YES | Yes / No | Yes / No |
| All turbidity readings < IFE ² triggers | Yes / No | | |
| Notes: | PRINTED NAME: Jonathan Woody | | DATE: 6-8-22 |
| | SIGNATURE: <i>Jonathan Woody</i> | | CERT #: 7252 |
| | PHONE #: (541) 643-6137 | | |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

| System Name: | PP&L Toketee Village | | ID#: 4101012 | County : | Douglas | | WTP - : | WTP-A |
|--------------|---|------------------|--------------|--------------|-------------|-------------|--------------------------|-------------------------|
| | | | | Month/Year : | June / 2022 | | Disinfection Giardia Log | 0.5 |
| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
| | ppm or mg/L | minutes | C X T | ° C | | formula | Yes / No | GPM |
| 1 | 0.83 | 120 | 99.6 | 13 | 7.40 | 17.70 | YES | 70 |
| 2 | 0.85 | 120 | 102.0 | 13 | 7.46 | 18.14 | YES | 70 |
| 3 | 0.81 | 120 | 97.2 | 13 | 7.47 | 18.12 | YES | 70 |
| 4 | 0.68 | 120 | 81.6 | 14 | 7.46 | 16.65 | YES | 70 |
| 5 | 0.68 | 120 | 81.6 | 13 | 7.50 | 18.06 | YES | 70 |
| 6 | 0.71 | 120 | 85.2 | 13 | 7.52 | 18.25 | YES | 70 |
| 7 | 0.70 | 120 | 84.0 | 14 | 7.58 | 17.44 | YES | 70 |
| 8 | 0.78 | 120 | 93.6 | 14 | 7.51 | 17.15 | YES | 70 |
| 9 | 0.69 | 120 | 82.8 | 14 | 7.67 | 18.01 | YES | 70 |
| 10 | 0.65 | 120 | 78.0 | 14 | 6.85 | 13.23 | YES | 70 |
| 11 | 0.78 | 120 | 93.6 | 14 | 7.46 | 16.84 | YES | 70 |
| 12 | 0.58 | 120 | 69.6 | 15 | 7.36 | 14.84 | YES | 70 |
| 13 | 0.83 | 120 | 99.6 | 15 | 7.40 | 15.49 | YES | 70 |
| 14 | 0.81 | 120 | 97.2 | 14 | 7.26 | 15.69 | YES | 70 |
| 15 | 0.78 | 120 | 93.6 | 14 | 7.41 | 16.53 | YES | 70 |
| 16 | 0.79 | 120 | 94.8 | 14 | 7.29 | 15.83 | YES | 70 |
| 17 | 0.71 | 120 | 85.2 | 14 | 7.44 | 16.58 | YES | 70 |
| 18 | 0.72 | 120 | 86.4 | 14 | 7.24 | 15.42 | YES | 70 |
| 19 | 0.81 | 120 | 97.2 | 14 | 7.36 | 16.28 | YES | 70 |
| 20 | 0.62 | 120 | 74.4 | 17 | 6.73 | 10.30 | YES | 70 |
| 21 | 0.78 | 120 | 93.6 | 14 | 7.40 | 16.47 | YES | 70 |
| 22 | 0.79 | 120 | 94.8 | 15 | 7.33 | 15.03 | YES | 70 |
| 23 | 0.75 | 120 | 90.0 | 15 | 7.40 | 15.35 | YES | 70 |
| 24 | 0.79 | 120 | 94.8 | 20 | 7.35 | 10.83 | YES | 70 |
| 25 | 0.68 | 120 | 81.6 | 17 | 7.39 | 13.28 | YES | 70 |
| 26 | 0.67 | 120 | 80.4 | 21 | 7.17 | 9.33 | YES | 70 |
| 27 | 0.74 | 120 | 88.8 | 18 | 7.36 | 12.36 | YES | 70 |
| 28 | 0.75 | 120 | 90.0 | 18 | 7.54 | 13.23 | YES | 70 |
| 29 | 0.75 | 120 | 90.0 | 18 | 7.39 | 12.51 | YES | 70 |
| 30 | 0.73 | 120 | 87.6 | 18 | 7.49 | 12.96 | YES | 70 |
| 31 | | 120 | | | | | | 70 |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.