

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Month/Year: Nov-22

Conventional or Direct Filtration

System Name: PP&L Toketea Village ID#: 41 01012 WTP: TP - Conventional

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	POL	0.05	0.03	POL	0.05	POL	0.05
2	POL	0.05	0.04	0.05	0.11	POL	0.11
3	POL	0.06	0.04	POL	POL	POL	0.06
4	POL	POL	POL	0.06	POL	POL	0.06
5	POL	POL	POL	0.05	POL	POL	0.05
6	POL	POL	POL	0.06	POL	POL	0.06
7	POL	POL	POL	POL	0.07	POL	0.07
8	POL	POL	0.05	POL	POL	POL	0.05
9	POL	POL	POL	0.08	POL	POL	0.08
10	POL	POL	POL	POL	0.06	0.00	0.06
11	POL	POL	POL	POL	POL	POL	0.00
12	POL	0.13	0.05	POL	POL	POL	0.13
13	POL	POL	0.06	0.05	POL	POL	0.06
14	POL	POL	POL	0.08	0.05	POL	0.08
15	POL	POL	POL	POL	0.06	POL	0.06
16	POL	POL	POL	0.06	0.05	POL	0.06
17	POL	POL	POL	POL	0.06	POL	0.06
18	POL	POL	POL	POL	0.06	POL	0.06
19	POL	POL	POL	0.07	POL	POL	0.07
20	POL	POL	POL	POL	0.05	POL	0.05
21	POL	POL	POL	0.05	0.10	POL	0.10
22	POL	POL	POL	0.08	0.06	POL	0.08
23	POL	POL	0.07	0.05	POL	POL	0.07
24	POL	POL	0.07	POL	POL	POL	0.07
25	POL	POL	0.06	POL	POL	POL	0.06
26	POL	POL	0.08	0.05	POL	POL	0.08
27	POL	POL	0.07	0.05	POL	POL	0.07
28	POL	POL	POL	POL	0.06	POL	0.06
29	POL	POL	POL	POL	POL	POL	0.11
30	0.11	POL	POL	POL	0.12	POL	0.12
31	POL	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	0.00

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <b>YES</b>	CT's met everyday? (see back) <b>Yes</b> / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b> / No
All 4-hour turbidity readings ≤ 1 NTU? <b>YES</b>		
All turbidity readings < IFE <sup>2</sup> triggers <b>Yes</b> / No		

Notes: PRINTED NAME: Jonathan Woody  
 SIGNATURE: *Jonathan Woody* DATE: 12-8-22  
 PHONE #: (541) 643-6137 CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County : Month/Year :		Douglas November / 2022		WTP - :	WTP-A
				Disinfection Giardia Log		CT Met? <sup>3</sup>		0.5	
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM	
1	0.95	120	114.0	10	7.40	22.06	YES	70	
2	1.25	120	150.0	10	7.44	23.15	YES	70	
3	1.00	120	120.0	10	7.41	22.27	YES	70	
4	0.65	120	78.0	12	7.18	17.36	YES	70	
5	0.85	120	102.0	12	7.17	17.68	YES	70	
6	0.68	120	81.6	10	7.30	20.67	YES	70	
7	0.71	120	85.2	11	7.40	20.11	YES	70	
8	0.73	120	87.6	10	7.35	21.15	YES	70	
9	0.89	120	106.8	9	7.36	23.08	YES	70	
10	0.89	120	106.8	8	7.50	25.93	YES	70	
11	0.98	120	117.6	10	7.13	20.14	YES	70	
12	0.87	120	104.4	9	7.09	20.95	YES	70	
13	0.97	120	116.4	9	7.39	23.54	YES	70	
14	0.98	120	117.6	9	7.31	22.91	YES	70	
15	0.79	120	94.8	8	7.31	23.96	YES	70	
16	0.82	120	98.4	8	7.33	24.22	YES	70	
17	0.76	120	91.2	7	7.42	26.55	YES	70	
18	0.74	120	88.8	8	7.34	24.08	YES	70	
19	0.62	120	74.4	8	7.38	24.09	YES	70	
20	0.62	120	74.4	8	7.33	23.67	YES	70	
21	0.89	120	106.8	8	7.68	27.66	YES	70	
22	0.92	120	110.4	7	7.61	28.96	YES	70	
23	1.16	120	139.2	10	7.50	23.41	YES	70	
24	1.23	120	147.6	8	7.54	27.36	YES	70	
25	1.11	120	133.2	10	7.60	24.93	YES	70	
26	1.13	120	135.6	8	7.62	27.83	YES	70	
27	1.05	120	126.0	10	7.56	23.61	YES	70	
28	1.05	120	126.0	8	7.76	29.00	YES	70	
29	1.13	120	135.6	8	7.71	28.75	YES	70	
30	1.05	120	126.0	8	7.65	27.88	YES	70	
31		120						70	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.