

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County:

Douglas

Conventional or Direct Filtration

Month/Year:

Dec-22

System Name: PP&L Toketee Village ID#: 41 01012 WTP: TP - Conventional

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	POL	POL	POL	0.06	POL	POL	0.06
2	POL	POL	POL	0.07	POL	POL	0.07
3	POL	POL	POL	0.07	POL	POL	0.07
4	POL	POL	POL	0.06	POL	POL	0.06
5	POL	POL	POL	0.06	0.05	POL	0.06
6	POL	POL	POL	0.07	POL	POL	0.07
7	POL	POL	POL	POL	0.06	POL	0.06
8	POL	POL	POL	0.06	0.08	POL	0.09
9	POL	POL	POL	POL	POL	POL	0.00
10	0.11	POL	POL	POL	POL	0.00	0.11
11	POL	POL	0.09	POL	POL	POL	0.09
12	POL	POL	0.07	POL	POL	POL	0.07
13	POL	POL	POL	0.06	POL	POL	0.06
14	POL	POL	0.05	POL	POL	POL	0.07
15	POL	POL	POL	0.06	POL	POL	0.06
16	POL	POL	POL	0.07	POL	POL	0.07
17	POL	POL	0.05	POL	POL	POL	0.07
18	POL	POL	0.06	POL	POL	POL	0.06
19	POL	POL	POL	POL	POL	0.06	0.06
20	0.05	POL	POL	POL	0.07	0.06	0.07
21	POL	POL	POL	POL	POL	POL	0.00
22	POL	POL	0.05	0.05	POL	POL	0.07
23	POL	POL	0.06	0.08	POL	POL	0.08
24	POL	POL	0.07	POL	POL	POL	0.07
25	POL	POL	0.08	POL	POL	POL	0.08
26	POL	POL	POL	0.24	POL	POL	0.24
27	POL	POL	0.26	POL	POL	POL	0.26
28	POL	POL	POL	POL	POL	POL	0.00
29	0.05	0.02	POL	POL	POL	POL	0.05
30	POL	POL	POL	0.09	POL	POL	0.09
31	POL	POL	POL	0.07	POL	POL	0.07

Conventional or Direct Filtration

95% of 4-hour turbidity readings ≤ 0.3 NTU?  YES

All 4-hour turbidity readings ≤ 1 NTU?  YES

All turbidity readings < IFE<sup>2</sup> triggers  Yes /  No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)  Yes /  No

All Cl2 residual at entry point ≥ 0.2 mg/l?  Yes /  No

Notes:

PRINTED NAME: Jonathan Woody

SIGNATURE: *John Woody*

DATE: 1/9/25

PHONE #: (541) 643-6137

CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e))(B&C)

## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County : Douglas		WTP - : Disinfection Giardia Log		WTP-A
				Month/Year :	December / 2022	CT Met? <sup>3</sup>	0.5	
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM
1	1.01	120	121.2	5	7.56	32.26	YES	70
2	0.95	120	114.0	10	7.38	22.64	YES	70
3	0.92	120	110.4	9	7.34	23.00	YES	70
4	0.79	120	94.8	9	7.28	22.19	YES	70
5	0.78	120	93.6	5	7.75	34.58	YES	70
6	1.08	120	129.6	10	7.13	20.37	YES	70
7	0.94	120	112.8	7	7.84	31.54	YES	70
8	0.94	120	112.8	5	7.76	35.13	YES	70
9	1.04	120	124.8	5	7.53	32.68	YES	70
10	0.95	120	114.0	9	7.19	21.89	YES	70
11	0.94	120	112.8	8	7.12	22.79	YES	70
12	0.95	120	114.0	8	7.61	27.16	YES	70
13	0.88	120	105.6	5	7.41	30.71	YES	70
14	0.90	120	108.0	8	7.32	24.35	YES	70
15	0.88	120	105.6	5	7.47	31.38	YES	70
16	0.84	120	100.8	6	7.38	28.26	YES	70
17	0.96	120	115.2	8	7.57	26.81	YES	70
18	0.93	120	111.6	8	7.53	26.33	YES	70
19	0.97	120	116.4	4	7.43	33.47	YES	70
20	0.93	120	111.6	5	7.62	33.34	YES	70
21	0.93	120	111.6	4	7.51	34.29	YES	70
22	0.92	120	110.4	4	7.51	34.25	YES	70
23	0.92	120	110.4	4	7.90	39.52	YES	70
24	0.89	120	106.8	4	7.60	35.27	YES	70
25	0.85	120	102.0	6	7.45	29.01	YES	70
26	0.85	120	102.0	6	7.45	29.01	YES	70
27	0.64	120	76.8	7	7.52	27.14	YES	70
28	0.74	120	88.8	6	7.67	31.01	YES	70
29	0.73	120	87.6	5	7.56	31.86	YES	70
30	0.65	120	78.0	5	7.67	32.86	YES	70
31	0.68	120	81.6	6	7.22	26.19	YES	70

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.