

OHA - Drinking Water Program -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Douglas

Month/Year: Jan-23

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	0.04	0.02	POL	POL	0.04
2	POL	POL	POL	0.03	POL	POL	0.03
3	POL	POL	POL	POL	POL	POL	0.06
4	POL	POL	POL	POL	POL	POL	0.00
5	POL	0.13	0.03	0.04	0.09	POL	0.13
6	POL	POL	POL	POL	0.05	POL	0.06
7	POL	POL	POL	POL	POL	POL	0.00
8	POL	0.07	POL	POL	POL	POL	0.07
9	POL	POL	POL	0.04	POL	POL	0.04
10	POL	POL	POL	POL	POL	0.03	0.05
11	POL	POL	0.04	POL	POL	POL	0.00
12	POL	POL	POL	POL	POL	POL	0.04
13	POL	POL	POL	POL	0.08	POL	0.08
14	POL	POL	POL	POL	0.05	POL	0.05
15	POL	POL	POL	POL	0.04	POL	0.04
16	POL	POL	POL	POL	0.04	POL	0.04
17	POL	POL	POL	POL	POL	POL	0.00
18	POL	0.04	POL	POL	POL	POL	0.07
19	POL	POL	POL	POL	POL	POL	0.00
20	POL	0.06	POL	0.20	POL	POL	0.20
21	POL	POL	POL	0.13	0.13	POL	0.13
22	POL	POL	POL	POL	POL	POL	0.00
23	POL	POL	0.13	POL	POL	POL	0.17
24	POL	0.22	POL	POL	POL	POL	0.22
25	POL	POL	POL	0.20	POL	POL	0.20
26	POL	POL	POL	POL	POL	POL	0.00
27	0.09	0.06	POL	POL	POL	POL	0.09
28	POL	POL	POL	0.05	POL	POL	0.05
29	POL	POL	POL	0.10	POL	POL	0.10
30	POL	POL	POL	POL	POL	0.08	0.15
31	POL	POL	POL	POL	POL	POL	0.00

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU?

YES

All 4-hour turbidity readings ≤ 1 NTU?

YES

All turbidity readings < IFE² triggers

Yes / No

CT's met everyday? (see back)

Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l?

Yes / No

Notes: 0.00 = Plant off line.

PRINTED NAME: Jonathan Woody

SIGNATURE: Jonathan Woody

DATE: 2/10/23

PHONE #: (541) 643-6137

CERT #: 123

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County : Douglas		WTP - : Disinfection Giardia Log		WTP-A 0.5
				Month/Year : January / 2011		Temp pH	Required CT formula	CT Met? ³ Yes / No
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ ppm or mg/L	Contact Time (T) minutes	Actual CT C X T	Temp ° C				
1	0.62	120	74.4	6	7.15	25.37	YES	70
2	0.65	120	78.0	6	7.19	25.82	YES	70
3	0.66	120	79.2	5	7.47	30.59	YES	70
4	0.67	120	80.4	5	7.40	30.27	YES	70
5	0.65	120	78.0	5	7.62	32.26	YES	70
6	0.74	120	88.8	5	7.51	31.33	YES	70
7	0.74	120	88.8	5	7.61	32.49	YES	70
8	1.00	120	120.0	9	7.48	24.39	YES	70
9	0.89	120	106.8	6	7.46	29.25	YES	70
10	1.06	120	127.2	6	8.12	37.95	YES	70
11	0.99	120	118.8	5	7.52	32.37	YES	70
12	0.93	120	111.6	5	7.79	35.47	YES	70
13	0.93	120	111.6	6	7.58	30.69	YES	70
14	0.82	120	98.4	8	7.34	24.30	YES	70
15	0.93	120	111.6	6	7.45	29.28	YES	70
16	0.77	120	92.4	8	7.42	24.86	YES	70
17	0.75	120	90.0	6	7.60	30.27	YES	70
18	0.79	120	94.8	6	7.43	28.60	YES	70
19	0.88	120	105.6	6	7.55	30.18	YES	70
20	0.93	120	111.6	6	7.51	29.92	YES	70
21	0.84	120	100.8	8	7.29	23.93	YES	70
22	1.20	120	144.0	8	7.44	26.30	YES	70
23	1.02	120	122.4	6	7.56	30.79	YES	70
24	1.15	120	138.0	5	7.52	32.98	YES	70
25	1.13	120	135.6	5	7.57	33.51	YES	70
26	offline	120	#####			#VALUE!	#VALUE!	70
27	1.02	120	122.4	4	7.63	36.21	YES	70
28	0.92	120	110.4	5	7.47	31.53	YES	70
29	0.79	120	94.8	4	7.43	32.77	YES	70
30	1.12	120	134.4	4	7.72	37.87	YES	70
31	1.23	120	147.6	4	8.09	43.98	YES	70

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.