

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Nov-23

System Name:	PP&L Toketee Village		ID#: 41	01012			WTP: TP - Conventional
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	Set to Bad	Set to Bad	Set to Bad	0.05	POL	POL	0.05
2	0.05	POL	POL	0.05	0.04	POL	0.05
3	POL	POL	0.06	0.05	POL	POL	0.06
4	POL	POL	0.08	POL	POL	POL	0.08
5	POL	POL	0.05	POL	POL	POL	0.05
6	POL	POL	POL	POL	POL	POL	0.07
7	0.09	POL	POL	POL	POL	POL	0.09
8	POL	POL	POL	0.09	0.16	POL	0.16
9	POL	POL	POL	POL	POL	POL	0.00
10	POL	POL	POL	0.08	POL	0.00	0.08
11	POL	POL	POL	POL	POL	POL	0.00
12	POL	POL	POL	0.06	POL	POL	0.06
13	POL	POL	POL	POL	POL	POL	0.00
14	POL	POL	0.09	POL	POL	POL	0.09
15	POL	POL	POL	0.05	POL	POL	0.05
16	POL	POL	POL	POL	POL	POL	0.00
17	0.09	POL	POL	POL	POL	POL	0.09
18	POL	POL	0.08	0.05	POL	POL	0.08
19	POL	POL	POL	0.07	POL	POL	0.07
20	POL	POL	POL	POL	0.05	POL	0.05
21	POL	POL	POL	POL	POL	POL	0.06
22	0.06	POL	POL	POL	POL	POL	0.00
23	POL	POL	POL	0.05	POL	POL	0.06
24	POL	POL	POL	POL	0.05	POL	0.06
25	POL	POL	POL	POL	POL	POL	0.00
26	POL	POL	0.06	0.05	POL	POL	0.06
27	POL	POL	POL	POL	0.06	POL	0.06
28	POL	POL	POL	POL	POL	POL	0.00
29	0.06	0.10	0.12	POL	0.08	POL	0.20
30	POL	POL	POL	0.06	POL	POL	0.06
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> YES	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> YES		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / No		
Notes:	PRINTED NAME: Jonathan Woody	DATE: 12-9-23
	SIGNATURE: <i>John Woody</i>	CERT #: 7232
	PHONE #: (541) 643-6137	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:		PP&L Toketee Village		ID#:	County :	Douglas		WTP - :	WTP-A
				4101012	Month/Year :	November / 2023		Disinfection Giardia Log	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM	
1	0.54	120	64.8	9	7.52	23.48	YES	70	
2	0.52	120	62.4	10	7.04	18.55	YES	70	
3	0.56	120	67.2	10	7.26	20.11	YES	70	
4	0.62	120	74.4	11	6.67	15.51	YES	70	
5	0.54	120	64.8	11	7.43	19.94	YES	70	
6	0.61	120	73.2	11	7.56	21.03	YES	70	
7	0.54	120	64.8	11	7.54	20.72	YES	70	
8	0.64	120	76.8	11	7.70	22.16	YES	70	
9	0.67	120	80.4	12	7.39	18.70	YES	70	
10	0.69	120	82.8	12	7.42	18.93	YES	70	
11	0.69	120	82.8	12	7.46	19.20	YES	70	
12	0.55	120	66.0	12	7.52	19.30	YES	70	
13	0.50	120	60.0	9	7.50	23.20	YES	70	
14	0.47	120	56.4	9	7.60	23.96	YES	70	
15	0.62	120	74.4	11	7.50	20.62	YES	70	
16	0.65	120	78.0	9	7.30	22.00	YES	70	
17	0.66	120	79.2	9	7.62	24.66	YES	70	
18	0.63	120	75.6	9	7.51	23.63	YES	70	
19	0.66	120	79.2	9	7.58	24.31	YES	70	
20	0.64	120	77.2	8	7.99	30.06	YES	70	
21	0.70	120	84.0	9	7.67	25.22	YES	70	
22	0.72	120	86.4	8	7.53	25.71	YES	70	
23	0.67	120	80.4	10	7.55	22.53	YES	70	
24	0.64	120	76.8	8	7.28	23.31	YES	70	
25	0.67	120	80.4	8	7.28	23.39	YES	70	
26	0.67	120	80.4	8	7.36	24.06	YES	70	
27	0.76	120	91.2	6	7.30	27.20	YES	70	
28	0.74	120	88.8	6	7.57	29.91	YES	70	
29	0.72	120	86.4	6	7.37	27.77	YES	70	
30	0.77	120	92.4	6	7.71	31.58	YES	70	
31		120						70	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.