

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: Jun-24

System Name:	PP&L Toketee Village		ID#: 41	01012			WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	POL	0.03	POL	POL	POL	0.03	0.04	
2	POL	POL	POL	POL	0.03	POL	0.04	
3	POL	POL	POL	POL	POL	0.04	0.04	
4	0.04	POL	POL	POL	POL	POL	0.04	
5	POL	0.04	POL	POL	POL	POL	0.04	
6	0.04	POL	POL	POL	POL	POL	0.04	
7	0.05	0.04	POL	POL	POL	POL	0.06	
8	0.07	POL	POL	POL	POL	POL	0.07	
9	POL	POL	POL	0.16	POL	POL	0.16	
10	POL	POL	POL	0.15	POL	POL	0.15	
11	POL	POL	POL	0.04	POL	POL	0.04	
12	POL	POL	POL	0.04	POL	POL	0.04	
13	0.04	POL	POL	POL	0.03	POL	0.04	
14	POL	POL	0.04	POL	POL	POL	0.04	
15	0.07	0.04	POL	POL	POL	POL	0.07	
16	0.05	POL	POL	POL	POL	POL	0.05	
17	POL	0.05	POL	POL	POL	POL	0.05	
18	POL	POL	POL	POL	0.08	POL	0.08	
19	POL	POL	0.06	POL	POL	POL	0.06	
20	POL	0.06	POL	POL	POL	0.07	0.05	
21	POL	POL	POL	0.05	0.04	POL	0.05	
22	POL	0.04	POL	0.06	0.04	POL	0.06	
23	0.04	POL	0.04	0.05	POL	POL	0.05	
24	0.06	0.04	POL	POL	0.06	POL	0.06	
25	POL	0.04	0.09	0.04	POL	POL	0.09	
26	0.06	0.04	POL	POL	POL	0.07	0.07	
27	0.06	0.04	POL	POL	POL	POL	0.06	
28	POL	POL	0.04	0.04	POL	POL	0.04	
29	0.05	0.04	POL	POL	0.03	POL	0.05	
30	POL	0.04	POL	POL	POL	0.05	0.05	
31								

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		
Notes: Plant Maintenance in on 8-15-15 resulted in turbidimeter values not being recorded continuously. Plant returned to normal operation on 8-16-15.	PRINTED NAME: Jonathan Woody	
	SIGNATURE: <i>Jonathan Woody</i>	DATE: 7-7-24
	PHONE #: ( 541 ) 643-6137	CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))



**OHA - Drinking Water Program - Surface Water Quality Data Form**

System Name:	PP&L Toketee Village		ID#: 4101012	County :		Douglas		WTP - :	WTP-A
				Month/Year :		June / 2024		Disinfection Giardia Log	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM	
1	0.83	120	99.6	14	7.76	18.92	YES	70	
2	0.82	120	98.4	14	7.85	19.53	YES	70	
3	0.82	120	98.4	14	7.66	18.21	YES	70	
4	0.72	120	86.4	19	7.79	13.54	YES	70	
5	0.73	120	87.6	14	7.71	18.36	YES	70	
6	0.76	120	91.2	14	7.73	18.56	YES	70	
7	0.87	120	104.4	16	7.63	15.86	YES	70	
8	0.72	120	86.4	15	7.83	17.94	YES	70	
9	0.72	120	86.4	15	7.76	17.48	YES	70	
10	0.58	120	69.6	16	7.87	16.77	YES	70	
11	0.58	120	69.6	16	7.89	16.89	YES	70	
12	0.67	120	80.4	16	7.64	15.56	YES	70	
13	0.83	120	99.6	16	7.73	16.38	YES	70	
14	0.79	120	94.8	17	7.83	15.83	YES	70	
15	0.51	120	61.2	17	7.86	15.50	YES	70	
16	0.52	120	62.4	14	7.78	18.40	YES	70	
17	0.53	120	63.6	21	7.70	11.20	YES	70	
18	0.77	120	92.4	15	7.81	17.91	YES	70	
19	0.72	120	86.4	14	7.83	19.17	YES	70	
20	0.76	120	91.2	15	7.85	18.16	YES	70	
21	0.76	120	91.2	15	7.82	17.96	YES	70	
22	0.74	120	88.8	16	7.93	17.46	YES	70	
23	0.76	120	91.2	16	7.94	17.56	YES	70	
24	0.73	120	87.6	16	7.93	17.44	YES	70	
25	0.73	120	87.6	16	7.82	16.74	YES	70	
26	0.68	120	81.6	17	7.82	15.57	YES	70	
27	0.63	120	75.6	17	7.82	15.49	YES	70	
28	0.72	120	86.4	17	7.74	15.19	YES	70	
29	0.44	120	52.8	16	7.91	16.75	YES	70	
30	0.64	120	76.8	17	7.95	16.27	YES	70	
31		120						70	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.