

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County: Douglas  
 Month/Year: Sep-24

Conventional or Direct Filtration

WTP : TP - Conventional

System Name: PP&L Toketee Village ID#: 41 01012

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	POL	0.05	POL	POL	POL	POL	0.05
2	0.05	POL	0.04	POL	POL	POL	0.05
3	0.05	POL	POL	0.03	POL	POL	0.03
4	POL	POL	0.04	0.02	POL	POL	0.04
5	0.04	POL	0.03	0.03	POL	0.03	0.04
6	0.04	POL	0.03	POL	POL	0.03	0.04
7	0.02	POL	POL	POL	0.04	POL	0.04
8	0.03	POL	0.03	0.08	0.03	POL	0.08
9	0.03	0.03	POL	POL	POL	0.03	0.03
10	POL	POL	0.03	POL	0.07	0.03	0.07
11	POL	POL	0.06	0.03	POL	0.05	0.06
12	POL	POL	0.03	POL	POL	0.04	0.06
13	POL	POL	POL	0.04	POL	POL	0.04
14	POL	0.03	POL	POL	POL	0.04	0.04
15	0.03	POL	POL	POL	0.04	POL	0.04
16	POL	POL	0.04	POL	POL	POL	0.04
17	POL	POL	POL	POL	0.04	POL	0.04
18	POL	0.03	POL	POL	POL	POL	0.08
19	0.03	POL	0.08	0.05	POL	POL	0.08
20	0.03	POL	POL	POL	POL	0.03	0.03
21	POL	0.03	0.03	POL	POL	POL	0.03
22	0.03	POL	POL	POL	POL	POL	0.03
23	POL	POL	POL	POL	POL	POL	0.03
24	0.03	POL	0.04	POL	POL	POL	0.04
25	POL	POL	POL	POL	0.04	POL	0.04
26	0.03	POL	0.03	0.03	POL	POL	0.03
27	POL	POL	0.03	0.03	POL	POL	0.03
28	0.03	POL	POL	POL	0.03	POL	0.03
29	POL	POL	POL	0.06	0.03	POL	0.06
30	POL	0.03	POL	POL	0.03	POL	0.03
31	POL	POL	0.03	POL	POL	POL	0.00

<p><b>Conventional or Direct Filtration</b></p> <p>95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> YES</p> <p>All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> YES</p> <p>All turbidity readings &lt; IFE<sup>2</sup> triggers <input checked="" type="radio"/> Yes / No</p>		<p><b>Monthly Summary (Answer Yes or No)</b></p> <p>CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No</p> <p>All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No</p>	
<p>Notes:</p>		<p>PRINTED NAME: John Woody</p> <p>SIGNATURE: <i>John Woody</i></p> <p>PHONE #: (541) 643-6137</p>	
		<p>DATE: 10-5-24</p> <p>CERT #: 7232</p>	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:		PP&L Toketee Village		ID#:	County :	Douglas		WTP - :	WTP-A
				4101012	Month/Year :	Sep-2024		Disinfection Giardia Log	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM	
1	0.58	120	69.6	16	7.62	15.28	YES	70	
2	0.54	120	64.8	17	7.87	15.61	YES	70	
3	0.61	120	73.2	17	7.71	14.83	YES	70	
4	0.67	120	80.4	19	7.80	13.51	YES	70	
5	0.57	120	68.4	16	7.83	16.50	YES	70	
6	0.54	120	64.8	18	7.66	13.51	YES	70	
7	0.54	120	64.8	18	7.68	13.61	YES	70	
8	0.68	120	81.6	16	7.83	16.71	YES	70	
9	0.66	120	79.2	16	7.85	16.79	YES	70	
10	0.67	120	80.4	16	7.89	17.06	YES	70	
11	0.53	120	63.6	16	7.76	16.01	YES	70	
12	0.61	120	73.2	15	7.82	17.65	YES	70	
13	0.48	120	57.6	15	7.75	16.95	YES	70	
14	0.45	120	54.0	15	7.76	16.95	YES	70	
15	0.35	120	42.0	15	7.79	16.95	YES	70	
16	0.50	120	60.0	15	7.83	17.50	YES	70	
17	0.48	120	57.6	15	7.82	17.39	YES	70	
18	0.29	120	34.8	15	7.76	16.65	YES	70	
19	0.32	120	38.4	15	7.79	16.89	YES	70	
20	0.66	120	79.2	14	7.82	18.97	YES	70	
21	0.63	120	75.6	15	7.80	17.56	YES	70	
22	0.68	120	81.6	14	7.89	19.51	YES	70	
23	0.70	120	84.0	14	7.83	19.13	YES	70	
24	0.68	120	81.6	15	7.80	17.66	YES	70	
25	0.68	120	81.6	15	7.85	17.99	YES	70	
26	0.68	120	81.6	15	7.89	18.26	YES	70	
27	0.71	120	85.2	15	7.94	18.66	YES	70	
28	0.69	120	82.8	15	7.89	18.28	YES	70	
29	0.72	120	86.4	15	7.87	18.21	YES	70	
30	0.71	120	85.2	14	7.79	18.87	YES	70	
31		120						70	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.