

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: May-25

System Name: PP&L Toketee Village		ID#: 41 01012		WTP: TP - Conventional			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	0.11	0.06	POL	0.11
2	POL	POL	0.04	POL	POL	POL	0.06
3	POL	POL	POL	0.04	POL	POL	0.04
4	POL	POL	POL	POL	POL	POL	0.05
5	0.02	POL	POL	0.04	POL	POL	0.04
6	POL	POL	POL	POL	POL	POL	0.00
7	0.14	0.02	POL	POL	POL	POL	0.14
8	POL	POL	0.08	POL	POL	POL	0.08
9	POL	POL	POL	0.05	POL	POL	0.05
10	POL	POL	0.07	0.02	POL	0.00	0.07
11	POL	POL	0.05	POL	POL	POL	0.05
12	POL	POL	POL	POL	POL	0.03	0.03
13	POL	POL	POL	POL	POL	POL	0.00
14	POL	POL	0.04	0.02	POL	POL	0.04
15	POL	POL	POL	POL	0.03	0.02	0.03
16	POL	POL	POL	POL	POL	POL	0.00
17	POL	POL	0.05	0.02	POL	POL	0.05
18	POL	POL	POL	POL	POL	POL	0.00
19	POL	POL	0.02	POL	POL	POL	0.04
20	POL	POL	0.03	POL	POL	POL	0.03
21	POL	POL	POL	POL	0.02	POL	0.12
22	POL	POL	0.02	POL	POL	POL	0.05
23	POL	0.02	POL	POL	POL	POL	0.03
24	POL	POL	POL	POL	POL	0.06	0.06
25	0.02	POL	POL	POL	POL	POL	0.00
26	0.04	0.02	POL	POL	POL	POL	0.04
27	POL	0.02	POL	POL	POL	POL	0.09
28	POL	POL	POL	0.02	POL	POL	0.05
29	POL	POL	0.04	POL	POL	POL	0.04
30	0.03	0.02	POL	POL	POL	POL	0.03
31	0.08	0.02	0.07	0.03	POL	POL	0.08

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ YES	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ YES	☒ Yes / No	☒ Yes / No
All turbidity readings < IFE ² triggers	☒ Yes / No		

Notes:	PRINTED NAME: Jonathan Woods
	SIGNATURE: <i>Jonathan Woods</i> DATE: 6-9-25
	PHONE #: (541) 643-6137 CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County : Month/Year :	Douglas May / 2025		WTP - : Disinfection Giardia Log	WTP-A 0.5
Date / Time	Minimum Cl₂ Residual at 1st User (C)³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM
1	0.52	120	62.4	11	7.62	21.26	YES	70
2	0.62	120	74.4	12	7.61	20.06	YES	70
3	0.55	120	66.0	14	7.32	15.58	YES	70
4	0.59	120	70.8	15	7.46	15.42	YES	70
5	0.59	120	70.8	16	7.64	15.42	YES	70
6	0.68	120	81.6	12	7.70	20.84	YES	70
7	0.59	120	70.8	17	7.61	14.26	YES	70
8	0.62	120	74.4	13	7.51	18.00	YES	70
9	0.64	120	76.8	14	7.53	17.01	YES	70
10	0.66	120	79.2	14	7.53	17.05	YES	70
11	0.62	120	74.4	13	7.57	18.41	YES	70
12	0.64	120	76.8	14	7.56	17.20	YES	70
13	0.65	120	78.0	11	7.35	19.63	YES	70
14	0.61	120	73.2	13	7.71	19.36	YES	70
15	0.59	120	70.8	13	7.45	17.55	YES	70
16	0.58	120	69.6	13	7.62	18.66	YES	70
17	0.56	120	67.2	13	7.54	18.08	YES	70
18	0.64	120	76.8	13	7.31	16.76	YES	70
19	0.58	120	69.6	13	7.52	17.99	YES	70
20	0.68	120	81.6	13	7.57	18.53	YES	70
21	0.69	120	82.8	13	7.40	17.42	YES	70
22	0.71	120	85.2	14	7.42	16.46	YES	70
23	1.08	120	129.6	14	7.62	18.48	YES	70
24	0.99	120	118.8	17	7.30	13.30	YES	70
25	0.97	120	116.4	17	7.42	13.88	YES	70
26	1.09	120	130.8	14	7.69	18.99	YES	70
27	0.73	120	87.6	16	7.59	15.38	YES	70
28	0.99	120	118.8	14	7.57	17.96	YES	70
29	0.91	120	109.2	16	7.56	15.52	YES	70
30	1.06	120	127.2	16	7.56	15.79	YES	70
31	1.05	120	126.0	18	7.68	14.43	YES	70

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised October 31 2013, E. Hightower