

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County: **Douglas**

Conventional or Direct Filtration

Month/Year: **Jul-25**

System Name:	PP&L Toketee Village			ID#: 41	01012	WTP : TP - Conventional	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	0.02	POL	POL	POL	POL	0.03
2	0.03	0.02	0.02	0.03	POL	POL	0.05
3	POL	0.02	POL	POL	POL	POL	0.03
4	0.03	0.02	POL	POL	POL	POL	0.03
5	0.03	0.02	POL	POL	POL	POL	0.03
6	0.04	POL	POL	POL	POL	0.04	0.04
7	0.03	POL	0.03	POL	POL	POL	0.03
8	POL	POL	POL	POL	POL	POL	0.00
9	POL	POL	0.06	0.03	POL	0.02	0.06
10	POL	POL	POL	0.03	POL	0.00	0.03
11	POL	0.02	POL	POL	POL	POL	0.03
12	0.03	0.02	POL	0.03	0.03	POL	0.06
13	0.03	POL	0.03	POL	0.03	0.02	0.03
14	0.03	0.02	0.03	POL	POL	0.02	0.04
15	POL	POL	0.02	POL	POL	POL	0.03
16	0.04	0.04	0.06	0.02	POL	POL	0.06
17	0.04	0.03	POL	POL	POL	0.04	0.04
18	POL	POL	POL	POL	POL	POL	POL
19	0.05	POL	0.07	0.03	POL	POL	0.07
20	POL	0.05	0.04	POL	POL	POL	0.05
21	POL	0.03	0.03	0.03	0.03	POL	0.04
22	POL	0.03	POL	POL	POL	POL	0.04
23	0.05	0.03	0.01	0.03	POL	POL	0.10
24	POL	POL	POL	POL	POL	POL	0.00
25	POL	0.03	0.03	POL	POL	POL	0.03
26	POL	0.02	POL	POL	POL	POL	0.04
27	POL	POL	POL	POL	POL	POL	0.00
28	POL	POL	POL	POL	POL	0.04	0.04
29	0.03	POL	0.03	POL	POL	POL	0.03
30	POL	0.03	0.03	0.03	POL	POL	0.08
31	POL	0.03	POL	POL	POL	POL	0.03

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?**YES**All 4-hour turbidity readings $\leq$ 1 NTU?**YES**All turbidity readings < IFE² triggers**Yes / No**

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)**Yes / No**All Cl2 residual at entry point
 $\geq$ 0.2 mg/l?**Yes / No**

Notes: POL= Plant Offline

PRINTED NAME:

John Woody

SIGNATURE:

John WoodyDATE: **8/1/25**

PHONE #:

(541) 643-6137CERT #: **7232**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: PP&L Toketee Village	ID#: 41	01012	Month/Year: Jul-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--	----------------	--------------	---------------------------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.73	120	87.6	18.0	7.78	14.4	Yes	70
2	0.67	120	80.4	17.0	7.95	16.3	Yes	70
3	0.61	120	73.2	18.0	7.88	14.8	Yes	70
4	0.61	120	73.2	19.0	7.84	13.6	Yes	70
5	0.68	120	81.6	18.0	8.06	15.9	Yes	70
6	0.68	120	81.6	18.0	8.01	15.6	Yes	70
7	0.64	120	76.8	18.0	8.02	15.6	Yes	70
8	0.56	120	67.2	20.0	8.03	13.6	Yes	70
9	0.86	120	103.2	19.0	7.96	14.7	Yes	70
10	0.86	120	103.2	18.0	7.99	15.8	Yes	70
11	0.85	120	102.0	19.0	7.85	14.0	Yes	70
12	0.92	120	110.4	20.0	7.96	13.8	Yes	70
13	0.81	120	97.2	19.0	8.01	14.8	Yes	70
14	0.67	120	80.4	20.0	7.89	13.1	Yes	70
15	0.72	120	86.4	21.0	8.06	13.1	Yes	70
16	0.74	120	88.8	20.0	8.05	14.0	Yes	70
17	0.67	120	80.4	20.0	8.01	13.7	Yes	70
18	Plant Offline	120	#VALUE!	POL	POL	#VALUE!	Yes	70
19	0.82	120	98.4	20.0	8.14	14.6	Yes	70
20	0.62	120	74.4	19.0	8.01	14.5	Yes	70
21	0.92	120	110.4	19.0	8.04	15.2	Yes	70
22	0.84	120	100.8	18.0	8.04	16.1	Yes	70
23	0.39	120	46.8	19.0	7.93	13.7	Yes	70
24	0.66	120	79.2	19.0	7.92	14.1	Yes	70
25	0.65	120	78.0	18.0	7.95	15.2	Yes	70
26	0.68	120	81.6	19.0	8.05	14.8	Yes	70
27	0.65	120	78.0	19.0	8.01	14.6	Yes	70
28	0.66	120	79.2	18.0	7.97	15.4	Yes	70
29	0.49	120	58.8	19.0	7.93	13.9	Yes	70
30	0.65	120	78.0	19.0	8.01	14.6	Yes	70
31	0.7	120	84.0	19.0	7.98	14.5	Yes	70

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012