

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
 Month/Year: Aug-25

System Name: <u>PP&L Toketee Village</u>		ID#: <u>41</u>		<u>01012</u>		WTP : <u>TP - Conventional</u>	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.03	POL	POL	POL	POL	0.03
2	POL	POL	0.03	POL	POL	POL	0.04
3	0.04	0.03	POL	POL	POL	POL	0.04
4	0.03	0.03	POL	POL	POL	POL	0.03
5	0.04	0.02	POL	POL	POL	0.04	0.04
6	POL	POL	0.03	POL	POL	POL	0.03
7	0.04	0.03	POL	POL	POL	POL	0.04
8	0.04	POL	POL	POL	POL	0.03	0.03
9	POL	POL	0.03	0.02	POL	POL	0.03
10	POL	0.03	POL	POL	0.03	0.00	0.08
11	POL	POL	POL	0.03	POL	POL	0.03
12	POL	0.03	POL	POL	POL	POL	0.03
13	0.04	POL	POL	POL	0.03	POL	0.04
14	POL	0.03	POL	POL	POL	POL	0.03
15	0.04	0.03	POL	0.04	POL	POL	0.04
16	POL	POL	POL	POL	POL	0.03	0.05
17	POL	POL	POL	POL	POL	POL	0.00
18	0.04	0.03	POL	POL	POL	0.02	0.04
19	0.02	POL	0.03	POL	POL	POL	0.03
20	POL	0.05	0.06	0.06	POL	POL	0.07
21	POL	0.02	0.06	POL	POL	POL	0.09
22	0.02	POL	0.03	POL	POL	POL	0.03
23	POL	0.02	0.02	POL	POL	0.02	0.12
24	POL	0.05	0.04	POL	0.04	0.03	0.16
25	POL	POL	0.04	0.03	0.03	POL	0.04
26	POL	0.03	POL	POL	POL	POL	0.05
27	0.05	POL	POL	0.03	0.03	0.02	0.03
28	0.02	0.02	POL	POL	POL	0.05	0.05
29	0.02	POL	0.03	0.02	POL	POL	0.03
30	POL	0.02	0.10	0.03	POL	POL	0.10
31	POL	0.03	POL	POL	POL	POL	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	<u>YES</u>	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	<u>YES</u>	<u>Yes</u> / No	<u>Yes</u> / No
All turbidity readings < IFE ² triggers	<u>Yes</u> / No		
Notes:		PRINTED NAME: <u>Jonathan Woody</u>	
		SIGNATURE: <u>John Woody</u>	DATE: <u>9-10-25</u>
		PHONE #: <u>(541) 643-6137</u>	CERT #: <u>7232</u>

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#:	County :	Douglas		WTP - :	WTP-A
			4101012	Month/Year :	August / 2025		Disinfection Giardia Log	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM
1	0.69	120	82.8	22	8.01	11.97	YES	70
2	0.67	120	80.4	20	8.06	13.92	YES	70
3	0.67	120	80.4	20	8.05	13.87	YES	70
4	0.70	120	84.0	18	8.38	17.96	YES	70
5	0.65	120	78.0	18	8.15	16.41	YES	70
6	0.63	120	75.6	18	7.90	14.92	YES	70
7	0.65	120	78.0	20	7.99	13.53	YES	70
8	0.64	120	76.8	19	8.05	14.77	YES	70
9	0.66	120	79.2	18	8.07	15.95	YES	70
10	0.63	120	75.6	18	8.10	16.07	YES	70
11	0.52	120	62.4	21	7.95	12.28	YES	70
12	0.60	120	72.0	21	7.90	12.16	YES	70
13	0.65	120	78.0	20	7.92	13.18	YES	70
14	0.57	120	68.4	20	7.97	13.31	YES	70
15	1.06	120	127.2	20	7.96	14.02	YES	70
16	0.98	120	117.6	20	8.10	14.63	YES	70
17	0.98	120	117.6	20	7.98	14.00	YES	70
18	0.82	120	98.4	20	7.96	13.64	YES	70
19	0.63	120	75.6	23	8.10	11.50	YES	70
20	0.48	120	57.6	23	7.83	10.21	YES	70
21	0.58	120	69.6	19	7.67	12.74	YES	70
22	1.62	120	194.4	20	7.53	12.74	YES	70
23	0.78	120	93.6	21	7.42	10.38	YES	70
24	0.42	120	50.4	22	7.35	9.06	YES	70
25	0.43	120	51.6	22	7.35	9.07	YES	70
26	0.31	120	37.2	23	7.34	8.33	YES	70
27	0.41	120	49.2	22	7.41	9.26	YES	70
28	0.63	120	75.6	22	7.51	9.86	YES	70
29	0.74	120	88.8	19	7.92	14.24	YES	70
30	0.78	120	93.6	20	7.90	13.28	YES	70
31	0.74	120	88.8	20	7.90	13.22	YES	70

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised October 31 2013 - E. Hightower