

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Sep-25

System Name: PP&L Toketee Village		ID#: 41		01012		WTP : TP - Conventional	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	0.02	POL	POL	POL	POL	0.03
2	0.03	0.02	POL	POL	POL	POL	0.05
3	0.02	POL	POL	0.02	POL	POL	0.02
4	POL	0.03	POL	POL	POL	POL	0.03
5	0.03	0.02	POL	POL	POL	0.03	0.03
6	0.02	POL	POL	0.03	POL	POL	0.03
7	POL	0.03	POL	POL	POL	POL	0.04
8	POL	0.03	POL	0.03	0.03	POL	0.09
9	POL	POL	POL	POL	POL	POL	0.04
10	POL	POL	POL	POL	0.04	0.00	0.04
11	POL	POL	POL	POL	POL	POL	0.00
12	POL	POL	POL	POL	POL	POL	0.00
13	POL	POL	0.03	POL	POL	POL	0.03
14	POL	POL	POL	0.04	0.02	POL	0.04
15	POL	POL	POL	POL	POL	0.04	0.04
16	0.03	POL	POL	0.03	POL	POL	0.03
17	POL	0.03	POL	POL	POL	POL	0.03
18	POL	POL	POL	0.04	POL	POL	0.04
19	POL	0.04	POL	POL	POL	POL	0.04
20	POL	POL	0.05	POL	POL	POL	0.05
21	POL	0.04	POL	0.10	0.03	POL	0.10
22	POL	POL	POL	POL	POL	0.03	0.03
23	0.03	POL	POL	POL	POL	POL	0.00
24	0.03	0.02	POL	POL	POL	0.03	0.03
25	0.02	POL	POL	POL	POL	POL	0.03
26	0.03	POL	POL	POL	POL	POL	0.00
27	0.04	0.03	POL	POL	POL	POL	0.04
28	POL	POL	POL	POL	POL	POL	0.00
29	POL	0.04	POL	POL	POL	POL	0.04
30	POL	0.04	0.03	POL	POL	POL	0.04
31	POL	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	0.00

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

YES

All 4-hour turbidity readings $\leq$ 1 NTU?

YES

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Jonathan Woody

SIGNATURE: Jonathan Woody

DATE: 10-9-25

PHONE #: (541) 643-6137

CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Conventional

System Name:	PP&L Toketee Village	ID#: 41	01012	Month/Year:	Sep-25	Disinfection Giardia Log Inactiv:	0.5
--------------	----------------------	---------	-------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.76	120.0	91.2	19	7.88	14.1	Yes	70
2	0.68	120.0	81.6	19	7.71	13.1	Yes	70
3	0.69	120.0	82.8	19	7.83	13.7	Yes	70
4	0.70	120.0	84.0	20	7.95	13.4	Yes	70
5	0.69	120.0	82.8	20	7.94	13.3	Yes	70
6	0.67	120.0	80.4	20	7.98	13.5	Yes	70
7	0.67	120.0	80.4	20	8.06	13.9	Yes	70
8	0.68	120.0	81.6	18	8.01	15.6	Yes	70
9	0.51	120.0	61.2	18	7.80	14.2	Yes	70
10	0.50	120.0	60.0	18	7.82	14.3	Yes	70
11	0.50	120.0	60.0	18	7.80	14.2	Yes	70
12	0.50	120.0	60.0	17	7.87	15.5	Yes	70
13	0.52	120.0	62.4	18	7.89	14.7	Yes	70
14	0.52	120.0	62.4	18	7.86	14.5	Yes	70
15	0.47	120.0	56.4	18	7.86	14.4	Yes	70
16	0.51	120.0	61.2	17	7.96	16.1	Yes	70
17	0.51	120.0	61.2	18	7.91	14.8	Yes	70
18	0.58	120.0	69.6	18	7.90	14.8	Yes	70
19	0.57	120.0	68.4	20	7.99	13.4	Yes	70
20	0.57	120.0	68.4	18	7.83	14.4	Yes	70
21	0.56	120.0	67.2	18	7.91	14.9	Yes	70
22	0.56	120.0	67.2	17	7.89	15.8	Yes	70
23	0.52	120.0	62.4	15	7.80	17.3	Yes	70
24	0.62	120.0	74.4	16	7.88	16.9	Yes	70
25	0.63	120.0	75.6	16	7.90	17.1	Yes	70
26	0.65	120.0	78.0	15	8.03	19.2	Yes	70
27	0.68	120.0	81.6	15	8.09	19.7	Yes	70
28	0.65	120.0	78.0	15	7.98	18.8	Yes	70
29	0.50	120.0	60.0	16	7.83	16.4	Yes	70
30	0.56	120.0	67.2	16	7.89	16.9	Yes	70
31		120.0						70

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012