

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Mar-21**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	0.09	POL	POL	0.09
2	POL	POL	POL	0.08	POL	POL	0.08
3	POL	POL	0.06	POL	POL	POL	0.06
4	POL	POL	POL	0.10	POL	0.08	0.10
5	POL	POL	POL	POL	POL	POL	0.00
6	POL	POL	0.04	POL	POL	POL	0.04
7	POL	POL	POL	0.06	POL	POL	0.06
8	POL	POL	POL	POL	0.03	POL	0.03
9	POL	POL	POL	0.04	POL	POL	0.04
10	POL	POL	POL	POL	POL	0.00	0.00
11	POL	POL	POL	POL	POL	POL	0.00
12	POL	POL	POL	0.06	0.02	POL	0.06
13	POL	POL	0.05	POL	POL	POL	0.05
14	POL	POL	0.03	POL	POL	POL	0.03
15	POL	POL	0.03	POL	POL	POL	0.03
16	POL	POL	POL	0.08	POL	POL	0.08
17	POL	POL	POL	0.04	POL	POL	0.04
18	POL	POL	POL	0.05	POL	POL	0.05
19	POL	POL	POL	POL	POL	POL	0.00
20	POL	POL	0.02	POL	POL	POL	0.05
21	POL	POL	POL	0.05	POL	POL	0.05
22	POL	POL	POL	0.03	POL	POL	0.03
23	POL	POL	POL	POL	POL	POL	0.00
24	POL	0.09	POL	POL	POL	POL	0.09
25	POL	POL	0.03	POL	POL	POL	0.03
26	POL	POL	0.05	POL	POL	POL	0.05
27	POL	POL	POL	0.03	POL	POL	0.03
28	POL	POL	POL	0.02	POL	POL	0.04
29	POL	POL	POL	0.03	POL	POL	0.04
30	POL	POL	POL	POL	POL	POL	0.00
31	POL	POL	POL	0.04	POL	POL	0.08

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? (YES)	CT's met everyday? (see back) (Yes) / No	All Cl2 residual at entry point ≥ 0.2 mg/l? (Yes) / No
All 4-hour turbidity readings ≤ 1 NTU? (YES)		
All turbidity readings < IFE ² triggers (Yes) / No		

Notes:	PRINTED NAME: <i>Jonathan Woody</i>	
	SIGNATURE: <i>Jonathan Woody</i>	DATE: 4-7-21
	PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County :	Douglas		WTP - :	WTP-A
				Month/Year :	March / 2021		Disinfection Giardia Log	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM
1	0.70	120	84.0	5	7.40	29.96	YES	70
2	0.74	120	88.8	5	7.38	29.89	YES	70
3	0.68	120	81.6	5	7.47	30.66	YES	70
4	0.63	120	75.6	5	7.52	31.04	YES	70
5	0.53	120	63.6	5	7.32	28.54	YES	70
6	0.56	120	67.2	5	7.41	29.59	YES	70
7	0.44	120	52.8	7	7.48	26.15	YES	70
8	0.64	120	76.8	7	7.89	31.02	YES	70
9	0.56	120	67.2	7	7.61	27.78	YES	70
10	0.56	120	67.2	6	7.59	29.51	YES	70
11	0.60	120	72.0	5	7.52	30.93	YES	70
12	0.66	120	79.2	7	7.38	25.88	YES	70
13	0.60	120	72.0	8	7.42	24.38	YES	70
14	0.61	120	73.2	7	7.46	26.47	YES	70
15	0.60	120	72.0	6	7.41	27.78	YES	70
16	0.63	120	75.6	8	7.29	23.36	YES	70
17	0.72	120	86.4	7	7.65	28.71	YES	70
18	0.61	120	73.2	7	7.36	25.55	YES	70
19	0.46	120	55.2	7	7.57	27.07	YES	70
20	0.46	120	55.2	7	7.42	25.65	YES	70
21	0.55	120	66.0	7	7.69	28.66	YES	70
22	0.55	120	66.0	7	7.43	26.01	YES	70
23	0.57	120	68.4	7	7.55	27.22	YES	70
24	0.60	120	72.0	6	7.62	29.97	YES	70
25	0.70	120	84.0	7	7.40	26.18	YES	70
26	0.73	120	87.6	7	7.48	27.04	YES	70
27	0.78	120	93.6	7	6.70	20.63	YES	70
28	0.69	120	82.8	7	7.36	25.78	YES	70
29	0.74	120	88.8	7	7.14	23.98	YES	70
30	0.71	120	85.2	7	7.42	26.40	YES	70
31	0.60	120	72.0	7	7.54	27.21	YES	70