

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: **Douglas**  
 Month/Year: **Sep-21**

Conventional or Direct Filtration

System Name:	PP&L Toketee Village		ID#: 41	01012		WTP : TP - Conventional	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.04	0.03	0.03	POL	0.04	0.03	0.04
2	POL	0.04	0.03	POL	0.04	POL	0.04
3	POL	0.03	0.03	POL	POL	POL	0.04
4	POL	0.04	POL	POL	POL	POL	0.04
5	POL	0.04	POL	POL	POL	POL	0.04
6	POL	POL	POL	0.04	POL	POL	0.04
7	POL	POL	0.05	POL	POL	POL	0.05
8	POL	0.04	0.04	0.03	POL	POL	0.11
9	POL	POL	0.04	POL	POL	POL	0.04
10	POL	0.04	POL	0.04	POL	0.00	0.04
11	POL	POL	0.04	0.04	POL	POL	0.04
12	POL	POL	0.04	POL	POL	POL	0.04
13	POL	POL	0.05	POL	POL	POL	0.05
14	POL	0.05	0.03	POL	POL	POL	0.05
15	POL	0.06	POL	POL	POL	POL	0.06
16	POL	0.05	POL	POL	POL	POL	0.05
17	POL	0.05	POL	POL	POL	POL	0.05
18	POL	POL	0.05	POL	POL	POL	0.05
19	POL	POL	POL	POL	POL	POL	0.06
20	POL	POL	POL	POL	POL	POL	0.00
21	POL	POL	0.04	0.09	POL	POL	0.14
22	POL	POL	0.06	0.04	POL	POL	0.06
23	POL	POL	POL	POL	POL	POL	0.04
24	POL	POL	POL	POL	POL	POL	0.00
25	POL	POL	POL	POL	0.05	POL	0.05
26	POL	POL	POL	0.04	0.04	POL	0.04
27	POL	POL	POL	POL	POL	POL	0.00
28	POL	POL	0.09	0.05	POL	POL	0.09
29	POL	POL	0.05	POL	POL	POL	0.05
30	POL	POL	0.05	0.04	POL	POL	0.05
31	POL	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	0.00

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <b>YES</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes / No</b>
All 4-hour turbidity readings ≤ 1 NTU? <b>YES</b>		
All turbidity readings < IFE <sup>2</sup> triggers <b>Yes / No</b>		

Notes:	PRINTED NAME: <b>Jonathan Woady</b>
	SIGNATURE: <b>John Woady</b> DATE: <b>10-3-21</b>
	PHONE #: <b>(541) 643-6137</b> CERT #: <b>7232</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))  
 PAGE 1 of 2

## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County : Douglas		WTP - : Disinfection Giardia Log		WTP-A 0.5
				Month/Year :	Sept - 2021			
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM
1	0.66	120	79.2	19	7.58	12.43	YES	70
2	0.42	120	50.4	19	7.48	11.65	YES	70
3	0.53	120	63.6	17	7.50	13.60	YES	70
4	0.62	120	74.4	18	8.02	15.58	YES	70
5	0.58	120	69.6	19	7.66	12.69	YES	70
6	0.49	120	58.8	19	7.37	11.27	YES	70
7	0.45	120	54.0	20	7.35	10.41	YES	70
8	0.64	120	76.8	19	7.89	13.92	YES	70
9	0.70	120	84.0	17	7.41	13.41	YES	70
10	0.56	120	67.2	19	7.47	11.80	YES	70
11	0.61	120	73.2	18	7.57	13.17	YES	70
12	0.72	120	86.4	18	7.50	12.99	YES	70
13	0.62	120	74.4	19	7.70	12.94	YES	70
14	0.61	120	73.2	18	7.51	12.88	YES	70
15	0.58	120	69.6	18	7.63	13.42	YES	70
16	0.51	120	61.2	18	7.37	12.08	YES	70
17	0.68	120	81.6	18	7.88	14.90	YES	70
18	0.68	120	81.6	18	7.76	14.25	YES	70
19	0.72	120	86.4	18	7.86	14.85	YES	70
20	0.63	120	75.6	18	7.58	13.25	YES	70
21	0.40	120	48.0	17	7.60	13.90	YES	70
22	0.61	120	73.2	17	6.88	10.89	YES	70
23	0.45	120	54.0	17	7.55	13.72	YES	70
24	0.48	120	57.6	17	7.48	13.42	YES	70
25	0.58	120	69.6	16	7.56	14.95	YES	70
26	0.68	120	81.6	17	7.54	14.04	YES	70
27	0.57	120	68.4	16	7.43	14.23	YES	70
28	0.58	120	69.6	16	7.50	14.62	YES	70
29	0.58	120	69.6	16	7.42	14.19	YES	70
30	0.55	120	66.0	15	7.69	16.71	YES	70
31	0.47	120	56.4	15	7.64	16.25	YES	70

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.