

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Sep-22

System Name: PP&L Toketee Village		ID#: 41		01012		WTP : TP - Conventional	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	0.04	POL	POL	POL	0.05
2	POL	0.04	POL	POL	POL	POL	0.04
3	POL	0.04	POL	POL	POL	POL	0.05
4	POL	0.05	POL	POL	POL	0.05	0.05
5	0.04	POL	POL	0.06	0.04	POL	0.06
6	POL	POL	POL	POL	0.11	POL	0.11
7	POL	0.06	POL	POL	POL	0.05	0.06
8	POL	POL	0.05	0.05	POL	POL	0.05
9	POL	POL	POL	POL	POL	POL	POL
10	POL	POL	POL	0.05	POL	0.00	0.05
11	POL	0.05	POL	POL	0.04	POL	0.05
12	POL	POL	POL	POL	0.04	POL	0.13
13	POL	POL	POL	0.04	POL	POL	0.05
14	POL	POL	0.05	POL	POL	POL	0.05
15	POL	0.05	POL	POL	POL	POL	0.05
16	POL	POL	POL	0.05	POL	POL	0.05
17	POL	POL	POL	0.07	0.07	POL	0.07
18	POL	POL	POL	POL	POL	POL	POL
19	POL	POL	POL	POL	POL	POL	POL
20	POL	POL	POL	POL	POL	POL	POL
21	POL	POL	POL	0.06	POL	POL	0.06
22	POL	POL	POL	0.05	POL	POL	0.05
23	POL	POL	POL	0.06	POL	POL	0.06
24	POL	POL	POL	0.05	POL	POL	0.05
25	POL	0.06	POL	0.05	POL	POL	0.06
26	POL	POL	POL	POL	0.06	POL	0.06
27	POL	POL	POL	POL	0.09	POL	0.09
28	POL	POL	POL	POL	POL	0.05	0.06
29	POL	POL	POL	POL	POL	POL	0.00
30	POL	0.06	POL	POL	POL	POL	0.06
31	POL	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	0.00

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> YES All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> YES All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> YES / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> YES / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> YES / No
Notes:	PRINTED NAME: Jonathan Woody SIGNATURE: <i>John Woody</i> PHONE #: (541) 643-6137	
	DATE: 10-6-22 CERT #: 7232	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County :		Douglas		WTP - :	WTP-A
				Month/Year :		Sep-2022		Disinfection Giardia Log	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM	
1	0.94	120	112.8	20	7.42	11.31	YES	70	
2	0.91	120	109.2	20	7.72	12.60	YES	70	
3	0.78	120	93.6	21	7.54	10.85	YES	70	
4	0.85	120	102.0	21	7.40	10.38	YES	70	
5	0.94	120	112.8	20	7.54	11.83	YES	70	
6	0.96	120	115.2	19	7.39	11.99	YES	70	
7	0.94	120	112.8	20	7.58	12.00	YES	70	
8	0.91	120	109.2	20	7.61	12.10	YES	70	
9	POL	120	#####	POL	POL	#VALUE!	#VALUE!	70	
10	0.86	120	103.2	19	7.37	11.76	YES	70	
11	0.76	120	91.2	21	7.55	10.87	YES	70	
12	0.80	120	96.0	20	7.68	12.26	YES	70	
13	0.86	120	103.2	20	7.89	13.35	YES	70	
14	0.83	120	99.6	20	7.50	11.50	YES	70	
15	0.91	120	109.2	19	7.40	11.96	YES	70	
16	0.86	120	103.2	20	7.90	13.40	YES	70	
17	0.68	120	81.6	20	8.16	14.46	YES	70	
18	0.68	120	81.6	20	7.89	13.08	YES	70	
19	POL	120	#####	POL	POL	#VALUE!	#VALUE!	70	
20	0.94	120	112.8	20	7.49	11.61	YES	70	
21	0.74	120	88.8	18	7.20	11.64	YES	70	
22	0.84	120	100.8	16	7.17	13.32	YES	70	
23	0.74	120	88.8	16	7.17	13.17	YES	70	
24	0.87	120	104.4	18	7.38	12.64	YES	70	
25	0.85	120	102.0	18	7.36	12.52	YES	70	
26	0.47	120	56.4	19	7.73	12.86	YES	70	
27	0.57	120	68.4	20	7.83	12.63	YES	70	
28	0.57	120	68.4	18	7.29	11.81	YES	70	
29	0.56	120	67.2	17	7.32	12.76	YES	70	
30	0.57	120	68.4	17	7.80	15.27	YES	70	
31		120						70	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.