

OHA - Drinking Water Program -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Douglas

Month/Year: Mar-23

System Name:	PP&L Toketee Village		ID#: 41	01012			WTP: TP - Conventional
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	0.13	POL	POL	0.15
2	POL	POL	POL	POL	POL	0.13	0.13
3	POL	POL	POL	POL	POL	POL	0.00
4	POL	POL	0.08	0.07	POL	POL	0.08
5	POL	POL	POL	POL	0.07	POL	0.07
6	POL	POL	POL	POL	POL	POL	0.05
7	0.02	POL	POL	POL	POL	POL	0.02
8	POL	POL	0.04	0.07	POL	POL	0.09
9	POL	POL	POL	POL	POL	POL	0.07
10	POL	POL	POL	POL	0.12	0.00	0.12
11	POL	POL	POL	0.06	POL	POL	0.06
12	POL	POL	0.12	0.16	POL	POL	0.16
13	POL	POL	POL	POL	POL	0.19	0.19
14	POL	POL	POL	POL	POL	POL	0.00
15	POL	0.11	0.07	POL	POL	POL	0.11
16	POL	POL	POL	0.04	POL	POL	0.21
17	POL	POL	POL	0.15	POL	POL	0.25
18	POL	POL	0.15	POL	POL	POL	0.15
19	POL	POL	POL	POL	POL	POL	0.00
20	POL	POL	POL	0.04	POL	POL	0.04
21	POL	POL	POL	POL	POL	POL	0.00
22	POL	POL	POL	0.05	POL	POL	0.05
23	POL	POL	POL	POL	POL	POL	0.00
24	POL	POL	0.12	POL	POL	POL	0.12
25	POL	POL	POL	POL	POL	POL	0.00
26	POL	POL	POL	0.04	POL	POL	0.11
27	POL	POL	POL	0.04	0.04	POL	0.04
28	POL	POL	POL	POL	POL	POL	0.00
29	POL	POL	POL	0.05	0.03	POL	0.05
30	POL	POL	POL	POL	POL	POL	0.00
31	POL	POL	0.04	0.09	POL	POL	0.12

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> YES	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> YES		
All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> Yes / No		
Notes:	PRINTED NAME: Jonathan Woody	DATE: 4-8-23
	SIGNATURE: John Woody	CERT #: 7232
	PHONE #: (541) 643-6137	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: PP&L Toketee Village ID#: 41 01012 Month/Year: Mar-23 Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.74	120	88.8	4.0	7.53	33.8	Yes	70
2	0.74	120	88.8	4.0	7.54	33.9	Yes	70
3	0.69	120	82.8	4.0	7.48	33.0	Yes	70
4	0.69	120	82.8	4.0	7.56	34.0	Yes	70
5	0.83	120	99.6	6.0	7.84	33.3	Yes	70
6	0.95	120	114.0	4.0	7.75	37.5	Yes	70
7	1.02	120	122.4	4.0	7.54	35.0	Yes	70
8	1.03	120	123.6	4.0	7.61	36.0	Yes	70
9	1.06	120	127.2	4.0	7.59	35.9	Yes	70
10	1.05	120	126.0	4.0	7.51	34.8	Yes	70
11	1.05	120	126.0	4.0	7.56	35.4	Yes	70
12	0.69	120	82.8	6.0	7.25	26.5	Yes	70
13	0.72	120	86.4	4.0	7.56	34.1	Yes	70
14	1.04	120	124.8	4.0	7.49	34.5	Yes	70
15	0.98	120	117.6	4.0	7.58	35.4	Yes	70
16	1.03	120	123.6	4.0	7.50	34.6	Yes	70
17	1.03	120	123.6	4.0	7.56	35.3	Yes	70
18	1.03	120	123.6	7.0	7.53	28.5	Yes	70
19	0.98	120	117.6	7.0	7.69	30.0	Yes	70
20	0.91	120	109.2	5.0	7.61	33.1	Yes	70
21	1.02	120	122.4	5.0	7.71	34.8	Yes	70
22	1.03	120	123.6	6.0	7.24	27.5	Yes	70
23	0.75	120	90.0	5.0	7.54	31.7	Yes	70
24	0.69	120	82.8	6.0	7.28	26.8	Yes	70
25	1.01	120	121.2	5.0	7.58	33.2	Yes	70
26	0.92	120	110.4	6.0	7.38	28.5	Yes	70
27	0.94	120	112.8	6.0	7.71	32.2	Yes	70
28	1.06	120	127.2	4.0	7.47	34.3	Yes	70
29	0.47	120	56.4	5.0	7.13	26.5	Yes	70
30	0.75	120	90.0	5.0	7.66	33.1	Yes	70
31	0.71	120	85.2	5.0	7.79	34.6	Yes	70

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.