

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Apr-23

System Name:	PP&L Toketee Village		ID#: 41	01012		WTP : TP - Conventional	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	0.05	POL	POL	POL	0.08
2	0.03	POL	POL	POL	0.05	POL	0.05
3	POL	POL	0.03	0.03	POL	POL	0.03
4	POL	POL	POL	0.04	POL	POL	0.04
5	POL	POL	POL	0.05	POL	POL	0.05
6	POL	POL	POL	POL	POL	POL	0.00
7	POL	POL	POL	POL	POL	POL	0.09
8	0.03	POL	POL	0.04	POL	POL	0.04
9	POL	POL	POL	0.04	POL	POL	0.04
10	POL	POL	POL	0.03	POL	0.00	0.03
11	POL	POL	POL	POL	POL	POL	0.00
12	POL	POL	0.03	POL	POL	POL	0.05
13	POL	POL	POL	POL	POL	POL	0.05
14	0.03	POL	POL	POL	POL	POL	0.03
15	POL	POL	0.04	POL	POL	POL	0.04
16	POL	POL	0.05	POL	POL	POL	0.05
17	POL	POL	0.05	POL	POL	POL	0.05
18	POL	POL	0.04	POL	POL	POL	0.04
19	POL	POL	POL	0.05	POL	POL	0.05
20	POL	POL	0.03	0.03	POL	POL	0.03
21	POL	POL	POL	POL	POL	0.04	0.04
22	POL	POL	POL	0.07	0.04	POL	0.07
23	POL	POL	POL	POL	POL	POL	0.04
24	POL	POL	POL	POL	POL	0.05	0.05
25	POL	POL	POL	POL	POL	POL	0.00
26	POL	0.05	POL	POL	POL	POL	0.05
27	POL	POL	0.04	0.04	0.04	POL	0.04
28	POL	POL	POL	POL	0.03	POL	0.04
29	POL	POL	0.04	POL	POL	POL	0.04
30	POL	POL	POL	0.04	POL	POL	0.04
31	POL	POL	POL	POL	POL	POL	0.00

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> YES	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> YES		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / No		
Notes:	PRINTED NAME: Jonathan Woolly	DATE: 5-9-23
	SIGNATURE: John Woolly	CERT #: 7232
	PHONE #: (541) 643-6137	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: PP&L Toketee Village ID#: 41 01012 Month/Year: Apr-23 Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.99	120	118.8	7.0	7.36	26.7	Yes	70
2	0.96	120	115.2	7.0	7.43	27.3	Yes	70
3	1.17	120	140.4	5.0	7.80	36.6	Yes	70
4	1.05	120	126.0	5.0	7.56	33.1	Yes	70
5	1.09	120	130.8	5.0	7.70	35.0	Yes	70
6	1.09	120	130.8	5.0	7.58	33.5	Yes	70
7	0.79	120	94.8	5.0	7.51	31.5	Yes	70
8	0.84	120	100.8	6.0	7.78	32.7	Yes	70
9	0.74	120	88.8	6.0	7.77	32.2	Yes	70
10	0.75	120	90.0	6.0	7.62	30.5	Yes	70
11	0.93	120	111.6	7.0	7.83	31.4	Yes	70
12	0.97	120	116.4	6.0	7.90	34.6	Yes	70
13	0.62	120	74.4	6.0	7.95	33.9	Yes	70
14	0.5	120	60.0	6.0	7.96	33.5	Yes	70
15	0.86	120	103.2	7.0	7.76	30.4	Yes	70
16	0.88	120	105.6	7.0	7.83	31.2	Yes	70
17	0.88	120	105.6	7.0	7.79	30.8	Yes	70
18	0.83	120	99.6	7.0	7.86	31.4	Yes	70
19	0.57	120	68.4	7.0	7.92	31.1	Yes	70
20	0.65	120	78.0	7.0	7.89	31.1	Yes	70
21	0.59	120	70.8	6.0	7.98	34.1	Yes	70
22	0.53	120	63.6	7.0	7.74	29.0	Yes	70
23	0.56	120	67.2	6.0	7.76	31.4	Yes	70
24	0.88	120	105.6	9.0	7.67	25.7	Yes	70
25	0.58	120	69.6	8.0	7.78	27.7	Yes	70
26	0.72	120	86.4	9.0	7.93	27.7	Yes	70
27	0.63	120	75.6	9.0	7.56	24.1	Yes	70
28	0.64	120	76.8	10.0	7.76	24.2	Yes	70
29	0.87	120	104.4	11.0	7.89	24.3	Yes	70
30	0.87	120	104.4	11.0	7.82	23.7	Yes	70
31		120					Yes	70

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.