

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Jul-23

System Name:	PP&L Toketee Village		ID#: 41	01012	WTP : TP - Conventional		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.05	0.04	POL	POL	0.05	POL	0.05
2	POL	0.04	POL	0.04	POL	POL	0.04
3	POL	0.05	POL	POL	POL	POL	0.05
4	POL	0.04	POL	0.04	POL	POL	0.04
5	POL	0.04	POL	POL	POL	0.04	0.04
6	POL	POL	POL	POL	POL	POL	0.00
7	POL	POL	0.04	0.08	POL	POL	0.08
8	POL	POL	0.09	POL	POL	POL	0.09
9	0.10	0.09	POL	POL	POL	POL	0.10
10	POL	POL	0.04	POL	POL	0.04	0.05
11	POL	POL	0.04	POL	0.04	POL	0.04
12	0.04	0.04	POL	POL	POL	0.05	0.05
13	POL	POL	POL	0.04	POL	0.04	0.04
14	POL	POL	0.05	POL	0.07	POL	0.07
15	POL	0.04	POL	0.04	POL	POL	0.04
16	POL	0.04	POL	0.05	0.05	POL	0.05
17	POL	0.05	POL	POL	POL	0.04	0.05
18	0.05	0.04	POL	POL	0.05	POL	0.05
19	POL	0.05	POL	POL	POL	POL	0.05
20	0.05	0.04	POL	0.06	0.04	0.04	0.07
21	POL	0.04	POL	0.05	POL	POL	0.05
22	POL	0.05	POL	POL	0.05	POL	0.05
23	POL	0.05	POL	POL	POL	POL	0.05
24	0.05	0.04	POL	POL	0.05	POL	0.05
25	0.05	0.04	POL	0.05	0.04	POL	0.05
26	POL	0.04	POL	POL	0.06	POL	0.06
27	POL	0.05	POL	0.06	0.08	POL	0.08
28	POL	0.05	POL	POL	0.05	POL	0.05
29	POL	POL	0.05	POL	POL	POL	0.05
30	0.05	0.04	POL	POL	0.05	POL	0.05
31	POL	0.05	POL	POL	0.06	0.05	0.06

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> YES	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> YES		
All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> Yes / No		
Notes:	PRINTED NAME: Jonathan Woody	DATE: 8-8-23
	SIGNATURE: <i>Jonathan Woody</i>	CERT #: 7232
	PHONE #: (541) 643-6137	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County : Month/Year :		Douglas July / 2023		WTP - :	WTP-A
								Disinfection <i>Giardia</i> Log	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM	
1	0.62	120	74.4	16	7.64	15.47	YES	70	
2	0.74	120	88.8	18	7.72	14.13	YES	70	
3	0.72	120	86.4	18	7.90	15.08	YES	70	
4	0.80	120	96.0	18	7.63	13.76	YES	70	
5	0.46	120	55.2	20	7.85	12.57	YES	70	
6	0.56	120	67.2	19	7.62	12.48	YES	70	
7	0.50	120	60.0	20	7.78	12.30	YES	70	
8	0.51	120	61.2	20	7.72	12.04	YES	70	
9	0.54	120	64.8	20	7.32	10.40	YES	70	
10	0.42	120	50.4	19	7.73	12.79	YES	70	
11	0.71	120	85.2	19	7.75	13.32	YES	70	
12	0.84	120	100.8	18	7.88	15.17	YES	70	
13	0.84	120	100.8	20	7.65	12.18	YES	70	
14	0.68	120	81.6	23	7.95	10.93	YES	70	
15	0.76	120	91.2	22	7.60	10.35	YES	70	
16	0.88	120	105.6	20	7.62	12.10	YES	70	
17	0.75	120	90.0	22	7.67	10.62	YES	70	
18	0.69	120	82.8	22	7.64	10.42	YES	70	
19	0.75	120	90.0	22	7.68	10.66	YES	70	
20	0.85	120	102.0	19	7.69	13.24	YES	70	
21	0.84	120	100.8	20	7.76	12.69	YES	70	
22	0.58	120	69.6	19	7.88	13.77	YES	70	
23	0.77	120	92.4	20	7.57	11.73	YES	70	
24	0.80	120	96.0	20	7.39	11.00	YES	70	
25	0.96	120	115.2	25	7.92	9.75	YES	70	
26	0.95	120	114.0	19	7.58	12.85	YES	70	
27	0.99	120	118.8	18	7.42	13.01	YES	70	
28	0.71	120	85.2	19	7.93	14.24	YES	70	
29	0.69	120	82.8	18	6.68	9.53	YES	70	
30	0.66	120	79.2	18	7.74	14.11	YES	70	
31	0.65	120	78.0	24	8.08	10.69	YES	70	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.