

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Jul-24

System Name: PP&L Toketes Village ID#: 41 01012 WTP: TP - Conventional

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	0.05	POL	POL	POL	0.05
2	0.04	POL	0.04	POL	0.04	POL	0.10
3	POL	0.04	POL	POL	POL	POL	0.04
4	0.05	0.04	POL	0.04	POL	POL	0.05
5	0.05	0.04	POL	0.05	0.04	POL	0.05
6	0.04	POL	POL	0.04	0.04	POL	0.04
7	POL	0.05	POL	POL	POL	0.04	0.06
8	POL	0.04	0.04	POL	0.05	POL	0.05
9	POL	0.05	POL	0.05	POL	POL	0.09
10	0.04	0.04	POL	POL	POL	0.05	0.05
11	0.04	POL	0.04	POL	POL	POL	0.04
12	0.05	POL	POL	0.04	0.04	POL	0.05
13	0.05	POL	POL	0.04	0.04	POL	0.05
14	POL	POL	0.05	POL	POL	POL	0.05
15	POL	0.04	0.04	0.05	POL	0.05	0.08
16	0.07	0.07	0.15	0.11	0.04	0.04	0.28
17	POL	POL	POL	0.05	0.04	POL	0.05
18	POL	POL	POL	0.05	0.04	POL	0.05
19	POL	POL	POL	0.04	POL	POL	0.05
20	POL	0.04	0.04	0.04	POL	0.04	0.06
21	POL	POL	0.05	POL	POL	POL	0.05
22	0.05	0.04	POL	0.05	0.05	POL	0.08
23	POL	0.04	POL	POL	POL	0.04	0.06
24	POL	0.05	0.04	POL	POL	POL	0.05
25	0.05	0.04	POL	0.04	POL	POL	0.05
26	0.05	0.04	POL	POL	0.04	POL	0.05
27	POL	POL	0.05	POL	POL	POL	0.06
28	0.06	POL	POL	POL	0.06	0.04	0.06
29	0.05	0.04	0.04	POL	0.05	0.04	0.05
30	0.05	0.04	0.04	0.08	0.04	POL	0.08
31	0.05	0.04	POL	POL	0.04	0.05	0.05

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> YES	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> YES		
All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> Yes / No		

Notes:

PRINTED NAME: Jonathan Woody
 SIGNATURE: *Jonathan Woody*
 PHONE #: (541) 643-6137
 DATE: 8-6-24
 CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County : Month/Year :	Douglas July / 2024		WTP - : Disinfection <i>Giardia</i> Log	WTP-A 0.5
	Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM
1	0.44	120	52.8	18	8.03	15.32	YES	70
2	0.52	120	62.4	20	7.86	12.70	YES	70
3	0.52	120	62.4	18	7.88	14.63	YES	70
4	0.47	120	56.4	17	7.93	15.84	YES	70
5	0.48	120	57.6	17	7.96	16.03	YES	70
6	0.51	120	61.2	17	7.92	15.85	YES	70
7	0.47	120	56.4	17	7.95	15.96	YES	70
8	0.44	120	52.8	18	7.91	14.66	YES	70
9	0.41	120	49.2	16	7.82	16.14	YES	70
10	0.43	120	51.6	18	7.93	14.75	YES	70
11	0.35	120	42.0	19	7.90	13.52	YES	70
12	0.42	120	50.4	18	7.96	14.90	YES	70
13	0.42	120	50.4	18	7.84	14.25	YES	70
14	0.42	120	50.4	18	7.95	14.84	YES	70
15	0.48	120	57.6	18	8.19	16.33	YES	70
16	1.03	120	123.6	18	7.89	15.56	YES	70
17	0.46	120	55.2	20	7.62	11.53	YES	70
18	0.41	120	49.2	20	7.80	12.26	YES	70
19	0.63	120	75.6	20	7.80	12.58	YES	70
20	0.71	120	85.2	20	7.82	12.79	YES	70
21	0.71	120	85.2	20	7.86	12.98	YES	70
22	0.51	120	61.2	25	7.72	8.59	YES	70
23	0.55	120	66.0	18	7.69	13.68	YES	70
24	0.48	120	57.6	18	7.70	13.62	YES	70
25	0.56	120	67.2	18	7.75	14.00	YES	70
26	0.72	120	86.4	18	7.77	14.37	YES	70
27	0.53	120	63.6	18	7.82	14.32	YES	70
28	0.64	120	76.8	21	7.72	11.43	YES	70
29	0.65	120	78.0	18	7.72	13.99	YES	70
30	0.80	120	96.0	19	7.74	13.41	YES	70
31	0.75	120	90.0	17	7.75	15.30	YES	70

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.