

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Jan-25

System Name: PP&L Toketee Village ID#: 41 01012 WTP: TP - Conventional

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	0.06	0.05	POL	0.10
2	POL	POL	POL	POL	POL	0.04	0.04
3	0.03	POL	POL	POL	POL	POL	0.00
4	POL	POL	0.08	0.03	POL	POL	0.08
5	POL	POL	0.07	POL	POL	POL	0.07
6	POL	POL	POL	POL	POL	0.07	0.07
7	0.06	POL	POL	POL	POL	POL	0.00
8	POL	POL	POL	0.03	POL	POL	0.04
9	POL	POL	POL	0.05	POL	POL	0.05
10	POL	POL	0.03	POL	POL	0.00	0.05
11	POL	POL	POL	POL	POL	0.04	0.04
12	0.03	POL	POL	POL	POL	POL	0.00
13	POL	POL	0.04	POL	POL	POL	0.04
14	POL	POL	POL	POL	POL	POL	0.05
15	0.05	POL	POL	POL	POL	0.05	0.05
16	0.03	POL	0.03	0.03	POL	0.03	0.04
17	POL	POL	0.03	POL	0.06	POL	0.09
18	POL	POL	POL	POL	POL	POL	0.00
19	POL	POL	0.04	POL	POL	POL	0.04
20	POL	POL	POL	POL	POL	POL	0.00
21	0.04	POL	POL	POL	POL	POL	0.04
22	POL	POL	POL	0.03	POL	POL	0.04
23	POL	POL	POL	0.03	POL	POL	0.03
24	POL	POL	POL	POL	POL	POL	0.00
25	POL	0.03	POL	POL	POL	POL	0.10
26	POL	POL	POL	0.04	0.03	POL	0.04
27	POL	POL	POL	POL	POL	POL	0.00
28	POL	0.07	0.03	POL	POL	POL	0.07
29	POL	POL	POL	POL	POL	0.04	0.04
30	POL	POL	POL	POL	POL	POL	0.00
31	POL	POL	POL	0.04	POL	POL	0.04

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? YES	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? YES		
All turbidity readings < IFE ² triggers Yes / No		

Notes:	PRINTED NAME: Jonathan Woody
	SIGNATURE: <i>John Woody</i> DATE: 2-9-25
	PHONE #: (541) 643-6137 CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	PP&L Toketee Village		ID#: 4101012	County :	Douglas		WTP - :	WTP-A
				Month/Year :	January / 2025		Disinfection Giardia Log	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	ppm or mg/L	minutes	C X T	° C		formula	Yes / No	GPM
1	0.36	120	43.2	12	7.47	18.57	YES	70
2	0.41	120	49.2	9	7.37	21.94	YES	70
3	0.43	120	51.6	9	7.26	21.16	YES	70
4	0.52	120	62.4	5	7.46	29.99	YES	70
5	0.49	120	58.8	6	7.46	27.93	YES	70
6	0.55	120	66.0	7	7.47	26.39	YES	70
7	0.47	120	56.4	6	7.51	28.37	YES	70
8	0.55	120	66.0	6	7.57	29.26	YES	70
9	0.47	120	56.4	9	7.55	23.54	YES	70
10	0.55	120	66.0	9	7.68	24.88	YES	70
11	0.56	120	67.2	10	7.58	22.49	YES	70
12	0.72	120	86.4	10	7.65	23.48	YES	70
13	0.54	120	64.8	11	7.57	20.94	YES	70
14	0.58	120	69.6	6	7.59	29.57	YES	70
15	0.62	120	74.4	5	7.54	31.23	YES	70
16	0.55	120	66.0	10	7.54	22.15	YES	70
17	0.70	120	84.0	6	7.71	31.32	YES	70
18	0.70	120	84.0	6	7.68	30.98	YES	70
19	0.68	120	81.6	6	7.58	29.81	YES	70
20	0.61	120	73.2	5	7.62	32.11	YES	70
21	0.66	120	79.2	5	7.72	33.50	YES	70
22	0.58	120	69.6	9	7.64	24.61	YES	70
23	0.71	120	85.2	8	7.44	24.87	YES	70
24	0.71	120	85.2	7	7.54	27.56	YES	70
25	0.50	120	60.0	8	7.59	25.61	YES	70
26	0.69	120	82.8	9	7.63	24.83	YES	70
27	0.76	120	91.2	4	7.59	34.61	YES	70
28	0.77	120	92.4	7	7.63	28.67	YES	70
29	0.71	120	85.2	8	7.61	26.42	YES	70
30	0.76	120	91.2	7	7.68	29.15	YES	70
31	0.78	120	93.6	7	7.65	28.91	YES	70

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.