

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: Oct-22

System Name:	City of Gold Beach		ID#: 4101059	WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	off	off	off	0.01	0.01	0.04	0.05
2	off	off	off	0.02	0.01	0.02	0.04
3	0.01	off	off	off	0.02	0.01	0.04
4	0.02	off	off	0.02	0.01	0.03	0.04
5	0.01	off	off	0.02	0.02	0.02	0.04
6	0.04	off	off	0.02	0.02	0.02	0.04
7	off	off	off	0.02	0.02	0.06	0.07
8	0.01	off	off	0.02	0.02	0.02	0.06
9	0.04	off	off	0.02	0.04	0.04	0.04
10	off	off	off	0.02	0.02	0.02	0.03
11	off	off	off	0.02	0.02	0.04	0.04
12	0.02	off	off	0.01	0.01	0.01	0.04
13	0.01	0.01	0.01	0.09	0.02	0.09	0.09
14	0.05	0.02	0.02	0.02	0.03	0.02	0.05
15	0.02	0.02	0.02	0.02	0.08	0.08	0.08
16	0.02	0.02	0.02	0.06	0.02	0.02	0.08
17	0.02	0.02	0.02	0.02	0.04	0.02	0.09
18	off	off	off	0.02	0.02	0.03	0.12
19	off	off	off	0.03	0.02	0.03	0.07
20	off	off	off	0.03	0.02	0.07	0.07
21	off	off	off	0.02	0.02	off	0.03
22	off	off	0.03	0.02	0.03	0.02	0.06
23	off	off	off	0.02	0.02	0.02	0.06
24	off	off	off	0.02	0.04	0.02	0.09
25	off	off	off	0.02	0.02	0.06	0.07
26	off	off	off	0.03	off	off	0.07
27	off	off	off	0.05	0.02	0.02	0.05
28	off	off	off	0.04	0.04	off	0.04
29	off	off	off	0.02	0.02	off	0.03
30	off	off	off	0.04	0.02	0.02	0.04
31	off	off	off	0.02	0.02	0.02	0.03

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All 4-hour turbidity readings ≤ 1 NTU? <b>Yes</b>		
All turbidity readings < IFE <sup>2</sup> triggers <b>Yes</b>		

<b>Notes:</b>	<b>PRINTED NAME: Will Newdall</b>	
	<b>SIGNATURE:</b>	<b>11/7/2022</b>
	<b>PHONE #: (541 )247-7459</b>	<b>CERT #:FE0054</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	--	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.87	60	52.2	20.1	7.26	10.5	YES	700
2	0.85	60	51.0	20.9	7.29	10.0	YES	700
3	0.93	60	55.8	20.6	7.22	10.1	YES	700
4	0.85	60	51.0	20.4	7.22	10.1	YES	700
5	0.87	60	52.2	19.8	7.21	10.5	YES	700
6	0.94	60	56.4	20.2	7.18	10.2	YES	700
7	0.84	60	50.4	19.8	7.22	10.5	YES	700
8	0.85	60	51.0	20.4	7.29	10.4	YES	700
9	0.83	60	49.8	19.9	7.19	10.3	YES	700
10	0.81	60	48.6	19.6	7.21	10.6	YES	700
11	0.85	60	51.0	19.9	7.12	10.1	YES	700
12	0.82	60	49.2	19.9	7.18	10.3	YES	700
13	0.78	60	46.8	18.9	7.23	11.1	YES	700
14	0.8	60	48.0	19.5	7.35	11.2	YES	700
15	0.77	60	46.2	19.5	7.32	11.0	YES	700
16	0.76	60	45.6	18.9	7.35	11.6	YES	700
17	0.89	60	53.4	19.1	7.23	11.1	YES	700
18	0.81	60	48.6	19.0	7.34	11.6	YES	700
19	0.87	60	52.2	19.3	7.36	11.5	YES	700
20	0.86	60	51.6	19.2	7.34	11.5	YES	700
21	0.89	60	53.4	18.8	7.25	11.4	YES	700
22	0.84	60	50.4	18.6	7.31	11.8	YES	700
23	0.82	60	49.2	18.4	7.21	11.5	YES	700
24	0.88	60	52.8	19.0	7.25	11.3	YES	700
25	0.88	60	52.8	18.8	7.25	11.4	YES	700
26	0.91	60	54.6	18.7	7.35	12.0	YES	700
27	0.91	60	54.6	17.6	7.17	12.1	YES	700
28	0.92	60	55.2	18.2	7.32	12.3	YES	700
29	0.95	60	57.0	18.6	7.24	11.6	YES	700
30	0.9	60	54.0	18.1	7.28	12.1	YES	700
31	0.81	60	48.6	17.4	7.28	12.6	YES	700

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

### Water Production Record for The City of Gold Beach

October 2022		Chlorine Residual	
Date	Gallons Pumped	Location 1 Residual	Location 2 Residual
1	529,000	City Hall	HC or Wedd
2	454,000	City Hall	HC or Wedd
3	561,000	City Hall	.64 HC or Wedd
4	581,000	City Hall	.61 HC or Wedd
5	390,000	City Hall	.76 HC or Wedd
6	548,000	City Hall	.75 HC or Wedd
7	554,000	City Hall	.60 HC or Wedd
8	458,000	City Hall	HC or Wedd
9	516,000	City Hall	HC or Wedd
10	509,000	City Hall	.73 HC or Wedd
11	511,000	City Hall	.59 HC or Wedd
12	645,000	City Hall	.67 HC or Wedd
13	637,000	City Hall	.60 HC or Wedd
14	553,000	City Hall	.66 HC or Wedd
15	738,000	City Hall	HC or Wedd
16	484,000	City Hall	HC or Wedd
17	487,000	City Hall	.57 HC or Wedd
18	493,000	City Hall	.63 HC or Wedd
19	577,000	City Hall	.59 HC or Wedd
20	483,000	City Hall	.53 HC or Wedd
21	569,000	City Hall	.59 HC or Wedd
22	<del>480,000</del>	City Hall	HC or Wedd
23	498,000	City Hall	HC or Wedd
24	547,000	City Hall	.49 HC or Wedd
25	471,000	City Hall	HC or Wedd
26	428,000	City Hall	.71 HC or Wedd
27	602,000	City Hall	.91 HC or Wedd
28	379,000	City Hall	.85 HC or Wedd
29	427,000	City Hall	HC or Wedd
30	444,000	City Hall	HC or Wedd
31	393,000	City Hall	.64 HC or Wedd