

**OHA - Drinking Water Services -Turbidity Monitoring Report Form**

**Conventional or Direct Filtration**

County: **Curry**  
 Month/Year: **Apr-23**

System Name:		City of Gold Beach		ID#: 4101059		WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	off	off	0.04	0.05	0.06	off	0.09
2	off	off	0.04	0.04	0.05	off	0.06
3	off	off	0.04	0.06	0.07	0.05	0.08
4	off	off	0.04	0.05	off	off	0.07
5	off	off	0.05	0.05	off	off	0.07
6	off	off	0.05	0.06	off	off	0.08
7	off	off	0.04	0.05	off	off	0.06
8	off	off	0.05	0.06	0.05	off	0.06
9	off	off	0.04	0.05	off	off	0.06
10	off	off	0.04	0.07	0.04	off	0.07
11	off	off	0.04	0.05	0.06	off	0.07
12	off	off	off	0.05	0.05	off	0.12
13	off	off	0.07	0.06	0.04	off	0.09
14	off	off	0.04	0.04	0.05	off	0.07
15	off	off	0.05	0.06	0.04	off	0.08
16	off	off	off	0.05	0.06	off	0.07
17	off	off	0.06	0.04	0.04	off	0.07
18	off	off	off	0.05	0.06	0.04	0.08
19	0.04	off	0.04	0.04	0.04	off	0.06
20	off	off	0.07	0.04	off	off	0.07
21	off	off	0.04	0.04	off	off	0.06
22	off	0.05	0.08	0.04	off	off	0.08
23	off	off	0.05	0.05	off	off	0.06
24	off	off	0.04	0.04	0.04	off	0.10
25	off	off	0.06	0.07	0.04	off	0.07
26	off	off	0.09	0.05	off	off	0.09
27	off	off	0.04	0.07	off	off	0.07
28	off	off	0.04	0.04	0.04	off	0.04
29	off	off	0.04	0.04	0.04	off	0.06
30	off	off	0.04	0.04	0.05	0.05	0.05
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<b>Yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>
All turbidity readings < IFE <sup>2</sup> triggers	<b>Yes</b>		

<b>Notes:</b>	<b>PRINTED NAME: Will Newdall</b>	
	<b>SIGNATURE:</b>	<b>DATE: 5-5-23</b>
	<b>PHONE #: (541) 247-7459</b>	<b>CERT #: FE0054</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	Apr-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.95	60	57.0	9.7	7.15	20.6	YES	700
2	0.91	60	54.6	10.4	7.34	20.9	YES	700
3	0.97	60	58.2	11.3	7.08	18.2	YES	700
4	1.06	60	63.6	12.2	7.00	16.9	YES	700
5	0.8	60	48.0	11.7	7.11	17.6	YES	700
6	0.99	60	59.4	12.9	7.02	15.8	YES	700
7	0.94	60	56.4	11.7	7.01	17.2	YES	700
8	0.92	60	55.2	12.8	7.10	16.2	YES	700
9	0.82	60	49.2	13.0	6.99	15.2	YES	700
10	0.97	60	58.2	14.2	7.05	14.6	YES	700
11	0.93	60	55.8	13.6	7.04	15.1	YES	700
12	1.16	60	69.6	15.0	7.13	14.6	YES	700
13	1.06	60	63.6	13.3	7.13	16.1	YES	700
14	0.97	60	58.2	14.9	6.96	13.5	YES	700
15	0.95	60	57.0	14.2	6.94	14.0	YES	700
16	0.92	60	55.2	15.2	7.02	13.4	YES	700
17	0.94	60	56.4	14.6	7.04	14.1	YES	700
18	1.02	60	61.2	14.7	7.05	14.2	YES	700
19	1.07	60	64.2	14.4	7.08	14.7	YES	700
20	0.97	60	58.2	14.0	7.03	14.7	YES	700
21	0.92	60	55.2	11.9	7.28	18.6	YES	700
22	0.98	60	58.8	13.1	7.01	15.5	YES	700
23	0.95	60	57.0	13.5	7.00	15.0	YES	700
24	0.76	60	45.6	12.7	7.03	15.6	YES	700
25	0.94	60	56.4	10.1	7.09	19.6	YES	700
26	0.94	60	56.4	10.6	7.10	19.1	YES	700
27	0.94	60	56.4	10.5	7.04	18.8	YES	700
28	0.83	60	49.8	11.7	7.05	17.3	YES	700
29	0.85	60	51.0	13.2	7.06	15.4	YES	700
30	0.81	60	48.6	13.9	7.05	14.6	YES	700
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

### Water Production Record for The City of Gold Beach

April 2023		Chlorine Residual			
Date	Gallons Pumped	Location 1	Residual	Location 2	Residual
1	410,000	City Hall	X	HC or Wedd	X
2	420,000	City Hall	X	HC or Wedd	X
3	426,000	City Hall	.88	HC or Wedd	
4	620,000	City Hall	.89	HC or Wedd	
5	353,000	City Hall	.67	HC or Wedd	
6	451,000	City Hall	.77	HC or Wedd	
7	470,000	City Hall	X	HC or Wedd	X
8	427,000	City Hall	X	HC or Wedd	X
9	336,000	City Hall	X	HC or Wedd	X
10	370,000	City Hall	.67	HC or Wedd	
11	423,000	City Hall	.65	HC or Wedd	
12	395,000	City Hall	.77	HC or Wedd	
13	471,000	City Hall	.63	HC or Wedd	
14	361,000	City Hall	X	HC or Wedd	
15	325,000	City Hall	X	HC or Wedd	
16	423,000	City Hall	X	HC or Wedd	
17	354,000	City Hall	.76	HC or Wedd	
18	382,000	City Hall	.69	HC or Wedd	
19	654,000	City Hall	.74	HC or Wedd	
20	436,000	City Hall	.67	HC or Wedd	
21	206,000	City Hall		HC or Wedd	
22	433,000	City Hall		HC or Wedd	
23	364,000	City Hall		HC or Wedd	
24	359,000	City Hall	.74	HC or Wedd	
25	466,000	City Hall	.66	HC or Wedd	
26	376,000	City Hall	.70	HC or Wedd	
27	412,000	City Hall	.79	HC or Wedd	
28	454,000	City Hall		HC or Wedd	
29	419,000	City Hall		HC or Wedd	
30	394,000	City Hall		HC or Wedd	
31		City Hall		HC or Wedd	