

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: Jun-24

System Name:	City of Gold Beach		ID#: 4101059				WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	0.03	0.02	0.02	OFF	0.06	
2	OFF	OFF	0.02	0.02	OFF	0.04	0.07	
3	0.02	OFF	0.02	0.02	0.02	OFF	0.03	
4	0.02	0.02	OFF	0.02	0.02	OFF	0.06	
5	OFF	0.02	0.02	0.02	0.02	OFF	0.19	
6	OFF	0.02	0.02	0.02	0.02	OFF	0.25	
7	OFF	OFF	0.02	OFF	0.02	OFF	0.08	
8	0.02	OFF	0.02	0.02	0.02	OFF	0.23	
9	0.02	OFF	0.02	0.02	0.02	OFF	0.11	
10	0.02	0.02	0.02	OFF	OFF	0.02	0.05	
11	0.02	0.02	0.02	OFF	OFF	0.02	0.11	
12	0.02	OFF	0.02	0.04	0.04	0.02	0.37	
13	0.02	OFF	0.03	0.02	0.02	0.02	0.14	
14	OFF	0.02	0.02	0.02	OFF	0.02	0.04	
15	OFF	OFF	0.02	0.03	0.02	0.03	0.07	
16	OFF	OFF	0.02	0.02	OFF	0.02	0.02	
17	OFF	OFF	0.02	0.02	OFF	0.02	0.06	
18	OFF	OFF	0.02	0.02	0.02	0.02	0.05	
19	OFF	OFF	0.02	0.02	0.02	0.02	0.04	
20	OFF	OFF	0.02	0.02	0.02	0.02	0.04	
21	OFF	OFF	0.02	0.02	0.02	0.02	0.04	
22	OFF	0.02	0.02	0.02	0.02	0.02	0.07	
23	OFF	OFF	0.02	0.02	0.02	0.06	0.06	
24	OFF	OFF	0.02	0.02	0.02	0.02	0.02	
25	0.02	OFF	0.02	0.02	0.02	0.02	0.02	
26	OFF	OFF	0.02	0.02	0.02	OFF	0.06	
27	0.02	OFF	0.02	0.02	0.02	0.02	0.05	
28	OFF	OFF	0.00	0.02	0.02	0.02	0.03	
29	0.02	OFF	0.02	0.02	0.02	0.02	0.03	
30	0.02	OFF	0.02	0.02	0.02	0.02	0.03	
31								

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes		CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes		Yes	Yes
All turbidity readings < IFE ² triggers	Yes			

Notes:	PRINTED NAME: Will Newdall	
	SIGNATURE:	6/1/2024
	PHONE #: (541)247-7459	CERT #:FE0054

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	Jun-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.88	60	52.8	19.9	6.99	9.6	YES	700
2	1	60	60.0	20.0	6.93	9.5	YES	700
3	0.99	60	59.4	17.1	6.95	11.6	YES	700
4	0.99	60	59.4	18.1	6.92	10.7	YES	700
5	0.99	60	59.4	18.0	7.04	11.3	YES	700
6	0.98	60	58.8	17.3	7.02	11.7	YES	700
7	0.92	60	55.2	20.6	6.96	9.1	YES	700
8	0.97	60	58.2	19.9	6.99	9.7	YES	700
9	0.82	60	49.2	20.0	7.02	9.6	YES	700
10	0.95	60	57.0	18.0	7.02	11.2	YES	700
11	0.93	60	55.8	18.1	6.98	10.9	YES	700
12	0.95	60	57.0	18.4	6.92	10.5	YES	700
13	0.92	60	55.2	19.3	7.04	10.3	YES	700
14	0.9	60	54.0	20.1	7.01	9.6	YES	700
15	0.91	60	54.6	18.5	7.03	10.8	YES	700
16	0.88	60	52.8	18.8	7.05	10.6	YES	700
17	0.93	60	55.8	19.1	7.02	10.3	YES	700
18	0.95	60	57.0	16.1	7.06	12.9	YES	700
19	1	60	60.0	17.1	7.01	11.9	YES	700
20	1.01	60	60.6	19.5	7.02	10.1	YES	700
21	1.03	60	61.8	20.2	7.01	9.7	YES	700
22	0.93	60	55.8	21.8	7.06	8.7	YES	700
23	0.95	60	57.0	21.5	7.05	8.9	YES	700
24	0.99	60	59.4	19.3	6.94	10.0	YES	700
25	1	60	60.0	18.2	7.00	11.0	YES	700
26	0.83	60	49.8	18.7	6.96	10.3	YES	700
27	0.89	60	53.4	17.9	7.03	11.2	YES	700
28	1	60	60.0	18.1	7.02	11.1	YES	700
29	0.97	60	58.2	20.2	7.00	9.6	YES	700
30	0.99	60	59.4	21.1	7.02	9.1	YES	700
31							NO	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Water Production Record for The City of Gold Beach

Date	Gallons Pumped	Chlorine Residual	
		Location 1 Residual	Location 2 Residual
1	573,000	City Hall	HC or Wedd
2	588,000	City Hall	HC or Wedd
3	461,000	City Hall	.55 HC or Wedd
4	506,000	City Hall	.38 HC or Wedd
5	620,000	City Hall	.42 HC or Wedd
6	574,000	City Hall	.46 HC or Wedd
7	651,000	City Hall	HC or Wedd
8	515,800	City Hall	HC or Wedd
9	546,000	City Hall	HC or Wedd
10	573,000	City Hall	.61 HC or Wedd
11	723,000	City Hall	.84 HC or Wedd
12	487,000	City Hall	.76 HC or Wedd
13	588,000	City Hall	.84 HC or Wedd
14	677,000	City Hall	HC or Wedd
15	495,000	City Hall	HC or Wedd
16	555,000	City Hall	HC or Wedd
17	579,000	City Hall	.63 HC or Wedd
18	543,000	City Hall	.74 HC or Wedd
19	586,000	City Hall	.54 HC or Wedd
20	723,000	City Hall	.60 HC or Wedd
21	603,000	City Hall	HC or Wedd
22	689,000	City Hall	HC or Wedd
23	577,000	City Hall	HC or Wedd
24	648,000	City Hall	.68 HC or Wedd
25	688,000	City Hall	.84 HC or Wedd
26	704,000	City Hall	.40 HC or Wedd
27	415,000	City Hall	.69 HC or Wedd
28	569,000	City Hall	HC or Wedd
29	816,000	City Hall	HC or Wedd
30	750,000	City Hall	HC or Wedd
31		City Hall	HC or Wedd