

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: Jul-24

System Name:		City of Gold Beach		ID#: 4101059		WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.02	OFF	0.02	0.02	0.02	0.02	0.04
2	0.02	OFF	0.02	0.02	0.02	0.02	0.35
3	0.01	OFF	0.01	0.02	0.02	0.02	0.02
4	0.01	OFF	0.02	0.02	0.02	0.01	0.05
5	0.02	0.02	0.02	0.02	0.01	0.02	0.05
6	0.02	OFF	0.02	0.02	0.02	0.01	0.04
7	0.01	OFF	0.02	0.02	0.01	0.01	0.16
8	0.02	OFF	0.02	0.02	0.02	0.02	0.05
9	0.02	0.02	0.02	0.02	0.02	0.02	0.08
10	0.02	OFF	0.02	0.02	0.02	0.02	0.08
11	0.02	0.02	0.02	0.02	0.02	0.02	0.06
12	0.02	OFF	0.02	0.02	0.02	0.02	0.05
13	0.02	0.02	OFF	0.02	0.02	0.02	0.07
14	0.02	OFF	0.02	0.02	0.02	0.02	0.07
15	0.02	OFF	0.02	0.02	0.02	0.02	0.06
16	0.02	OFF	0.05	0.02	0.02	0.02	0.08
17	0.02	OFF	0.02	0.02	0.01	0.01	0.06
18	0.02	0.02	0.02	0.02	0.02	0.02	0.08
19	0.02	0.02	0.02	OFF	0.02	0.02	0.07
20	0.02	0.02	0.03	0.02	0.02	0.02	0.08
21	0.02	OFF	0.02	0.02	0.02	0.02	0.08
22	0.02	OFF	0.02	0.02	0.02	0.01	0.08
23	0.01	OFF	0.04	0.02	0.01	0.01	0.06
24	0.01	0.02	0.01	0.01	0.01	0.01	0.08
25	0.02	0.01	0.01	0.01	0.02	0.02	0.04
26	0.01	OFF	0.01	0.02	0.01	0.01	0.08
27	0.01	OFF	0.01	0.01	0.01	0.01	0.06
28	0.02	OFF	0.01	0.01	0.05	0.01	0.08
29	0.01	OFF	0.01	0.02	0.01	0.01	0.08
30	0.01	0.01	0.01	0.01	0.01	0.01	0.07
31	0.02	OFF	0.01	0.01	0.01	0.01	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE <sup>2</sup> triggers	Yes		

Notes:	PRINTED NAME: Will Newdall	
	SIGNATURE:	7/1/2024
	PHONE #: (541 )247-7459	CERT #:FE0054

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	Jul-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.97	60	58.2	21.0	6.93	8.8	YES	700
2	1.01	60	60.6	19.0	7.05	10.6	YES	700
3	0.97	60	58.2	23.9	6.93	7.2	YES	700
4	0.98	60	58.8	20.7	7.02	9.3	YES	700
5	0.98	60	58.8	20.2	6.89	9.2	YES	700
6	0.98	60	58.8	20.9	7.03	9.2	YES	700
7	0.98	60	58.8	25.7	7.00	6.6	YES	700
8	0.98	60	58.8	22.3	6.88	7.9	YES	700
9	0.92	60	55.2	19.5	7.02	10.0	YES	700
10	0.88	60	52.8	21.9	6.97	8.3	YES	700
11	0.9	60	54.0	27.6	7.01	5.7	YES	700
12	0.88	60	52.8	21.5	6.92	8.4	YES	700
13	0.9	60	54.0	24.2	7.05	7.4	YES	700
14	0.88	60	52.8	22.0	7.10	8.7	YES	700
15	0.88	60	52.8	21.7	6.98	8.5	YES	700
16	0.87	60	52.2	20.7	6.93	8.9	YES	700
17	0.87	60	52.2	21.5	6.96	8.5	YES	700
18	0.87	60	52.2	21.3	6.96	8.6	YES	700
19	0.99	60	59.4	20.7	6.93	9.0	YES	700
20	0.92	60	55.2	20.4	6.92	9.1	YES	700
21	1.02	60	61.2	20.2	6.98	9.5	YES	700
22	1.08	60	64.8	22.8	6.89	7.8	YES	700
23	1.07	60	64.2	25.0	6.89	6.7	YES	700
24	0.92	60	55.2	21.2	6.92	8.6	YES	700
25	1.01	60	60.6	20.1	7.02	9.7	YES	700
26	0.96	60	57.6	21.0	7.01	9.1	YES	700
27	1	60	60.0	24.9	7.06	7.1	YES	700
28	0.99	60	59.4	23.3	6.94	7.6	YES	700
29	1.01	60	60.6	21.4	7.03	9.0	YES	700
30	0.94	60	56.4	22.3	6.92	8.0	YES	700
31	0.98	60	58.8	21.2	6.99	8.9	YES	700

<sup>3</sup> If Cl<sub>2</sub> at entry poin

Revised September 2016

### Water Production Record for The City of Gold Beach

		Chlorine Residual		July 2024	
Date	Gallons Pumped	Location 1	Residual	Location 2	Residual
1	701,000	City Hall	.80	HC or Wedd	
2	795,000	City Hall	.84	HC or Wedd	
3	756,000	City Hall	.80	HC or Wedd	
4	826,000	City Hall		HC or Wedd	
5	877,000	City Hall		HC or Wedd	
6	808,000	City Hall		HC or Wedd	
7	834,000	City Hall		HC or Wedd	
8	796,000	City Hall	.74	HC or Wedd	
9	922,000	City Hall	.72	HC or Wedd	
10	756,000	City Hall	.69	HC or Wedd	
11	946,000	City Hall	.75	HC or Wedd	
12	763,000	City Hall		HC or Wedd	
13	831,000	City Hall		HC or Wedd	
14	709,000	City Hall		HC or Wedd	
15	719,000	City Hall	.69	HC or Wedd	
16	796,000	City Hall	.62	HC or Wedd	
17	754,000	City Hall	.70	HC or Wedd	
18	906,000	City Hall	.61	HC or Wedd	
19	970,000	City Hall		HC or Wedd	
20	799,000	City Hall		HC or Wedd	
21	770,000	City Hall		HC or Wedd	
22	740,000	City Hall	.75	HC or Wedd	
23	704,000	City Hall	.75	HC or Wedd	
24	939,000	City Hall	.86	HC or Wedd	
25	836,000	City Hall	.87	HC or Wedd	
26	865,000	City Hall		HC or Wedd	
27	754,000	City Hall		HC or Wedd	
28	717,000	City Hall		HC or Wedd	
29	840,000	City Hall	.87	HC or Wedd	
30	933,000	City Hall	.87	HC or Wedd	
31	802,000	City Hall	.82	HC or Wedd	