

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Curry**  
 Month/Year: **Aug-24**

Conventional or Direct Filtration

System Name:	City of Gold Beach		ID#: 4101059	WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.01	0.01	0.01	0.02	0.01	0.01	0.06
2	0.01	0.01	0.01	0.01	0.01	0.01	0.07
3	0.02	OFF	0.01	0.01	0.01	0.01	0.07
4	0.01	OFF	0.01	0.08	0.01	0.01	0.08
5	0.01	OFF	0.02	0.01	0.01	0.01	0.02
6	0.01	OFF	0.02	0.01	0.01	0.02	0.09
7	0.01	OFF	0.01	0.01	0.01	0.01	0.06
8	0.01	OFF	0.02	0.01	0.01	0.01	0.09
9	OFF	OFF	0.01	0.01	0.01	0.02	0.07
10	0.01	OFF	0.01	0.01	0.02	0.01	0.04
11	0.02	OFF	0.02	0.01	0.01	0.01	0.05
12	OFF	OFF	0.01	0.03	0.02	0.02	0.10
13	0.02	OFF	0.02	0.02	0.02	0.01	0.30
14	OFF	OFF	0.01	0.02	0.02	0.02	0.10
15	OFF	OFF	0.02	0.01	0.01	0.01	0.06
16	0.02	OFF	0.02	0.02	0.01	0.02	0.07
17	0.02	OFF	0.02	0.02	0.02	OFF	0.08
18	0.02	OFF	0.02	0.01	0.01	OFF	0.09
19	0.02	OFF	0.02	0.02	0.02	0.02	0.07
20	OFF	OFF	0.02	0.02	0.02	0.02	0.10
21	OFF	OFF	0.02	0.02	0.01	0.01	0.04
22	OFF	0.04	0.01	0.01	OFF	0.01	0.10
23	OFF	OFF	OFF	OFF	OFF	OFF	N/A
24	OFF	OFF	OFF	OFF	0.01	0.01	0.04
25	0.01	0.01	0.02	0.02	0.02	0.02	0.03
26	0.01	OFF	0.02	0.02	0.02	OFF	0.05
27	0.02	OFF	0.01	0.01	0.02	0.02	0.06
28	OFF	0.02	0.06	0.01	0.01	0.01	0.06
29	OFF	OFF	0.01	0.02	0.01	0.01	0.06
30	OFF	0.01	0.01	0.01	0.01	OFF	0.06
31	OFF	OFF	0.01	0.01	0.01	0.01	0.04

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All 4-hour turbidity readings ≤ 1 NTU? <b>Yes</b>		
All turbidity readings < IFE <sup>2</sup> triggers <b>Yes</b>		

<b>Notes:</b>	<b>PRINTED NAME: Will Newdall</b>	
	<b>SIGNATURE:</b>	<b>8/1/2024</b>
	<b>PHONE #: (541 )247-7459</b>	<b>CERT #: FE0054</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	Aug-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1	0.98	60	58.8	21.6	7.01	8.7	YES	700
2	0.96	60	57.6	21.6	6.98	8.6	YES	700
3	0.93	60	55.8	21.1	7.01	9.0	YES	700
4	0.91	60	54.6	21.4	6.98	8.7	YES	700
5	0.94	60	56.4	21.3	6.98	8.8	YES	700
6	0.97	60	58.2	22.2	7.00	8.3	YES	700
7	0.84	60	50.4	21.6	7.00	8.6	YES	700
8	0.97	60	58.2	21.2	6.90	8.6	YES	700
9	0.96	60	57.6	20.4	6.99	9.4	YES	700
10	0.95	60	57.0	20.3	6.96	9.3	YES	700
11	0.95	60	57.0	21.9	6.90	8.2	YES	700
12	0.85	60	51.0	22.3	6.92	7.9	YES	700
13	0.88	60	52.8	23.6	6.92	7.3	YES	700
14	0.96	60	57.6	22.1	6.89	8.1	YES	700
15	0.97	60	58.2	22.2	6.98	8.3	YES	700
16	0.95	60	57.0	20.5	6.93	9.1	YES	700
17	0.95	60	57.0	20.5	7.02	9.4	YES	700
18	0.93	60	55.8	20.9	7.03	9.2	YES	700
19	0.94	60	56.4	21.9	6.97	8.4	YES	700
20	0.89	60	53.4	19.1	6.97	10.1	YES	700
21	1	60	60.0	21.3	7.02	9.0	YES	700
22	0.87	60	52.2	21.4	7.09	9.0	YES	700
23	0.85	60	51.0	18.4	7.07	10.9	YES	0
24	0.99	60	59.4	21.8	7.04	8.7	YES	700
25	0.99	60	59.4	20.3	7.03	9.6	YES	700
26	0.98	60	58.8	21.3	7.05	9.1	YES	700
27	0.97	60	58.2	19.0	6.99	10.3	YES	700
28	1	60	60.0	21.8	6.94	8.4	YES	700
29	0.99	60	59.4	19.8	6.98	9.8	YES	700
30	0.99	60	59.4	19.0	7.07	10.7	YES	700
31	0.99	60	59.4	18.3	7.07	11.2	YES	700

<sup>3</sup> If Cl<sub>2</sub> at entry poin

Revised September 2016

### Water Production Record for The City of Gold Beach

		Chlorine Residual		August 2024	
Date	Gallons Pumped	Location 1	Residual	Location 2	Residual
1	973,100	City Hall	.75	HC or Wedd	
2	895,000	City Hall		HC or Wedd	
3	798,066	City Hall		HC or Wedd	
4	708,060	City Hall		HC or Wedd	
5	744,000	City Hall	.86	HC or Wedd	
6	787,000	City Hall	.70	HC or Wedd	
7	774,000	City Hall	.81	HC or Wedd	
8	669,000	City Hall	.68	HC or Wedd	
9	693,000	City Hall		HC or Wedd	
10	753,000	City Hall		HC or Wedd	
11	661,000	City Hall		HC or Wedd	
12	696,000	City Hall	.71	HC or Wedd	
13	719,000	City Hall	.65	HC or Wedd	
14	694,000	City Hall	.68	HC or Wedd	
15	742,000	City Hall	.65	HC or Wedd	
16	684,000	City Hall		HC or Wedd	
17	706,000	City Hall		HC or Wedd	
18	610,000	City Hall		HC or Wedd	
19	605,000	City Hall	.66	HC or Wedd	
20	552,000	City Hall	.48	HC or Wedd	
21	635,000	City Hall	.69	HC or Wedd	
22	675,000	City Hall	.50	HC or Wedd	
23	405,000	City Hall		HC or Wedd	
24	0	City Hall		HC or Wedd	
25	805,000	City Hall		HC or Wedd	
26	797,000	City Hall	.72	HC or Wedd	
27	608,000	City Hall	.52	HC or Wedd	
28	631,000	City Hall	.51	HC or Wedd	
29	617,000	City Hall	.62	HC or Wedd	
30	583,000	City Hall		HC or Wedd	
31	545,000	City Hall		HC or Wedd	