

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: Oct-24

System Name:	City of Gold Beach		ID#: 4101059				WTP : TP -
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	0.01	0.01	0.01	0.17
2	OFF	OFF	0.03	0.01	0.01	0.01	0.05
3	0.02	OFF	OFF	0.01	0.02	0.01	0.15
4	OFF	OFF	OFF	0.01	0.01	0.01	0.07
5	OFF	OFF	OFF	0.01	0.01	0.01	0.03
6	OFF	OFF	0.02	0.01	0.01	0.01	0.04
7	0.01	OFF	OFF	0.02	0.02	0.02	0.04
8	OFF	OFF	OFF	0.02	OFF	OFF	0.06
9	OFF	OFF	OFF	0.01	0.01	OFF	0.07
10	OFF	OFF	0.02	0.02	0.01	OFF	0.04
11	OFF	OFF	OFF	OFF	OFF	OFF	0.04
12	0.04	0.04	0.04	0.04	OFF	OFF	0.04
13	OFF	OFF	OFF	0.01	0.01	0.01	0.02
14	0.01	0.01	0.02	0.02	0.01	OFF	0.09
15	OFF	OFF	OFF	0.01	0.02	0.01	0.02
16	0.01	0.02	0.02	0.01	OFF	OFF	0.05
17	OFF	OFF	OFF	0.01	0.02	0.01	0.04
18	OFF	OFF	OFF	0.01	0.01	OFF	0.04
19	OFF	OFF	0.01	0.01	0.03	OFF	0.06
20	OFF	OFF	0.02	0.02	0.01	OFF	0.02
21	OFF	OFF	0.01	0.01	0.01	OFF	0.03
22	OFF	OFF	0.01	0.01	OFF	OFF	0.03
23	0.01	OFF	OFF	0.02	0.02	OFF	0.06
24	OFF	OFF	0.02	0.02	0.01	OFF	0.03
25	OFF	0.02	0.01	0.01	OFF	OFF	0.04
26	0.01	OFF	OFF	0.03	0.02	0.01	0.06
27	OFF	OFF	OFF	0.01	0.01	OFF	0.03
28	OFF	OFF	0.02	0.01	0.01	OFF	0.02
29	OFF	OFF	0.01	0.02	0.01	OFF	0.13
30	OFF	OFF	0.02	0.01	OFF	OFF	0.14
31	OFF	0.01	OFF	0.01	0.02	0.02	0.13

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes:	PRINTED NAME: Will Newdall	
	SIGNATURE:	10/1/2024
	PHONE #: (541)247-7459	CERT #:FE0054

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	Oct-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.95	60	57.0	26.5	6.96	6.1	YES	700
2	0.93	60	55.8	21.3	7.06	9.0	YES	700
3	0.82	60	49.2	20.7	7.15	9.6	YES	700
4	0.91	60	54.6	17.6	7.10	11.8	YES	700
5	0.95	60	57.0	18.6	7.06	10.9	YES	700
6	0.94	60	56.4	17.2	7.08	12.0	YES	700
7	0.98	60	58.8	19.3	7.10	10.6	YES	700
8	0.92	60	55.2	17.4	7.04	11.7	YES	700
9	0.91	60	54.6	18.7	7.05	10.7	YES	700
10	0.89	60	53.4	15.7	7.10	13.3	YES	700
11	1.05	60	63.0	18.7	7.07	11.0	YES	700
12	0.92	60	55.2	21.2	7.14	9.4	YES	700
13	1.04	60	62.4	18.2	7.13	11.6	YES	700
14	1.03	60	61.8	18.0	7.06	11.4	YES	700
15	0.95	60	57.0	19.5	7.09	10.3	YES	700
16	0.92	60	55.2	18.1	7.03	11.1	YES	700
17	0.91	60	54.6	16.6	7.07	12.4	YES	700
18	0.97	60	58.2	15.8	7.04	13.1	YES	700
19	0.98	60	58.8	17.8	7.12	11.8	YES	700
20	0.94	60	56.4	18.3	7.03	11.0	YES	700
21	0.97	60	58.2	18.7	7.01	10.6	YES	700
22	0.97	60	58.2	18.7	7.02	10.7	YES	700
23	0.99	60	59.4	18.3	7.00	10.9	YES	0
24	0.98	60	58.8	17.4	7.01	11.6	YES	700
25	0.9	60	54.0	16.4	7.07	12.6	YES	700
26	0.99	60	59.4	17.7	7.08	11.7	YES	700
27	0.98	60	58.8	17.6	7.04	11.6	YES	700
28	0.97	60	58.2	18.6	7.00	10.7	YES	700
29	0.92	60	55.2	16.8	6.98	11.9	YES	700
30	1.04	60	62.4	17.6	7.06	11.8	YES	700
31	0.95	60	57.0	17.3	7.07	11.9	YES	

³ If Cl₂ at entry poin

Water Production Record for The City of Gold Beach

Date	Gallons Pumped	Chlorine Residual		October 2024	
		Location 1	Residual	Location 2	Residual
1	611,000	City Hall	.65	HC or Wedd	
2	562,000	City Hall	.67	HC or Wedd	
3	605,000	City Hall	.65	HC or Wedd	
4	564,000	City Hall		HC or Wedd	
5	563,000	City Hall		HC or Wedd	
6	508,000	City Hall		HC or Wedd	
7	611,000	City Hall	.66	HC or Wedd	
8	856,000	City Hall	.76	HC or Wedd	
9	241,000	City Hall	.45	HC or Wedd	
10	330,000	City Hall	.68	HC or Wedd	
11	372,000	City Hall		HC or Wedd	
12	373,000	City Hall		HC or Wedd	
13	276,000	City Hall		HC or Wedd	
14	808,000	City Hall	.86	HC or Wedd	
15	423,000	City Hall	.73	HC or Wedd	
16	880,000	City Hall	.82	HC or Wedd	
17	323,000	City Hall	.59	HC or Wedd	
18	508,000	City Hall		HC or Wedd	
19	496,000	City Hall		HC or Wedd	
20	442,000	City Hall		HC or Wedd	
21	480,000	City Hall	.56	HC or Wedd	
22	500,000	City Hall	.55	HC or Wedd	
23	456,000	City Hall	.44	HC or Wedd	
24	472,000	City Hall	.79	HC or Wedd	
25	508,000	City Hall		HC or Wedd	
26	414,000	City Hall		HC or Wedd	
27	384,000	City Hall		HC or Wedd	
28	489,000	City Hall	.72	HC or Wedd	
29	478,000	City Hall	.65	HC or Wedd	
30	415,000	City Hall	.63	HC or Wedd	
31	497,000	City Hall	.53	HC or Wedd	