

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: 2/31/2025

System Name: City of Gold Beach		ID#: 4101059		WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	0.03	0.09	0.03	OFF	0.21
2	OFF	OFF	OFF	0.03	0.03	OFF	0.09
3	OFF	OFF	0.03	0.03	0.02	0.02	0.05
4	OFF	OFF	OFF	0.02	0.03	0.03	0.08
5	OFF	OFF	OFF	0.02	0.02	OFF	0.10
6	OFF	OFF	OFF	0.03	0.04	0.03	0.07
7	OFF	OFF	0.04	0.05	0.03	OFF	0.08
8	OFF	OFF	OFF	0.03	0.03	OFF	0.05
9	OFF	OFF	0.04	0.03	0.03	0.05	0.12
10	OFF	OFF	OFF	0.07	0.03	OFF	0.08
11	OFF	OFF	0.03	0.04	0.02	0.03	0.09
12	OFF	OFF	0.03	0.03	0.03	0.04	0.06
13	OFF	OFF	0.04	0.11	0.02	0.03	0.10
14	OFF	OFF	0.02	0.03	0.03	0.04	0.49
15	OFF	OFF	OFF	0.03	0.03	OFF	0.08
16	OFF	OFF	0.05	0.05	0.05	OFF	0.45
17	OFF	OFF	0.03	0.04	OFF	OFF	0.19
18	OFF	0.04	OFF	0.11	0.05	0.05	0.45
19	OFF	OFF	OFF	0.04	0.06	0.06	0.49
20	OFF	OFF	OFF	0.04	0.05	OFF	0.12
21	OFF	OFF	0.04	0.07	0.06	OFF	0.41
22	OFF	OFF	0.04	0.04	OFF	0.03	0.13
23	0.04	OFF	OFF	OFF	0.08	0.06	0.43
24	0.06	0.06	OFF	OFF	OFF	OFF	0.09
25	OFF	OFF	0.03	0.06	0.05	0.05	0.38
26	0.04	OFF	0.04	0.04	0.09	OFF	0.42
27	OFF	0.05	0.04	0.04	OFF	0.05	0.17
28	OFF	OFF	OFF	0.05	0.05	OFF	0.29
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		
Notes:		PRINTED NAME: Will Newdall	
		SIGNATURE:	2/31/2025
		PHONE #: (541)247-7459	CERT #: FE0054

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	2/31/2025	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	-----------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.94	60	56.4	15.2	6.92	13.0	YES	700
2	0.98	60	58.8	14.4	7.01	14.2	YES	700
3	1	60	60.0	9.7	6.93	19.2	YES	700
4	0.76	60	45.6	8.8	6.98	20.2	YES	700
5	0.94	60	56.4	9.4	6.81	18.7	YES	700
6	0.89	60	53.4	9.2	6.98	19.9	YES	700
7	0.94	60	56.4	9.3	7.00	20.1	YES	700
8	0.93	60	55.8	9.1	7.00	20.3	YES	700
9	0.91	60	54.6	9.5	7.02	19.9	YES	700
10	0.95	60	57.0	9.3	7.01	20.2	YES	700
11	0.95	60	57.0	8.6	7.00	21.0	YES	700
12	0.94	60	56.4	7.9	6.96	21.7	YES	700
13	0.96	60	57.6	8.7	6.93	20.4	YES	700
14	0.83	60	49.8	11.0	6.87	17.0	YES	700
15	0.96	60	57.6	8.1	6.93	21.2	YES	700
16	0.96	60	57.6	9.1	6.89	19.6	YES	700
17	0.86	60	51.6	8.9	6.90	19.7	YES	700
18	0.92	60	55.2	9.5	6.86	18.8	YES	700
19	0.86	60	51.6	9.8	7.00	19.2	YES	700
20	0.96	60	57.6	8.9	7.03	20.9	YES	700
21	0.94	60	56.4	10.8	6.63	16.0	YES	700
22	0.82	60	49.2	8.7	6.83	19.4	YES	700
23	0.85	60	51.0	10.7	6.75	16.7	YES	700
24	0.98	60	58.8	10.0	6.89	18.5	YES	700
25	0.9	60	54.0	9.9	6.87	18.4	YES	700
26	0.92	60	55.2	9.8	6.96	19.1	YES	700
27	0.92	60	55.2	9.3	7.01	20.1	YES	700
28	0.94	60	56.4	9.5	6.94	19.4	YES	700
29		60						
30		60						
31		60						

³ If Cl₂ at entry poin

Revised September 2016

	MONTH: <u>February</u>	YEAR: <u>2025</u>	PW ID: 4-101059		
	<u>WATER PRODUCTION</u>	<u>DISTRIBUTION SYSTEM CHLORINE RESIDUALS</u>			
<u>DATE</u>	<u>GALLONS PUMPED</u>	<u>LOCATION 1</u>	<u>RESIDUAL</u>	<u>LOCATION 2</u>	<u>RESIDUAL</u>
1	329,000	PW SHOP		HC OR WEDD	
2	399,000	PW SHOP		HC OR WEDD	
3	352,000	PW SHOP	.82	HC OR WEDD	
4	555,000	PW SHOP	.79	HC OR WEDD	
5	460,000	PW SHOP	.78	HC OR WEDD	
6	437,000	PW SHOP	.77	HC OR WEDD	
7	420,000	PW SHOP		HC OR WEDD	
8	420,000	PW SHOP		HC OR WEDD	
9	414,000	PW SHOP		HC OR WEDD	
10	309,000	PW SHOP	.81	HC OR WEDD	
11	457,000	PW SHOP	.69	HC OR WEDD	
12	486,000	PW SHOP	.79	HC OR WEDD	
13	532,000	PW SHOP	.68	HC OR WEDD	
14	483,000	PW SHOP		HC OR WEDD	
15	524,000	PW SHOP		HC OR WEDD	
16	381,000	PW SHOP		HC OR WEDD	
17	426,000	PW SHOP	Holiday	HC OR WEDD	
18	507,000	PW SHOP	.60	HC OR WEDD	
19	447,000	PW SHOP	.72	HC OR WEDD	
20	499,000	PW SHOP	.67	HC OR WEDD	
21	464,000	PW SHOP		HC OR WEDD	
22	489,000	PW SHOP		HC OR WEDD	
23	380,000	PW SHOP		HC OR WEDD	
24	717,000	PW SHOP	.68	HC OR WEDD	wallace battery dr
25	15,000	PW SHOP	.64	HC OR WEDD	
26	655,000	PW SHOP	.73	HC OR WEDD	
27	532,000	PW SHOP	.67	HC OR WEDD	
28	472,000	PW SHOP		HC OR WEDD	
29	364,000	PW SHOP		HC OR WEDD	
30		PW SHOP		HC OR WEDD	
31		PW SHOP	.	HC OR WEDD	