

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: Jul-25

System Name: City of Gold Beach		ID#: 4101059		WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	0.06	0.02	0.02	0.02	0.58
2	0.02	0.02	0.03	0.02	0.02	0.01	0.19
3	0.01	OFF	OFF	0.02	0.02	0.02	0.16
4	0.01	OFF	OFF	0.02	0.02	0.01	0.16
5	0.01	OFF	OFF	0.05	0.02	0.01	0.15
6	0.02	OFF	OFF	0.01	0.02	0.01	0.07
7	0.01	OFF	0.01	0.02	0.01	0.01	0.07
8	0.01	OFF	0.01	0.02	0.07	0.01	0.08
9	OFF	OFF	0.02	0.01	0.02	0.02	0.06
10	0.01	OFF	0.01	0.02	0.03	0.02	0.16
11	0.01	OFF	OFF	0.01	0.01	0.02	0.09
12	0.01	OFF	OFF	0.01	0.01	0.02	0.11
13	0.01	OFF	OFF	0.01	0.01	0.09	0.14
14	0.01	OFF	0.06	0.02	0.02	0.02	0.07
15	OFF	OFF	0.08	0.08	0.08	0.08	1.00
16	0.08	OFF	0.06	0.08	0.08	0.08	1.00
17	OFF	OFF	0.06	0.07	0.08	0.08	1.00
18	0.08	OFF	OFF	0.08	0.08	0.08	0.58
19	0.08	OFF	OFF	0.10	0.08	0.08	0.34
20	0.08	OFF	OFF	0.09	0.75	0.08	1.00
21	OFF	OFF	0.08	0.08	0.08	0.09	0.23
22	OFF	OFF	0.07	0.09	0.09	0.09	1.00
23	0.09	OFF	0.07	0.09	0.09	0.09	1.00
24	OFF	OFF	0.07	0.09	0.09	0.09	0.35
25	0.09	OFF	OFF	0.08	0.09	0.09	1.00
26	0.02	OFF	OFF	0.02	0.02	0.02	0.09
27	0.02	OFF	OFF	0.02	0.02	0.02	0.09
28	0.02	OFF	OFF	0.02	0.01	0.01	0.11
29	0.01	OFF	0.01	0.02	0.01	0.01	0.09
30	0.01	OFF	0.01	0.01	0.01	0.02	0.07
31	0.01	OFF	0.01	0.02	0.02	0.01	0.09

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes:	PRINTED NAME: Will Newdall	
	SIGNATURE:	7/30/2025
	PHONE #: (541)247-7459	CERT #: FE0054

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	Jul-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	1.1	60	66.0	19.9	7.20	10.7	YES	700
2	1.04	60	62.4	20.6	6.92	9.1	YES	700
3	1.03	60	61.8	20.1	6.92	9.4	YES	700
4	0.94	60	56.4	20.9	7.02	9.2	YES	700
5	0.9	60	54.0	20.8	7.06	9.3	YES	700
6	1.01	60	60.6	20.6	7.02	9.4	YES	700
7	1.01	60	60.6	21.2	6.92	8.7	YES	700
8	1.05	60	63.0	20.6	6.67	8.3	YES	700
9	0.93	60	55.8	21.0	6.98	8.9	YES	700
10	1.03	60	61.8	20.6	6.96	9.2	YES	700
11	1.05	60	63.0	22.0	6.69	7.6	YES	700
12	1.01	60	60.6	24.9	6.73	6.3	YES	700
13	1.13	60	67.8	22.1	6.65	7.5	YES	700
14	1.13	60	67.8	21.6	6.67	7.8	YES	700
15	0.95	60	57.0	21.6	6.96	8.5	YES	700
16	0.92	60	55.2	21.2	7.04	9.0	YES	700
17	1.08	60	64.8	21.3	7.02	9.1	YES	700
18	1.05	60	63.0	23.9	6.85	7.1	YES	700
19	1.02	60	61.2	23.3	6.78	7.2	YES	700
20	1.05	60	63.0	23.5	6.89	7.4	YES	700
21	1.04	60	62.4	21.9	6.91	8.3	YES	700
22	1.17	60	70.2	21.7	6.98	8.8	YES	700
23	1.16	60	69.6	22.1	7.02	8.7	YES	700
24	1.11	60	66.6	22.2	7.06	8.7	YES	700
25	0.98	60	58.8	22.9	6.82	7.4	YES	700
26	0.89	60	53.4	21.8	6.96	8.4	YES	700
27	0.9	60	54.0	21.3	6.98	8.7	YES	700
28	0.93	60	55.8	22.6	7.05	8.2	YES	700
29	0.9	60	54.0	22.3	6.95	8.1	YES	700
30	0.91	60	54.6	22.6	6.85	7.6	YES	700
31	0.9	60	54.0	22.5	6.97	8.0	YES	700

³ If Cl₂ at entry poin

Revised September 2016

WATER PRODUCTION RECORD FOR THE CITY OF GOLD BEACH

	MONTH: <u>July</u>	YEAR: <u>2025</u>	PW ID: 4101059		
	<u>WATER PRODUCTION</u>	<u>DISTRIBUTION SYSTEM CHLORINE RESIDUALS</u>			
<u>DATE</u>	<u>GALLONS PUMPED</u>	<u>LOCATION 1</u>	<u>RESIDUAL</u>	<u>LOCATION 2</u>	<u>RESIDUAL</u>
1	561,000	PW SHOP	.62	HC OR WEDD	
2	731,000	PW SHOP	.87	HC OR WEDD	
3	696,000	PW SHOP		HC OR WEDD	
4	677,000	PW SHOP		HC OR WEDD	
5	636,000	PW SHOP		HC OR WEDD	
6	674,000	PW SHOP		HC OR WEDD	
7	757,000	PW SHOP	.90	HC OR WEDD	
8	717,000	PW SHOP	.90	HC OR WEDD	
9	512,000	PW SHOP	.81	HC OR WEDD	
10	711,000	PW SHOP	.90	HC OR WEDD	
11	665,000	PW SHOP		HC OR WEDD	
12	673,000	PW SHOP		HC OR WEDD	
13	660,000	PW SHOP		HC OR WEDD	
14	713,000	PW SHOP	.88	HC OR WEDD	
15	677,000	PW SHOP	.79	HC OR WEDD	
16	753,000	PW SHOP	.80	HC OR WEDD	
17	639,000	PW SHOP	.82	HC OR WEDD	
18	659,000	PW SHOP		HC OR WEDD	
19	607,000	PW SHOP		HC OR WEDD	
20	685,000	PW SHOP		HC OR WEDD	
21	662,000	PW SHOP	.69	HC OR WEDD	
22	690,000	PW SHOP	.96	HC OR WEDD	
23	720,000	PW SHOP	.95	HC OR WEDD	
24	604,000	PW SHOP	.94	HC OR WEDD	
25	656,000	PW SHOP		HC OR WEDD	
26	659,000	PW SHOP		HC OR WEDD	
27	618,000	PW SHOP		HC OR WEDD	
28	709,000	PW SHOP	.69	HC OR WEDD	
29	706,000	PW SHOP	.65	HC OR WEDD	
30	696,000	PW SHOP	.71	HC OR WEDD	
31	673,000	PW SHOP	.70	HC OR WEDD	