

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: 9/31/2025

System Name: City of Gold Beach		ID#: 4101059		WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	0.03	0.03	0.04	0.04
2	0.04	OFF	OFF	0.04	0.04	0.04	0.04
3	OFF	OFF	0.04	0.04	0.04	0.04	0.04
4	OFF	OFF	0.04	0.03	0.03	0.04	0.13
5	OFF	OFF	0.04	0.04	0.04	0.04	0.04
6	OFF	OFF	0.04	0.04	0.04	0.04	0.04
7	OFF	OFF	OFF	0.04	0.05	0.05	0.05
8	OFF	OFF	0.05	OFF	0.02	0.02	0.14
9	0.02	0.02	0.02	0.02	OFF	OFF	0.09
10	OFF	0.02	0.02	0.01	0.02	OFF	0.10
11	0.01	OFF	0.01	OFF	0.03	0.02	0.08
12	OFF	OFF	OFF	0.01	0.01	0.01	0.08
13	OFF	OFF	0.02	0.01	0.01	0.01	0.05
14	OFF	OFF	0.01	0.01	0.01	0.01	0.12
15	OFF	OFF	0.01	0.01	0.01	0.01	0.07
16	OFF	OFF	0.01	0.01	0.01	0.04	0.13
17	OFF	OFF	0.01	0.01	0.01	0.01	0.02
18	OFF	OFF	0.01	0.02	0.01	0.01	0.09
19	OFF	OFF	OFF	0.01	0.01	0.01	0.06
20	OFF	OFF	OFF	0.01	0.01	0.02	0.06
21	OFF	OFF	0.01	0.01	0.01	0.02	0.08
22	OFF	OFF	0.01	0.01	0.01	0.01	0.09
23	0.02	OFF	0.01	OFF	OFF	0.01	0.02
24	0.01	0.01	0.02	0.01	0.01	0.01	0.02
25	0.01	OFF	0.01	0.01	0.02	0.01	0.11
26	OFF	OFF	OFF	0.01	0.01	0.03	0.08
27	OFF	OFF	OFF	0.01	0.01	OFF	0.06
28	OFF	OFF	0.01	0.02	0.01	0.01	0.14
29	OFF	OFF	0.02	0.02	0.02	0.02	0.07
30	OFF	OFF	0.01	0.02	0.02	OFF	0.07
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes:	PRINTED NAME: Will Newdall	
	SIGNATURE:	9/31/2025
	PHONE #: (541)247-7459	CERT #:FE0054

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	9/31/2025	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	-----------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.98	60	58.8	22.2	6.49	6.9	YES	700
2	0.986	60	59.2	22.0	6.71	7.6	YES	700
3	1.06	60	63.6	22.5	6.75	7.5	YES	700
4	0.99	60	59.4	22.5	6.70	7.3	YES	700
5	1.08	60	64.8	22.6	6.53	6.9	YES	700
6	1.04	60	62.4	22.7	6.60	7.0	YES	700
7	0.97	60	58.2	22.1	6.61	7.2	YES	700
8	1.03	60	61.8	22.2	6.57	7.1	YES	700
9	0.903	60	54.2	22.4	6.57	6.9	YES	700
10	1.17	60	70.2	22.1	6.68	7.6	YES	700
11	1.02	60	61.2	23.1	6.52	6.6	YES	700
12	1.03	60	61.8	22.8	6.70	7.2	YES	700
13	1.01	60	60.6	22.6	6.73	7.4	YES	700
14	0.965	60	57.9	23.1	6.72	7.1	YES	700
15	0.917	60	55.0	21.9	6.74	7.7	YES	700
16	0.91	60	54.6	21.7	6.67	7.6	YES	700
17	0.869	60	52.1	21.8	6.62	7.3	YES	700
18	0.91	60	54.6	21.9	6.67	7.5	YES	700
19	0.917	60	55.0	23.5	6.77	7.0	YES	700
20	0.903	60	54.2	22.1	6.70	7.4	YES	700
21	0.903	60	54.2	21.7	6.71	7.7	YES	700
22	0.903	60	54.2	21.7	6.70	7.6	YES	700
23	0.883	60	53.0	21.7	7.17	9.1	YES	700
24	0.917	60	55.0	21.3	7.16	9.4	YES	700
25	0.931	60	55.9	21.4	7.17	9.4	YES	700
26	0.931	60	55.9	26.6	7.16	6.5	YES	700
27	0.924	60	55.4	26.2	7.21	6.8	YES	700
28	0.883	60	53.0	25.4	7.18	7.1	YES	700
29	0.89	60	53.4	21.5	7.12	9.1	YES	700
30	0.917	60	55.0	20.8	6.68	8.1	YES	700
31							YES	700

³ If Cl₂ at entry poin

Revised September 2016

WATER PRODUCTION RECORD FOR THE CITY OF GOLD BEACH

	MONTH: <u>September</u>	YEAR: <u>2025</u>	PW ID: 4101059		
	<u>WATER PRODUCTION</u>	<u>DISTRIBUTION SYSTEM CHLORINE RESIDUALS</u>			
<u>DATE</u>	<u>GALLONS PUMPED</u>	<u>LOCATION 1</u>	<u>RESIDUAL</u>	<u>LOCATION 2</u>	<u>RESIDUAL</u>
1	576,000	PW SHOP		HC OR WEDD	
2	618,000	PW SHOP	.82	HC OR WEDD	
3	623,000	PW SHOP	.78	HC OR WEDD	
4	575,000	PW SHOP	.86	HC OR WEDD	
5	587,000	PW SHOP		HC OR WEDD	
6	530,000	PW SHOP		HC OR WEDD	
7	550,000	PW SHOP		HC OR WEDD	
8	609,000	PW SHOP	.86	HC OR WEDD	
9	701,000	PW SHOP	.79	HC OR WEDD	
10	350,000	PW SHOP	.59	HC OR WEDD	
11	713,000	PW SHOP	.84	HC OR WEDD	
12	490,000	PW SHOP		HC OR WEDD	
13	575,000	PW SHOP		HC OR WEDD	
14	531,000	PW SHOP		HC OR WEDD	
15	549,000	PW SHOP	.76	HC OR WEDD	
16	598,000	PW SHOP	.73	HC OR WEDD	
17	577,000	PW SHOP	.68	HC OR WEDD	
18	542,000	PW SHOP	.83	HC OR WEDD	
19	591,000	PW SHOP		HC OR WEDD	
20	544,000	PW SHOP		HC OR WEDD	
21	523,000	PW SHOP		HC OR WEDD	
22	527,000	PW SHOP	.70	HC OR WEDD	
23	656,000	PW SHOP	.82	HC OR WEDD	
24	389,000	PW SHOP	.73	HC OR WEDD	
25	719,000	PW SHOP	.76	HC OR WEDD	
26	445,000	PW SHOP		HC OR WEDD	
27	524,000	PW SHOP		HC OR WEDD	
28	805,000	PW SHOP		HC OR WEDD	
29	513,000	PW SHOP	.74	HC OR WEDD	
30	566,000	PW SHOP	.82	HC OR WEDD	
31		PW SHOP		HC OR WEDD	