

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: Oct-25

System Name: City of Gold Beach		ID#: 4101059		WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	0.01	0.01	0.01	OFF	0.02
2	OFF	0.01	0.02	0.01	0.01	OFF	0.08
3	OFF	OFF	0.01	0.02	0.02	OFF	0.06
4	OFF	OFF	0.01	0.01	0.01	OFF	0.04
5	OFF	OFF	0.02	0.01	0.01	OFF	0.02
6	OFF	OFF	0.01	0.02	0.02	0.02	0.53
7	OFF	OFF	0.02	0.02	0.02	0.02	0.06
8	OFF	OFF	0.02	0.02	OFF	OFF	0.02
9	OFF	0.02	0.02	0.02	OFF	OFF	0.05
10	OFF	0.02	OFF	OFF	0.02	0.02	0.07
11	OFF	OFF	OFF	0.02	0.02	OFF	0.02
12	OFF	OFF	0.02	0.02	0.02	OFF	0.04
13	OFF	OFF	0.04	0.01	0.01	OFF	0.12
14	OFF	OFF	0.01	0.01	0.01	OFF	0.10
15	OFF	OFF	0.01	0.01	OFF	OFF	0.02
16	OFF	0.01	0.01	0.01	OFF	OFF	0.07
17	OFF	0.01	0.01	OFF	OFF	0.01	0.59
18	OFF	OFF	OFF	0.01	0.01	OFF	0.09
19	OFF	OFF	OFF	0.01	0.01	0.01	0.10
20	OFF	OFF	0.01	0.01	0.01	0.01	0.13
21	OFF	OFF	0.01	0.01	0.01	OFF	0.01
22	OFF	OFF	0.01	OFF	0.01	OFF	0.09
23	OFF	OFF	0.01	0.01	OFF	OFF	0.03
24	OFF	0.01	0.01	0.01	0.01	OFF	0.07
25	OFF	OFF	0.01	0.01	0.01	OFF	0.09
26	OFF	OFF	OFF	0.01	0.01	OFF	0.03
27	OFF	OFF	OFF	0.02	0.02	0.02	0.05
28	OFF	OFF	0.02	0.02	OFF	OFF	0.06
29	0.02	0.02	0.02	OFF	0.02	0.02	0.02
30	OFF	OFF	OFF	0.02	0.02	0.02	0.05
31	OFF	OFF	OFF	0.02	0.02	OFF	0.04

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes:	PRINTED NAME: Will Newdall	
	SIGNATURE:	10/31/2025
	PHONE #: (541)247-7459	CERT #:FE0054

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	Oct-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.889	60	53.3	21.1	6.74	8.1	YES	700
2	1.075	60	64.5	20.7	6.67	8.3	YES	700
3	1.089	60	65.3	20.8	6.71	8.3	YES	700
4	1.089	60	65.3	20.6	6.69	8.4	YES	700
5	1.048	60	62.9	20.5	6.69	8.4	YES	700
6	1.061	60	63.7	21.1	6.72	8.2	YES	700
7	1.006	60	60.4	20.1	6.72	8.7	YES	700
8	1.006	60	60.4	20.0	6.68	8.6	YES	700
9	0.958	60	57.5	19.8	6.68	8.7	YES	700
10	0.979	60	58.7	19.5	6.73	9.1	YES	700
11	1.068	60	64.1	18.8	6.72	9.6	YES	700
12	0.951	60	57.1	19.3	6.71	9.1	YES	700
13	0.848	60	50.9	18.7	6.69	9.3	YES	700
14	0.903	60	54.2	19.0	6.69	9.2	YES	700
15	1.006	60	60.4	18.7	6.70	9.5	YES	700
16	1.02	60	61.2	18.8	6.72	9.5	YES	700
17	0.931	60	55.9	18.8	6.72	9.4	YES	700
18	0.828	60	49.7	17.4	6.71	10.2	YES	700
19	0.855	60	51.3	18.2	6.73	9.8	YES	700
20	1.013	60	60.8	18.1	6.71	9.9	YES	700
21	0.999	60	59.9	18.4	6.67	9.6	YES	700
22	0.958	60	57.5	18.0	6.73	10.0	YES	700
23	1.01	60	60.6	17.9	6.74	10.2	YES	700
24	1	60	60.0	17.9	6.98	11.1	YES	700
25	0.99	60	59.4	17.5	6.93	11.2	YES	700
26	0.965	60	57.9	17.5	6.95	11.3	YES	700
27	0.951	60	57.1	16.7	6.65	10.6	YES	700
28	0.903	60	54.2	17.0	6.65	10.3	YES	700
29	0.883	60	53.0	17.7	6.69	10.0	YES	700
30	0.979	60	58.7	17.1	6.67	10.4	YES	700
31	0.979	60	58.7	17.1	6.81	11.0	YES	700

³ If Cl₂ at entry poin

Revised September 2016

WATER PRODUCTION RECORD FOR THE CITY OF GOLD BEACH

	MONTH: <u>October</u>	YEAR: <u>2025</u>	PW ID: 4101059		
	<u>WATER PRODUCTION</u>	<u>DISTRIBUTION SYSTEM CHLORINE RESIDUALS</u>			
<u>DATE</u>	<u>GALLONS PUMPED</u>	<u>LOCATION 1</u>	<u>RESIDUAL</u>	<u>LOCATION 2</u>	<u>RESIDUAL</u>
1	482,000	PW SHOP	.69	HC OR WEDD	
2	539,000	PW SHOP	.54	HC OR WEDD	
3	496,000	PW SHOP		HC OR WEDD	
4	445,000	PW SHOP		HC OR WEDD	
5	501,000	PW SHOP	.	HC OR WEDD	
6	489,000	PW SHOP	.61	HC OR WEDD	
7	529,000	PW SHOP	.76	HC OR WEDD	
8	525,000	PW SHOP	.66	HC OR WEDD	
9	518,000	PW SHOP	.52	HC OR WEDD	
10	441,000	PW SHOP		HC OR WEDD	
11	383,000	PW SHOP		HC OR WEDD	
12	389,000	PW SHOP		HC OR WEDD	
13	480,000	PW SHOP	.76	HC OR WEDD	
14	491,000	PW SHOP	.72	HC OR WEDD	
15	470,000	PW SHOP	.62	HC OR WEDD	
16	487,000	PW SHOP	.59	HC OR WEDD	
17	520,000	PW SHOP		HC OR WEDD	
18	351,000	PW SHOP		HC OR WEDD	
19	415,000	PW SHOP		HC OR WEDD	
20	497,000	PW SHOP	.59	HC OR WEDD	
21	554,000	PW SHOP	.69	HC OR WEDD	
22	462,000	PW SHOP	.66	HC OR WEDD	
23	486,000	PW SHOP	.70	HC OR WEDD	
24	460,000	PW SHOP		HC OR WEDD	
25	426,000	PW SHOP		HC OR WEDD	
26	418,000	PW SHOP		HC OR WEDD	
27	453,000	PW SHOP	.51	HC OR WEDD	
28	500,000	PW SHOP	.69	HC OR WEDD	
29	602,000	PW SHOP	.56	HC OR WEDD	
30	366,000	PW SHOP		HC OR WEDD	
31	511,000	PW SHOP		HC OR WEDD	