

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry  
 Month/Year: Nov-25

Conventional or Direct Filtration

System Name:	City of Gold Beach		ID#: 4101059				WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	OFF	OFF	0.02	0.02	0.02	OFF	0.02	
2	OFF	0.02	0.02	0.02	OFF	OFF	0.05	
3	OFF	0.02	0.02	OFF	OFF	0.02	0.05	
4	0.02	OFF	0.02	0.02	OFF	OFF	0.05	
5	OFF	0.02	0.02	OFF	0.02	0.02	0.05	
6	0.02	OFF	OFF	0.02	OFF	OFF	0.02	
7	OFF	0.02	OFF	OFF	0.02	0.02	0.06	
8	OFF	OFF	OFF	0.02	0.02	0.02	0.07	
9	OFF	OFF	OFF	0.02	0.02	OFF	0.02	
10	OFF	OFF	0.02	0.02	0.02	OFF	0.10	
11	OFF	OFF	0.01	0.01	0.01	OFF	0.09	
12	OFF	OFF	0.02	0.01	0.01	OFF	0.03	
13	OFF	0.01	0.01	0.02	OFF	OFF	0.08	
14	0.01	0.01	OFF	0.01	OFF	OFF	0.03	
15	0.01	0.02	OFF	OFF	0.01	0.01	0.09	
16	OFF	OFF	OFF	0.01	0.01	OFF	0.02	
17	OFF	OFF	0.02	0.01	0.01	OFF	0.09	
18	OFF	OFF	0.01	0.01	0.02	OFF	0.13	
19	OFF	OFF	0.01	0.01	OFF	OFF	0.02	
20	OFF	0.01	OFF	OFF	0.01	0.01	0.12	
21	OFF	OFF	OFF	0.01	OFF	OFF	0.02	
22	OFF	OFF	0.01	0.01	OFF	OFF	0.13	
23	OFF	OFF	0.01	0.01	OFF	OFF	0.03	
24	0.01	OFF	0.02	0.02	0.02	OFF	0.02	
25	OFF	OFF	0.02	0.02	OFF	OFF	0.02	
26	OFF	0.02	0.02	0.02	OFF	OFF	0.06	
27	OFF	0.02	0.02	OFF	0.02	0.02	0.09	
28	OFF	OFF	OFF	0.02	0.02	OFF	0.02	
29	OFF	OFF	0.02	0.02	OFF	OFF	0.03	
30	OFF	0.02	0.02	0.02	OFF	OFF	0.06	
31								

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All 4-hour turbidity readings ≤ 1 NTU? <b>Yes</b>		
All turbidity readings < IFE <sup>2</sup> triggers <b>Yes</b>		

<b>Notes:</b>	<b>PRINTED NAME: Will Newdall</b>	
	<b>SIGNATURE:</b>	<b>11/30/2025</b>
	<b>PHONE #: (541 )247-7459</b>	<b>CERT #:FE0054</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	Nov-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1	1.054	60	63.2	17.6	6.68	10.2	YES	700
2	0.97	60	58.2	16.3	6.71	11.2	YES	700
3	1.123	60	67.4	16.5	6.71	11.2	YES	700
4	1.089	60	65.3	16.3	6.67	11.1	YES	700
5	1.068	60	64.1	16.5	6.71	11.1	YES	700
6	0.945	60	56.7	16.5	6.69	10.9	YES	700
7	0.93	60	55.8	14.4	6.58	12.0	YES	700
8	1.04	60	62.4	17.8	6.69	10.1	YES	700
9	1.03	60	61.8	17.0	6.00	8.2	YES	700
10	0.9	60	54.0	15.8	6.62	11.1	YES	700
11	0.91	60	54.6	17.1	6.78	10.8	YES	700
12	0.83	60	49.8	16.2	6.69	11.0	YES	700
13	0.84	60	50.4	15.8	6.67	11.2	YES	700
14	0.84	60	50.4	15.4	6.67	11.5	YES	700
15	0.9	60	54.0	15.6	6.66	11.4	YES	700
16	0.9	60	54.0	15.6	6.70	11.6	YES	700
17	0.9	60	54.0	15.2	6.66	11.7	YES	700
18	0.92	60	55.2	14.9	6.64	11.9	YES	700
19	0.87	60	52.2	14.8	6.66	12.0	YES	700
20	0.8	60	48.0	14.7	6.68	12.1	YES	700
21	0.89	60	53.4	14.2	6.59	12.2	YES	700
22	0.9	60	54.0	14.0	6.60	12.4	YES	700
23	0.83	60	49.8	14.1	6.59	12.2	YES	700
24	1.04	60	62.4	14.3	6.69	12.8	YES	700
25	1.01	60	60.6	14.4	6.66	12.5	YES	700
26	0.97	60	58.2	14.4	6.68	12.5	YES	700
27	0.93	60	55.8	14.3	6.73	12.8	YES	700
28	0.98	60	58.8	14.7	6.70	12.4	YES	700
29	0.99	60	59.4	14.5	6.75	12.8	YES	700
30	1.04	60	62.4	15.0	6.70	12.2	YES	700
31		60					YES	700

<sup>3</sup> If Cl<sub>2</sub> at entry poin

Revised September 2016

# WATER PRODUCTION RECORD FOR THE CITY OF GOLD BEACH

MONTH: <u>November</u>		YEAR: <u>2025</u>		PW ID: 4101059	
<u>WATER PRODUCTION</u>		<u>DISTRIBUTION SYSTEM CHLORINE RESIDUALS</u>			
<u>DATE</u>	<u>GALLONS PUMPED</u>	<u>LOCATION 1</u>	<u>RESIDUAL</u>	<u>LOCATION 2</u>	<u>RESIDUAL</u>
1	412,000	PW SHOP		HC OR WEDD	
2	502,000	PW SHOP		HC OR WEDD	
3	525,000	PW SHOP	.42	HC OR WEDD	
4	382,000	PW SHOP	.67	HC OR WEDD	
5	555,000	PW SHOP	.63	HC OR WEDD	
6	367,000	PW SHOP	.59	HC OR WEDD	
7	570,000	PW SHOP		HC OR WEDD	
8	308,000	PW SHOP		HC OR WEDD	
9	428,000	PW SHOP		HC OR WEDD	
10	414,000	PW SHOP	.61	HC OR WEDD	
11	457,000	PW SHOP		HC OR WEDD	
12	449,000	PW SHOP	.58	HC OR WEDD	
13	502,000	PW SHOP	.42	HC OR WEDD	
14	476,000	PW SHOP		HC OR WEDD	
15	441,000	PW SHOP		HC OR WEDD	
16	294,000	PW SHOP		HC OR WEDD	
17	407,000	PW SHOP	.41	HC OR WEDD	
18	446,000	PW SHOP	.53	HC OR WEDD	
19	441,000	PW SHOP	.44	HC OR WEDD	
20	467,000	PW SHOP	.39	HC OR WEDD	
21	319,000	PW SHOP		HC OR WEDD	
22	279,000	PW SHOP		HC OR WEDD	
23	405,408	PW SHOP		HC OR WEDD	
24	440,000	PW SHOP	.41	HC OR WEDD	
25	327,000	PW SHOP	.61	HC OR WEDD	
26	448,000	PW SHOP	.61	HC OR WEDD	
27	429,000	PW SHOP		HC OR WEDD	
28	346,000	PW SHOP		HC OR WEDD	
29	299,000	PW SHOP		HC OR WEDD	
30	463,000	PW SHOP		HC OR WEDD	
31		PW SHOP		HC OR WEDD	