

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry
 Month/Year: Jan-26

Conventional or Direct Filtration

System Name: City of Gold Beach ID#: 4101059 WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	0.02	0.03	0.03	0.02	0.05
2	OFF	OFF	OFF	0.02	0.02	OFF	0.05
3	OFF	OFF	OFF	0.02	0.02	OFF	0.03
4	OFF	OFF	OFF	0.02	0.06	0.04	0.06
5	OFF	OFF	0.02	0.02	0.06	OFF	0.06
6	OFF	OFF	0.02	0.70	OFF	OFF	0.99
7	OFF	OFF	0.42	0.04	0.03	0.03	0.93
8	OFF	OFF	0.03	0.02	OFF	OFF	0.03
9	OFF	OFF	OFF	0.02	0.02	0.02	0.02
10	OFF	OFF	OFF	OFF	0.02	0.02	0.02
11	OFF	OFF	OFF	OFF	0.02	0.02	0.02
12	0.02	OFF	0.02	OFF	OFF	OFF	0.02
13	OFF	OFF	0.02	0.02	0.02	OFF	0.02
14	OFF	OFF	0.02	0.02	OFF	OFF	0.02
15	OFF	OFF	0.02	0.02	0.06	0.03	0.33
16	OFF	OFF	OFF	0.02	0.02	OFF	0.02
17	OFF	OFF	OFF	OFF	0.02	0.02	0.02
18	0.02	OFF	OFF	0.02	0.02	0.03	0.03
19	OFF	OFF	OFF	0.02	0.02	OFF	0.02
20	OFF	OFF	0.02	0.02	0.02	OFF	0.13
21	OFF	OFF	0.02	0.02	OFF	OFF	0.04
22	OFF	0.02	0.02	0.02	0.02	0.02	0.07
23	0.02	0.03	OFF	OFF	OFF	OFF	0.15
24	OFF	OFF	OFF	0.02	0.02	0.02	0.17
25	OFF	OFF	OFF	OFF	0.02	0.02	0.06
26	0.02	OFF	OFF	0.02	0.02	OFF	0.03
27	OFF	OFF	0.02	0.02	0.02	OFF	0.18
28	OFF	OFF	OFF	0.02	0.02	OFF	0.06
29	OFF	OFF	OFF	0.02	0.02	OFF	0.07
30	OFF	OFF	OFF	OFF	0.02	0.02	0.26
31	OFF	OFF	OFF	OFF	OFF	0.02	0.08

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes	CT's met everyday? (see back) Yes	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes
All 4-hour turbidity readings ≤ 1 NTU? Yes		
All turbidity readings < IFE ² triggers Yes		

Notes:	PRINTED NAME: Will Newdall	
	SIGNATURE:	1/30/2026
	PHONE #: (541)247-7459	CERT #:FE0054

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	Jan-26	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.94	60	56.4	12.0	7.12	17.6	YES	700
2	0.83	60	49.8	11.9	7.14	17.6	YES	700
3	0.77	60	46.2	13.7	7.14	15.2	YES	700
4	0.86	60	51.6	12.0	7.16	17.6	YES	700
5	0.81	60	48.6	11.6	7.15	17.9	YES	700
6	0.82	60	49.2	11.8	7.09	17.4	YES	700
7	0.86	60	51.6	11.8	7.06	17.3	YES	700
8	0.73	60	43.8	11.5	7.07	17.4	YES	700
9	0.72	60	43.2	10.3	7.08	18.9	YES	700
10	0.76	60	45.6	11.0	7.06	18.0	YES	700
11	0.84	60	50.4	9.9	7.12	19.9	YES	700
12	0.72	60	43.2	11.4	7.07	17.5	YES	700
13	0.73	60	43.8	11.2	7.00	17.3	YES	700
14	0.84	60	50.4	11.1	7.04	17.9	YES	700
15	0.79	60	47.4	11.9	7.12	17.4	YES	700
16	0.74	60	44.4	11.2	7.18	18.5	YES	700
17	0.75	60	45.0	12.0	7.18	17.5	YES	700
18	0.7	60	42.0	11.3	7.19	18.3	YES	700
19	0.85	60	51.0	11.7	7.18	18.1	YES	700
20	0.94	60	56.4	10.7	7.07	18.8	YES	700
21	0.9	60	54.0	10.7	7.05	18.6	YES	700
22	0.99	60	59.4	10.7	7.09	19.0	YES	700
23	0.98	60	58.8	10.6	7.06	18.9	YES	700
24	0.86	60	51.6	11.8	7.13	17.7	YES	700
25	0.92	60	55.2	11.1	7.11	18.5	YES	700
26	1	60	60.0	10.7	7.16	19.5	YES	700
27	0.93	60	55.8	10.5	7.21	19.9	YES	700
28	0.94	60	56.4	11.8	7.12	17.8	YES	700
29	0.95	60	57.0	11.8	7.11	17.7	YES	700
30	0.95	60	57.0	12.3	7.04	16.8	YES	700
31	1	60	60.0	13.1	7.10	16.0	YES	700

³ If Cl₂ at entry poin

Revised September 2016

WATER PRODUCTION RECORD FOR THE CITY OF GOLD BEACH

MONTH: <u>January</u>		YEAR: <u>2026</u>	PW ID: 4101059		
<u>WATER PRODUCTION</u>		<u>DISTRIBUTION SYSTEM CHLORINE RESIDUALS</u>			
<u>DATE</u>	<u>GALLONS PUMPED</u>	<u>LOCATION 1</u>	<u>RESIDUAL</u>	<u>LOCATION 2</u>	<u>RESIDUAL</u>
1	228,000	PW SHOP		HC OR WEDD	
2	572,000	PW SHOP		HC OR WEDD	
3	349,000	PW SHOP		HC OR WEDD	
4	462,000	PW SHOP		HC OR WEDD	
5	458,000	PW SHOP	.57	HC OR WEDD	
6	372,000	PW SHOP	.40	HC OR WEDD	
7	308,000	PW SHOP	.57	HC OR WEDD	
8	513,000	PW SHOP	.61	HC OR WEDD	
9	248,000	PW SHOP		HC OR WEDD	
10	541,000	PW SHOP		HC OR WEDD	
11	411,000	PW SHOP		HC OR WEDD	
12	407,000	PW SHOP	.57	HC OR WEDD	
13	235,000	PW SHOP	.37	HC OR WEDD	
14	501,000	PW SHOP	.63	HC OR WEDD	
15	320,000	PW SHOP	.50	HC OR WEDD	
16	508,000	PW SHOP		HC OR WEDD	
17	382,000	PW SHOP		HC OR WEDD	
18	437,000	PW SHOP		HC OR WEDD	
19	383,000	PW SHOP	Holiday	HC OR WEDD	
20	370,000	PW SHOP	.73	HC OR WEDD	
21	367,000	PW SHOP	.62	HC OR WEDD	
22	336,000	PW SHOP	.65	HC OR WEDD	
23	797,000	PW SHOP		HC OR WEDD	
24	95,000	PW SHOP		HC OR WEDD	
25	489,000	PW SHOP		HC OR WEDD	
26	449,000	PW SHOP	.65	HC OR WEDD	
27	282,000	PW SHOP	.73	HC OR WEDD	
28	396,000	PW SHOP	.74	HC OR WEDD	
29	381,000	PW SHOP	.72	HC OR WEDD	
30	398,000	PW SHOP		HC OR WEDD	
31	436,000	PW SHOP		HC OR WEDD	