

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: Mar-25

System Name:		Rainbow Rock Village MHP		ID#: 41 01062		WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.08	0.06	0.07				0.08
2	0.04	0.06				0.08	0.08
3	0.06		0.04	0.05			0.06
4		0.05	0.06				0.06
5	0.08	0.07	0.08				0.08
6			0.06	0.08	0.07		0.08
7		0.07	0.05			0.09	0.09
8	0.05	0.03					0.05
9		0.08	0.06	0.07			0.08
10	0.06	0.06	0.04				0.06
11	0.09			0.09			0.09
12		0.10			0.08	0.08	0.10
13		0.07	0.06				0.07
14			0.05	0.06			0.06
15	0.09	0.10				0.05	0.10
16	0.06	0.07					0.07
17	0.07	0.09	0.10			0.09	0.01
18	0.08			0.06	0.06		0.08
19		0.06	0.05				0.06
20		0.03	0.05				0.05
21	0.04	0.06	0.04				0.06
22			0.04	0.07			0.07
23	0.08	0.09					0.09
24			0.07	0.05		0.08	0.08
25	0.04						0.04
26		0.03	0.05		0.06		0.06
27			0.08	0.07			0.08
28	0.07	0.06					0.07
29		0.05	0.09				0.09
30			0.09	0.10			0.10
31		0.08	0.07				0.08
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes				CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All 4-hour turbidity readings ≤ 1 NTU? Yes				Yes		Yes	
All turbidity readings < IFE ² triggers Yes							
Notes:				PRINTED NAME: Brenda L Vasquez			
				SIGNATURE: Brenda L Vasquez		DATE: 4-2-25	
				PHONE #: (541) 254-1909		CERT #:T070226- D070226	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - :	
System Name:	Rainbow Rock Village MHP	ID#: 41 01062	Month/Year:	Mar-25	Disinfection <i>Giardia</i> Log Inactive:	1	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.05	58	60.9	10.9	6.85	34.8	YES	4.38
2	1.03	58	59.7	11.1	6.76	33.2	YES	4.44
3	1.03	58	59.7	10.4	6.78	35.0	YES	3.96
4	0.96	58	55.7	10.8	6.70	32.9	YES	2.71
5	0.85	58	49.3	10.0	6.81	35.6	YES	3.89
6	0.95	58	55.1	9.9	6.73	35.2	YES	4.31
7	0.88	58	51.0	9.6	6.78	36.2	YES	4.23
8	0.92	58	53.4	9.8	6.74	35.4	YES	4.51
9	0.86	58	49.9	9.9	6.72	34.7	YES	2.99
10	1.02	58	59.2	10.1	6.84	36.4	YES	3.89
11	1.09	58	63.2	8.9	6.82	39.3	YES	6.82
12	1.02	58	59.2	10.2	6.91	37.0	YES	4.31
13	0.86	58	49.9	9.6	6.90	37.7	YES	3.82
14	0.94	58	54.5	8.8	6.92	40.3	YES	4.38
15	0.97	58	56.3	10.0	6.85	36.5	YES	3.47
16	1.04	58	60.3	10.6	6.88	35.8	YES	3.4
17	0.93	58	53.9	11.0	6.95	35.3	YES	4.58
18	0.92	58	53.4	9.6	6.80	36.6	YES	4.51
19	1.04	58	60.3	10.2	6.81	35.8	YES	3.75
20	0.94	58	54.5	10.6	6.86	35.1	YES	5.14
21	0.86	58	49.9	11.0	6.80	33.3	YES	3.13
22	1.02	58	59.2	10.9	6.76	33.6	YES	4.72
23	1	58	58.0	10.6	6.91	36.0	YES	3.89
24	0.96	58	55.7	11.1	6.80	33.4	YES	4.23
25	0.9	58	52.2	11.4	6.87	33.4	YES	3.54
26	0.9	58	52.2	12.9	6.76	28.3	YES	4.51
27	0.86	58	49.9	12.1	6.67	29.7	YES	4.51
28	0.97	58	56.3	11.6	6.75	31.9	YES	4.31
29	1.04	58	60.3	11.8	6.85	32.8	YES	5.97
30	0.98	58	56.8	10.9	6.77	33.6	YES	2.99
31	0.93	58	53.9	10.5	6.81	34.7	YES	3.26

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours. Revised November 2022