


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lincoln
 Month/Year: Jul-22

Conventional or Direct Filtration

System Name:	Johnson Creek Water Service		ID#: 41 01072				WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.03	0.03	OFF	OFF	OFF	OFF	0.03	
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3	OFF	OFF	OFF	OFF	0.03	0.03	0.03	
4	0.03	0.03	0.01	OFF	OFF	OFF	0.03	
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6	OFF	OFF	OFF	OFF	0.03	0.02	0.03	
7	0.02	0.02	OFF	OFF	OFF	OFF	0.02	
8	OFF	OFF	OFF	OFF	OFF	0.05	0.05	
9	0.10	0.12	OFF	OFF	OFF	OFF	0.12	
10	OFF	OFF	0.03	0.03	OFF	OFF	0.03	
11	OFF	OFF	0.03	0.19	OFF	OFF	0.19	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	OFF	0.04	0.03	0.04	
14	0.04	OFF	OFF	OFF	OFF	OFF	0.04	
15	OFF	OFF	OFF	OFF	OFF	0.03	0.03	
16	0.03	0.03	OFF	OFF	OFF	OFF	0.03	
17	OFF	OFF	OFF	OFF	OFF	0.04	0.04	
18	0.04	0.04	0.03	OFF	OFF	OFF	0.04	
19	OFF	OFF	OFF	OFF	OFF	0.11	0.11	
20	0.03	0.03	OFF	OFF	OFF	OFF	0.03	
21	OFF	OFF	OFF	0.03	0.03	0.03	0.03	
22	0.03	0.03	OFF	0.03	OFF	OFF	0.03	
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24	OFF	OFF	OFF	OFF	OFF	0.04	0.04	
25	0.04	0.04	0.04	0.03	0.03	0.03	0.04	
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27	OFF	OFF	OFF	OFF	0.05	0.03	0.05	
28	0.01	0.04	0.08	OFF	OFF	0.03	0.08	
29	0.03	OFF	OFF	OFF	0.03	0.03	0.03	
30	0.04	OFF	OFF	OFF	OFF	OFF	0.04	
31	OFF	OFF	OFF	OFF	OFF	0.03	0.03	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		

Notes:	PRINTED NAME: Aaron Olson
	SIGNATURE:  DATE: 8-8-22
	PHONE #: (503) 487-7591 CERT #: T-09128

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A	Inactivation
System Name:	Johnson Creek Water Service	ID#: 41 01072	Month/Year:	Jul-22	Disinfection <i>Giardia</i> Log Inactive:	1	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Jul	1.1	128	140.8	14.0	7.4	34.2	Yes	80
2-Jul	OFF	128						
3-Jul	1.2	128	153.6	14.0	7.4	34.5	Yes	80
4-Jul	1.1	128	140.8	14.0	7.6	36.8	Yes	80
5-Jul	OFF	128						
6-Jul	1.1	128	140.8	14.0	7.5	35.4	Yes	80
7-Jul	OFF	128						
8-Jul	1.0	128	128.0	14.0	7.6	36.4	Yes	80
9-Jul	OFF	128						
10-Jul	1.0	128	128.0	14.0	7.5	35.0	Yes	80
11-Jul	0.9	128	115.2	15.0	7.5	32.4	Yes	80
12-Jul	OFF	128						
13-Jul	0.7	128	89.6	15.0	7.7	34.1	Yes	80
14-Jul	0.7	128	89.6	15.0	7.6	32.9	Yes	80
15-Jul	0.7	128	89.6	15.0	7.6	32.9	Yes	80
16-Jul	0.7	128	89.6	15.0	7.7	34.1	Yes	80
17-Jul	0.7	128	89.6	15.0	7.6	32.9	Yes	80
18-Jul	0.8	128	102.4	15.0	7.6	33.3	Yes	80
19-Jul	0.8	128	102.4	15.0	7.6	33.3	Yes	80
20-Jul	0.8	128	102.4	15.0	7.5	32.0	Yes	80
21-Jul	0.8	128	102.4	15.0	7.5	32.0	Yes	80
22-Jul	0.5	128	64.0	15.0	7.4	29.8	Yes	80
23-Jul	OFF	128						
24-Jul	0.7	128	89.6	15.0	7.5	31.7	Yes	80
25-Jul	0.8	128	102.4	15.0	7.4	30.9	Yes	80
26-Jul	OFF	128						
27-Jul	0.7	128	89.6	15.0	7.6	32.9	Yes	80
28-Jul	0.9	128	115.2	15.0	7.7	34.9	Yes	80
29-Jul	0.8	128	102.4	15.0	7.6	33.3	Yes	80
30-Jul	0.8	128	102.4	16.0	7.6	31.1	Yes	80
31-Jul	0.9	128	115.2	16.0	7.6	31.5	Yes	80

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350